STATE OF WASHINGTON DEPARTMENT OF ECOLOGY

GENERAL ORDER OF APPROVAL FOR RICH-BURN, SPARK IGNITION, GASEOUS FOSSIL FUEL-POWERED EMERGENCY ELECTRICAL GENERATORS

General Order No. 06-AQG-005 Issued Oct 6, 2006

Table 1: Applicability Criteria for this General Order of Approval

Criterion	Limitation		
Fuel	Gaseous fossil fuels, such as natural gas and		
	propane.		
Generator set size	Not greater than 850 brake horsepower (BHP) engine.		
Engine qualifications	Spark ignition		
	Rich burn design: Equipped with 3-way catalytic muffler.		
Location	Located in counties or at industrial facilities		
	under jurisdiction of the Department of Ecology		
Minimum distances to property line and	If the exhaust stack extends at least ten feet above		
publicly-accessible buildings vary with	the roof line, there are no location restrictions.		
engine size	Engines under 100 BHP may use a shorter stack		
	with location restrictions shown in Table 2.		
Minimum stack height criteria			
Minimum stack height varies	Engines over 100 BHP, exhaust stack must		
with engine size and location.	extend at least ten feet above the roof line		
·	Engines 100 BHP or less may use a shorter stack		
	with location restrictions shown in Table 2.		
Allowed operating hours	Not more than 30 hours in any calendar year for required testing, and not more than 500 hours total operation in any calendar year.		
Other criteria	1 The generator set is not part of a new major stationary source or major modification to a major stationary source which is subject to review under the Prevention of Significant Deterioration program		

Criterion	Limitation
	2. The addition of the generator set to an existing
	source does not make the source subject to the
	Air Operating Permit program or require a
	modification in an existing Air Operating
	Permit.

Table 2: Emergency Generator Placement, Small Engines with Stack Height Less Than 10
Feet Above Roofline

Engine BHP	Exhaust stack height above housing or adjacent building roofline	Minimum from property line (feet)	Minimum distance from nearest single story building (feet)	Minimum distance from nearest building two stories or greater in height (feet)
R	ural	Fewer than 24,000 r	persons live within 2	2 miles of the proposed
Envir	onment	generator.		
≤25	3 feet	Zero	Zero	Zero
•	4.5 feet	Zero	Zero	Zero
#*	6 feet	Zero	Zero	Zero
	10 feet	Zero	Zero	Zero
> 25 to	3 feet	Zero	75	75
50	6 feet	Zero	Zero	Zero
	10 feet	Zeio	Zero	Zero
> 50 to	3 feet	Zero	95	280
100	6 feet	Zero	Zero	184
-	10 feet	Zero	Zero	Zero
Urban Environ	ment	24,000 persons or m generator.	ore live within 2 m	iles of the proposed
≤25	3 feet	Zero	Zero	Zero
	4.5 feet	Zero	Zero	Zero
	6 feet	Zero	Zero	Zero
	10 feet	Zero	Zero	Zero
> 25 to	3 feet	Zero	Zero	Zero
50	6 feet	Zero	Zero	Zero
	10 feet	Zero	Zero	Zero
> 50 to	6 feet	Zero	Zero	145
100	10 feet	Zero	Zero	Zero

General Order of Approval No. 06-AQG-005 Rich-burn, fossil fuel-fired emergency generators Page 3 of 8

Process to apply for coverage

Submit:

1. The appropriate application forms.

Contact the Ecology office which covers the location of your proposed emergency generator set installation for a copy

Table 3: Ecology Permit Issuing Offices

Air Quality Program	Air Quality Program
Central Regional Office	Eastern Regional Office
15 West Yakima Ave Suite 200	N. 4601 Monroe
Yakima, WA 98902-3452	Spokane, WA 99205-1295
Tel. No 509-575-2490	Tel. No 509-329-3400
Industrial Section	Nuclear Waste Program
PO Box 47600	Hanford Unit
Olympia, WA 98504-7600	3100 Port of Benton Blvd
Iel No	Richland, WA 99354
	Tel. No. 509-372-7950
On the internet at:	
http://www.ecy.wa.gov/programs/air/airhome.html	

- 2. The application/coverage fee of \$500
- 3. Documentation of SEPA compliance

If SEPA for this project has been done by another agency, submit copy of Determination of Nonsignificance, Mitigated Determination of Nonsignificance, or Environmental Impact Statement issued for the project

If SEPA has not been done by another agency, submit a completed SEPA checklist and our SEPA processing fee of A copy of the checklist is available from the above contacts or on the internet at http://www.ecy.wa.gov/biblio/forms-sepa forms.html

Granting of Coverage

For those units that qualify for coverage, the applicant will receive a Coverage Order within 30 days after the complete application has been received.

For those units that do not qualify for coverage, the applicant will receive a letter from Ecology within 30 days after the application has been received. The letter will state why the unit does not qualify for coverage under this General Order of Approval.

General Order of Approval No. 06-AQG-005 Rich-burn, fossil fuel-fired emergency generators Page 4 of 8

Approval Conditions

5. General and siting criteria

Parameter	Requirement or limitation
Fuel usage requirements	Gaseous fossil fuels, such as natural gas and propane.
Annual hours of use	Not more than 30 hours in any calendar year for required
	testing, and not more than 500 hours total operation in any calendar year.
Exhaust stack	Vertical exhaust
	Minimize bends, obstructions, and building interference with exhaust dispersion
	A minimum of ten feet above the roofline or compliant with the requirements in Table 2.
Minimum distance from stack to property line and to publicly-	No restriction if stack is at least ten-feet above the roofline
accessible buildings	If stack is less than ten feet above the roofline, distances must comply with the requirements in Table 2
	If publicly-accessible buildings are constructed after submittal of this application that are within the distance limitation indicated in Table 2, permittee will immediately notify in writing the permit issuing office (Table 3)
	If the building being serviced by the emergency generator set is converted from private access to publicly-accessible, permittee will immediately notify in writing the permit issuing office (Table 3).

General Order of Approval No. 06-AQG-005 Rich-burn, fossil fuel-fired emergency generators Page 5 of 8

- 2. Engine qualifications:
 - 2.1 Rich-burn design.
 - 2.2 Equipped with three-way (non-selective catalytic) catalytic muffler.
 - 2.3 Not greater than 850 BHP at full load.
 - 2.4 Emissions limits:
 - 2.4.1 Nitrogen oxides (NO_X): Not greater than 1.5 grams per brake horsepower-hour (g/BHP-hr).
 - 2.4.2 Carbon monoxide (CO): Not greater than 1.33 g/BHP-hr.
 - 2.4.3 Particulate matter less than 10 microns in aerodynamic diameter (PM₁₀): Not greater than 0.07 g/BHP-hr.
 - 2 4 4 Volatile organic compounds: Not greater than 0.025 g/BHP-hr
 - 2.4.5 Engines capable of greater than 500 BHP: Formaldehyde emissions less than or equal to 350 parts per million dry volume basis (engine design compliant with 40 CFR 63 Subpart ZZZZ).
- 3 Emission limitations monitoring, recordkeeping and reporting requirements

	Monitoring	Recordkeeping	Reporting
Consistent with	None	None	None
the fuel economy			
of an engine		*, .	
maintained			-
according to			
recommendations			
and engine use			
1	Non-resettable		None
hours per year	hour meter		
for required		operating hours	
testing.		Keen most recent	٠,
Not more than		1	
· '		1 '	
· •		1	
'			
		1	
COO DIID 1			NT.
	None	Ivone	None
1 2 2/ "			
mumer.			
	the fuel economy of an engine maintained according to manufacturer's recommendations and engine use limit specified in this permit. Not more than 30 hours per year for required	the fuel economy of an engine maintained according to manufacturer's recommendations and engine use limit specified in this permit. Not more than 30 hours per year for required testing Not more than 500 hours per year total operating time 500 BHP or less engine capacity: Use three-way-catalytic (TWC)	the fuel economy of an engine maintained according to manufacturer's recommendations and engine use limit specified in this permit. Not more than 30 hours per year for required testing. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year total operating time. Not more than 500 hours per year operating hours to Ecology within 48 hours of request. None

Pollutant or	Limitation(s)	Monitoring	Recordkeeping	Reporting
parameter				
	Over 500 BHP engine capacity: TWC muffler and compliant with the emission standards in 40 CFR Part 60 Subpart IIII	None	Documentation from manufacturer that engine is certified to meet 40 CFR Part 60 Subpart IIII standards.	None
			Provide documentation to Ecology within 48 hours of request	
Visible emissions	10% exclusive of visible condensed water vapor as measured by EPA Method 9, 40 CFR Part 60, Appendix A (July 1, 2000)	Once each day during periods of operation, observe stack for visible emissions (smoke coming from the stack)	In either a permanent-bound log book or in readily accessible computer memory, record dates and times of observation and whether smoke can be seen coming from the stack	If corrective action fails to eliminate visible smoke within 24-hours, report in writing to permit issuing office (Table 3)
			If smoke can be seen coming from the stack, record any corrective actions taken. Provide records to Ecology within 48 hours of request.	

Daily visual stack exhaust observation procedure:

Observe the emergency generator set stack exhaust during daylight hours while the generator is in operation. Observe the exhaust from the stack from a location with a clear view of the stack and where the sun is not directly in the observer's eyes. The observer shall be at least 15 feet but not more than 0.25 mile from the stack.

General Order of Approval No. 06-AQG-005 Rich-burn, fossil fuel-fired emergency generators Page 7 of 8

Other Conditions of Approval

- 4 The emergency generator set installed shall be the one described in the application and Order issued granting coverage under this General Order of Approval.
- 5. The emergency generator set shall be installed where and as described in the permit application
- 6. The permittee shall submit to Ecology the date installation of the emergency generator set is started and completed¹
 - This Order shall become invalid if installation of the generator set is not begun within 18 months after receipt of final approval, if installation is discontinued for a period of 18 months or more, or if construction is not complete in a period of time deemed reasonable by Ecology
 - 6.2 Ecology may extend these deadlines upon a satisfactory showing that an extension is justified. The extension request must be received by the Ecology prior to expiration of the Order.

Christ Land

- 7. Operation and Maintenance.
 - 7.1 The permittee is to follow all recommended operation and equipment maintenance provisions supplied by the manufacturer of the unit.
 - 7.2 If the visual inspection for opacity indicates that any smoke can be seen, the permittee is to take immediate steps to bring the generator back into compliance with the limitation
- 8. Periodic emissions inventory information and other information may be requested by the Ecology Information requested by Ecology shall be submitted within 30 days of receiving the request unless otherwise specified. Ecology will supply the necessary forms to use for periodic emission inventory.
- 9 Annual/periodic Registration or Air Operating Permit fees. The applicant will pay the required registration fees within 30 days of receipt of the invoice from Ecology
- 10 Access to the source for the purpose of determining compliance with the terms of this General Order of Approval by Ecology staff shall be permitted during normal business hours. Failure to allow such access is grounds for an enforcement action under the Washington State Clean Air Act
- 11. The applicant is required to comply with applicable rules and regulations pertaining to air quality, and conditions of operation imposed upon issuance of this order. Any violation of applicable state and/or federal air quality rules and regulations or of the terms of this approval shall be subject to the sanctions provided in Chapter 70.94 RCW. Authorization under this Order may be modified, suspended, or revoked in whole or part for cause including, but not limited to, the following:
 - 11.1 Violation of any terms or conditions of this authorization;

¹ Electronic mail submittals of the notifications to the approving office are encouraged to reduce paperwork.

General Order of Approval No. 06-AQG-005 Rich-burn, fossil fuel-fired emergency generators Page 8 of 8

- 11.2 Obtaining this authorization by misrepresentation or failure to disclose fully all relevant facts.
- 12 The provisions of this General Order of Approval are severable and, if any provision of this authorization, or application of any provisions of this authorization to any circumstance, is held invalid, the application of such provision to their circumstances, and the remainder of this authorization, shall not be affected thereby

Legal Basis to Issue This General Order of Approval

The Department of Ecology Air Quality Program is issuing this General Order of Approval as allowed under Washington Administrative Code (WAC) 173-400-560. Receipt of a Coverage Order for installation of a specific unit under this approval satisfies the requirements of WAC 173-400-110.

Approvals		WASHING TO	}		· .	
PREPARED BY:	, 9/3/0°	L. S. Mark	APPROVED BY	Y:		
Bernarda	Stal	9	SIN	∞		
Date: 10/5/06		2651 20/00		06/05		
Bernard Brady, PE			Stuart A. Clark, l	Program Man	ager	
Air Quality Program		NONAGE.	Air Quality Prog	ram		
Department of Ecolog		200	2Department of E	cology	*	
grand the second of the second	منتشنية المخارس	The second secon	the state of the s	•		