. .

PROJECT REPORT Sabey Data Center Properties > Quincy, WA



Intergate Quincy Notice of Construction

Prepared By:

Ashley Jones – Managing Consultant Hui Cheng – Senior Consultant Jennifer Pohlman – Associate Consultant Sam Najmolhoda – Associate Consultant

TRINITY CONSULTANTS

20819 72nd Avenue South Suite 610 Kent, WA 98032 (253) 867-5600

> Revised April 2020 Revised March 2020 February 2020

Project 194801.0095



Environmental solutions delivered uncommonly well

TABLE OF	CONTENTS

1. EXECUTIVE SUMMARY	1-1
2. DESCRIPTION OF FACILITY	2-1
2.1. New Standby Gensets	
2.2. Existing Standby Gensets	
2.3. Fuel Storage Tanks	
2.4. Cooling System	2-3
3. EMISSION CALCULATIONS	3-1
3.1. Methodology	
3.1.1. Calculation Methodologies for New Main Gensets	
3.1.2. Calculation Methodologies for New Support Gensets	
3.1.3. Calculation Methodologies for As-Built Gensets	
3.1.4. Calculation Methodologies for Diesel Storage Tanks	
3.1.5. Calculation Methodologies for New Cooling Systems	
3.2. Emission Summary	
4. REGULATORY APPLICABILITY	4-1
4.1. NOC Applicability	
4.2. New Source Review	
4.3. New Source Performance Standards (NSPS)	
4.3.1. NSPS Subpart A	
4.3.2. NSPS Subpart IIII	
4.4. National Emission Standards for Hazardous Air Pollutants	
4.4.1. NESHAP Subpart A	
4.4.2. NESHAP Subpart ZZZZ	
4.5. State and Local Regulatory Applicability	
4.5.1. Washington Toxic Air Pollutant Regulations	
4.5.2. State Regulatory Applicability	
5. BEST AVAILABLE CONTROL TECHNOLOGY	5-1
5.1. BACT Methodology	
5.2. BACT Analysis for NO _x Emissions	
5.3. BACT Analysis for CO. PM. and VOC Emissions	
5.4. BACT Analysis for SO ₂ Emissions	
5.5. BACT Analysis for TAP Emissions	5-4
6. AIR DISPERSION MODELING	6-1
6.1. Dispersion Model Selection	
6.2. Meteorological Data	
6.3. Coordinate System	
6.4. Terrain Elevations	
6.5. Receptor Grids	
6.6. Building Downwash	
6.7. Emission Source Parameters	
6.8. Load Analysis	
$6.9. \text{ NO}_{\text{X}}$ to NO_{2} Conversion	
6.10. NAAQS Analysis	
- · · · · · · · · · · · · · · · · · · ·	

6.10.1.	Background Concentration	
6.10.2.	Monte Carlo	6-9
6.10.3.	NO2 NAAQS Analysis	6-10
6.10.4.	PM _{2.5} NAAQS Analysis	6-11
6.10.5.	PM ₁₀ NAAQS Compliance Demonstration	6-13
6.10.6.	CO NAAQS Compliance Demonstration	6-14
6.10.7.	SO2 NAAQS Compliance Demonstration	6-14
6.11. TAP	P Analysis	
APPENDIX A:	APPLICATION FORMS AND SEPA DOCUMENTATION	A-1
APPENDIX B:	SITE PLAN	B-1
APPENDIX C:	EMISSION CALCULATIONS AND SUPPORTING DOCUMENTATION	C-1
APPENDIX D:	BACT COST CALCULATIONS	D-1
APPENDIX E:	AERMOD MODELING PARAMETERS	E-1
APPENDIX F:	AERMOD LOAD ANALYSIS RESULTS	F-1
APPENDIX G:	ELECTRONIC MODEL FILES	G-1

	LIST OF FIGURES
Figure 6-1. 2014-2018 Wind Rose at Grant County International Airport (KMWH)	6-2
Figure 6-2. Modeled Buildings and Fenceline	6-4

LIST OF TABLES

Table 2-1. Operation Scenarios Summary	2-2
Table 3-1. Project Emission Summary	3-4
Table 4-1. Project TAP Emission Summary	4-4
Table 4-2. Grain Loading Limit Compliance Demonstration	4-5
Table 5-1. Criteria Pollutant Control Efficiencies	5-3
Table 5-2. Criteria Pollutant Control Cost Effectiveness	5-4
Table 5-3. TAP Control Efficiencies	5-4
Table 5-4. Total TAP Control Cost Effectiveness	5-5
Table 6-1. Modeled Sources	6-5
Table 6-2. Load Analysis Results	6-8
Table 6-3. Background Concentrations for NAAQS Analysis	6-9
Table 6-4. 1-hour NO ₂ NAAQS Model Source Parameters	6-10
Table 6-5. 1-hr NO ₂ NAAQS Model Result	6-11
Table 6-6. Annual NO ₂ NAAQS Model Source Parameters	6-11
Table 6-7. Annual NO ₂ NAAQS Model Result	6-11
Table 6-8. 24-hour PM _{2.5} NAAQS Model Source Parameters	6-12
Table 6-9. 24-hour PM _{2.5} NAAQS Model Result	6-12
Table 6-10. Annual PM _{2.5} NAAQS Model Source Parameters	6-13
Table 6-11. Annual PM _{2.5} NAAQS Model Result	
Table 6-12. PM ₁₀ NAAQS Model Source Parameters	6-13
Table 6-13. PM ₁₀ NAAQS Model Results	6-13
Table 6-14. CO NAAQS Model Source Parameters	6-14
Table 6-15. CO NAAQS Model Results	6-14
Table 6-16. SO ₂ NAAQS Model Source Parameters	6-15

Table 6-17.	SO ₂ NAAQS Model Results6	-15
Table 6-18.	Maximum Modeled TAP Concentrations	-16

Sabey Data Center Properties (Sabey) is proposing to construct two new data center buildings at Intergate Quincy (IGQ) data center campus in Quincy, Washington. The IGQ campus currently consists of three buildings (Building A, Building B [under construction], and Building C) operated by Sabey with multiple tenants.

As part of the IGQ project, two new data center buildings (Building D and Building E) will be constructed, with a total of 30 diesel-fired main generator sets (gensets) of up to 2,500 kW each. The main gensets will be used to provide standby electrical power to the data center during periods of interrupted power supply. There will also be 1 – 300 kW support genset per building for emergency lighting in the event of a complete power outage. In addition, each data center main genset will have a 2,000-gallon diesel belly tank, and there will be a total of 20 – 15,000-gallon stand-alone fuel storage tanks for the two buildings. Lastly, Sabey will install a total of 120 indirect evaporative cooling (IDEC) units for the new data center buildings.

In addition to the new proposed buildings, Sabey is submitting as-built information for existing buildings A, B, and C permitted under Approval Order 16AQ-E011¹. Overall, Sabey is reducing the number of permitted gensets from Buildings A, B, and C from 44 to 37.

This NOC application contains the following elements:

- Section 2. Description of Facility
- Section 3. Emission Calculations
- > Section 4. Regulatory Applicability
- > Section 5. Best Available Control Technology
- > Section 6. Air Quality Dispersion Modeling
- > Appendix A: Application Form and SEPA Documentation
- > Appendix B: Site Plan
- > Appendix C: Emission Calculations and Supporting Documentation
- > Appendix D: BACT Cost Calculations
- > Appendix E: AERMOD Modeling Parameters
- > Appendix F: AERMOD Load Analysis Results
- > Appendix G: Model Files

A Determination of Nonsignificance was issued by the State of Washington Department of Ecology (Ecology) on July 1, 2019 after a review of the completed SEPA checklist. A copy of the Determination of Nonsignificance is included in Appendix A for reference.

This application demonstrates that the proposed project meets the requirements for a NOC application under Washington Administrative Code (WAC) 173-400-110(2)(a). The required NOC form can be found in Appendix A.

¹ A construction extension was granted by Ecology on September 7, 2018 to allow installation of the remaining gensets through July 1, 2020.

Sabey's IGQ facility proposed Buildings D and E will be used as an electronic data storage facility. In the event of interrupted power supply from the utility, the facility will have diesel-fired gensets to provide power. The following equipment will be installed for the operation of the proposed data center buildings.

- 30 2,500 kW diesel-fired main gensets (permit applicable) with attached 2,000-gallon belly diesel fuel tanks (de minimis unit²);
- 20 15,000-gallon diesel storage tanks (de minimis unit²);
- > 2 300 kW support gensets; and
- > 120 indirect evaporative cooling units

A site plan is included in Appendix B.

2.1. NEW STANDBY GENSETS

Buildings D and E will have a total of 30 diesel-fired main gensets of up to 2,500 kW and 2 – 300 kW support gensets. The site plan (Appendix B) shows the locations of the proposed gensets. The main gensets will provide electrical power to the data center during periods of interrupted power supply. The support gensets will provide power for each building for emergency lighting in the event of a complete power outage. All the generators will be operated in accordance to the following:

- Maximum of fifty-five (55) hours per year per genset at any load for all intended purposes, including emergency operations, maintenance and testing operations;
- > In compliance with Tier 2 certification requirements for main gensets; and
- > In compliance with Tier 3 certification requirements for support gensets.

Sabey has evaluated five models for the proposed main gensets, including:

- Caterpillar 3516C, 2500 kW Standby Generator Set;
- > Kohler KD2250, 2250 kW Standby Generator Set;
- Kohler KD2500, 2500 kW Standby Generator Set;
- > Cummins DQKAF, 2250 kW Standby Generator Set; and
- > Cummins DQKAN, 2500 kW Standby Generator Set.

Sabey has evaluated two models for the proposed support gensets, including:

- > Caterpillar C9, 300 kW Generator Set; and
- > Cummins DQDAC, 300 kW Generator Set

Sabey has not determined the model for the main gensets or support gensets to be installed at IGQ. Therefore, all models are considered in this NOC application. The specifications from the vendors are included in Appendix C. Table 2-1 below summarizes the operation scenarios for all 32 gensets.

² As discussed in Section 3, the VOC emissions from the diesel storage tanks are expected to be below the de minimis level of 2 tons per year.

	Operations for Each Genset ^a		Total Operations for All Gensets ^b		
Operation Scenario	(hr/day/genset)	(hr/yr/genset)	(engine-hr/hr)	(engine-hr/day)	(engine-hr/yr)
Main Genset Running at Any Load	24	55	30	720	1,650
Support Genset Running at Any Load	24	55	2	48	110

Table 2-1. Operation Scenarios Summary

^a The operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation), the maximum number of days of such operation will be 6 days in any given year while keeping the total number of hours per engine per year equal to or below 55.

^b All 30 main gensets will be operated up to 24 hr/day/genset which corresponds to maximum of 720 engine-hrs in any single day.

2.2. EXISTING STANDBY GENSETS

Approval Order (AO) 16AQ-E011 for the IGQ facility permitted the installation of 44 – 2 MWe generators at Buildings A, B, and C. To provide maximum flexibility, emission calculations for the installation of these engines were based on the worst-case emission rates across all loads for each model for the following engine models:

- > Caterpillar Model 3516C, 2.0 MWe;
- > Caterpillar Model 3512C, 1.5 MWe;
- Cummins QSK60-G14 NR2 2.0 MWe;
- Cummins QSK50-G5 NR2 1.5 MWe;
- > MTU 16V4000G43 2.0 MWe; and
- > MTU 12V4000G43 1.5 MWe

Only 37 gensets have actually been built or are planned, and each engine is 2 MWe or smaller. Sabey will not be installing the remaining 7 permitted 2 MWe gensets and requests that the facility remain permitted for a total of 37 gensets for Buildings A, B, and C.

The actual models and quantities of as-built and planned engines are as follows:

- > 1 Caterpillar C9, 300 kW unit;
- > 2 Caterpillar C9, 250 kW units;
- > 23 Caterpillar 3516C, 2.0 MW units;
- > 6 Caterpillar 3512C, 1.5 MW units; and
- > 5 Planned engines ≤2.0 MWe in size

The 2.0 MW and 1.5 MW engines are main gensets used to provide power to the data center during periods of interrupted power supply. The 300 kW and 250 kW engines are used as support gensets to provide power for emergency lighting. Facility-wide potential to emit calculations are performed based on the engines actually installed or planned. Emission calculations for as-built engines are discussed in 3.1.3 and included in Appendix C. All of the as-built generators operate in accordance with AO 16AQ-E011 and the following:

- Maximum of fifty-seven and a half (57.5) hours per year per genset at any load for all intended purposes, including emergency operations, maintenance and testing operations;
- > In compliance with Tier 2 certification requirements for main gensets; and
- > In compliance with Tier 3 certification requirements for support gensets.

Genset locations are consistent with the original modeling, so ambient concentrations of all pollutants are expected to be as modeled or lower since there are fewer and smaller engines. The existing gensets are not considered part of the project and are evaluated in the analysis via the local and regional background concentration value provided by Ecology for NAAQS analyses.

2.3. FUEL STORAGE TANKS

Each genset will be equipped with a 2,000-gallon belly tank. Sabey also proposes to install a total of 20 standalone diesel fuel storage tanks with two tanks per utility yard. The stand-alone tanks are sized at 15,000 gallons each. The diesel stored in these tanks will be used as fuel for the standby generators. The site plan (Appendix B) shows the locations of the stand-alone tanks. As discussed in Section 4.1, Sabey expects these fuel storage tanks will be exempt from NOC permitting.

2.4. COOLING SYSTEM

Sabey has selected an IDEC system for the IGQ campus cooling needs. PM emissions from the cooling systems are calculated based on specification data for Munters Oasis units. PM emissions are conservatively calculated based on total water consumption of 241 gal/hr plus the recirculation flowrate of 84 gal/min, total dissolved solids of 550 ppm, and drift loss of 0.001%. The cooling units are equipped with a mist eliminator to achieve the 0.001% drift loss rate. As shown in Section 3, the new cooling units are collectively smaller than the WAC 173-400-110(5) de minimis thresholds, so the units were not further evaluated in this application.

This section describes each of the emission sources as well as the methodologies used to calculate criteria pollutant, HAP, and TAP emissions from each source at the IGQ facility. Detailed supporting calculations and supporting documentation for the emission calculations, including manufacturer specifications, can be found in Appendix C.

3.1. METHODOLOGY

Criteria pollutants emitted from the gensets include particulate matter (PM), particulate matter with aerodynamic diameter less than 10 microns (PM₁₀), particulate matter with aerodynamic diameter less than 2.5 microns (PM_{2.5}), sulfur dioxide (SO₂), carbon monoxide (CO), nitrogen oxides (NO_X), and volatile organic compounds (VOC).

3.1.1. Calculation Methodologies for New Main Gensets

Vendor supplied emissions data was reviewed in order to estimate the maximum emissions from the main gensets. Vendor specifications for all models confirm that the engines are Tier 2 certified³ standby engines. The following specification information is provided by the vendors. Specification sheets are provided in Appendix C:

- Caterpillar provides the genset power at various loads (10%, 25%, 50%, 75%, and 100%), corresponding engine power, fuel consumption rate, and emission data in gram per horsepower-hr (g/hp-hr) and pound per hour (lb/hr) for PM, NO_x, CO, and hydrocarbons. A single Caterpillar model is assessed, CAT 3516C 2500 kW.
- Cummins provides the genset power at various loads (10%, 25%, 50%, 75%, and 100%), corresponding engine power, fuel consumption rate, and guaranteed emission levels accounting for site variations in g/hphr for PM, NO_X, CO and hydrocarbons. Two Cummins models are assessed, DQKAF - 2250 kW and DQKAN -2500 kW.
- Kohler provides the genset power at various loads (10%, 25%, 50%, 75%, and 100%), corresponding engine power, fuel consumption rate, and guaranteed emission levels accounting for site variations in g/kWh for PM, NO_X, CO and hydrocarbons. Two Kohler models are assessed, KD2250 2250 kW and KD2500 2500 kW.

An hourly emission rate is calculated based on the provided g/hp-hr or g/kWh emission data for each vendor, except for Caterpillar, which provides lb/hr data. Vendor performance emission data is provided in Appendix C. For each main genset, the maximum hourly emissions are calculated based on the following conservative approaches:

- Maximum performance data across all loads and vendors is used to determine the hourly emission rate for NO_X, CO, and PM.
- Maximum hydrocarbons (HC) performance data across all loads and vendors is used to determine the hourly emission rate for VOC. The HC emission rates are also conservatively assumed to estimate condensable particulate matter (CPM) emissions.
- > PM₁₀ and PM_{2.5} emissions are the sum of filterable PM and CPM emissions determined above.
- An upper limit of 15 ppm sulfur content, per 40 CFR 80.510(b), is used to determine SO₂ emissions. Emission factors from Table 3.4-1, AP-42 and Table 3.3-1, AP-42 are used to calculate emissions of SO₂ from the main gensets and support gensets, respectively. The maximum engine power at 100% load is used.

³ Tier 2 certified engines to meet the emission standards set forth under 40 CFR Part 60, Subpart IIII.

Cold-start emissions occurring during the first minute of engine start-up are calculated for VOC, NO_X, CO, and PM based on data from California Energy Commission (CEC) "Air Quality Implications of Backup Generators in California". Maximum emission rate calculations conservatively assume 28 cold-start periods per year. Each cold start assumes the first minute of operation is impacted by the cold-start and the remaining 59 minutes in an hour is normal emission rates Detailed cold-start emission calculations are provided in Appendix C.

For HAP and TAP emissions emitted by the main gensets, emission factors in units of pounds per million British thermal unit (lb/MMBtu) are obtained from Tables 3.4-3 and 3.4-4, AP-42. The maximum hourly fuel consumption rate across all loads and vendors and the default diesel heat content of 0.137 MMBtu per gallon diesel fuel are used to determine the emission rates for each HAP/TAP, except for diesel particulate matter (DPM). DPM is characterized as the filterable portion of particulate matter and based on the filterable particulate matter emissions calculated for the criteria pollutant. SO₂, CO, and NO_x are also criteria pollutants and TAPs (notably, NO_x is a criteria pollutant, while NO₂ is the associated TAP). Values calculated for these criteria pollutants are presented for the TAP emissions for these pollutants. It is conservatively assumed that 10% of NO_x is emitted in the form of NO₂.

3.1.2. Calculation Methodologies for New Support Gensets

Similar calculation methodologies for the main gensets are applied to support gensets:

- Caterpillar provides the genset power at various loads (10%, 25%, 50%, 75%, and 100%), corresponding engine power, fuel consumption rate, and emission data in gram per horsepower-hr (g/hp-hr) and pound per hour (lb/hr) for PM, NO_x, CO, and hydrocarbons. The CAT C9 genset at 300 kW is assessed and included.
- Cummins provides the genset power at various loads (10%, 25%, 50%, 75%, and 100%), corresponding engine power, fuel consumption rate, and guaranteed emission levels accounting for site variations in g/hp-hr for PM, NO_x, CO and hydrocarbons. The Cummins DQDAC genset at 300 kW is assessed and included.
- The maximum hourly emission rates across all loads and models are used. Maximum emission rates account for cold-start emissions during the first minute of engine start-up, as described in Section 3.1.1. Detailed emission calculations and vendor supplied specification sheets are provided in Appendix C.
- > PM₁₀ and PM_{2.5} emissions are the sum of PM and CPM emissions determined above.
- Emission factors from Table 3.3-1, AP-42 for engines smaller than 600 hp is used to determine SO₂ emissions. The maximum engine power at 100% load is used.
- HAP and TAP emissions are estimated based on factors from Table 3.3-2, AP-42 for engines smaller than 600 hp. The maximum hourly fuel consumption rate across all loads are used for each HAP/TAP, except for DPM and other criteria pollutants that are also TAPs (i.e., SO₂, CO and NO₂).

3.1.3. Calculation Methodologies for As-Built Gensets

Facility-wide potential to emit calculations are performed based on the engines that have actually been installed or are planned to be installed under AO 16AQ-EO11, as discussed in Section 2.2. Vendor supplied emissions data was reviewed to determine the maximum emission rates of PM, SO₂, CO, NO_X, and VOC across all loads for each engine model. For engines that have multiple versions of specification sheets issued over the span of the installation phases, the worst-case emission factors are used. Specification sheets are provided in Appendix C.

An hourly emission rate is calculated based on the provided g/hp-hr or g/kWh emission data for each vendor, except for Caterpillar, which provides lb/hr data. For each main genset and each support genset, the maximum hourly emissions are calculated based on the following conservative approaches:

- Emissions for the installed units are based on the highest emission factor across all loads for the engine model. Emissions for the planned engines are calculated based on the most conservative emission rates, fuel usage rates, and exhaust flow rates between the two main engines models that have been installed to date.
- Maximum emission rates account for cold-start emissions during the first minute of engine start-up, as described in Section 3.1.1.
- > PM₁₀ and PM_{2.5} emissions are the sum of PM and CPM emissions.
- An upper limit of 15 ppm sulfur content, per 40 CFR 80.510(b), is used to determine SO₂ emissions. Emission factors from Table 3.4-1, AP-42 and Table 3.3-1, AP-42 are used to calculate emissions of SO₂ from the main gensets and support gensets, respectively. The maximum engine power at 100% load is used.
- HAP and TAP emission factors from Tables 3.4-3 and 3.4-4, AP-42 are used to calculate emissions from the main gensets. HAP and TAP emissions are estimated based on factors from Table 3.3-2, AP-42 for the support gensets. The maximum hourly fuel consumption rate across all loads and all models are used for each HAP/TAP, except for DPM and other criteria pollutants that are also TAPs (i.e., SO₂, CO and NO₂).

3.1.4. Calculation Methodologies for Diesel Storage Tanks

Minimal VOC emissions are expected from the working losses and standing losses of the diesel storage tanks. Due to the low vapor pressure of diesel (<0.01 psia) and the maximum operation of the gensets being at or below 55 hours per year per genset, the VOC emissions from the diesel storage tanks are expected to be minimal (< 1 tpy). Diesel generally contains trace amounts of HAPs, but the emissions are expected to be negligible. Therefore, the VOC and HAP emissions are not quantified for the diesel storage tanks.

3.1.5. Calculation Methodologies for New Cooling Systems

PM emissions from the cooling systems are calculated based on specification data for Munters Oasis units. PM emissions are conservatively calculated based on total water consumption of 241 gal/hr plus a recirculation flow rate of 84 gal/min, total dissolved solids content of 550 ppm, and a drift loss rate of 0.001%. The cooling units are equipped with a mist eliminator to achieve the 0.001% drift loss rate. Emissions of PM from operation of the cooling towers are summarized in Table 3-1 below and are below the WAC 173-400-110(5) de minimis thresholds. Furthermore, Sabey does not add any products or chemicals that contain a toxic air pollutant.

3.2. EMISSION SUMMARY

Project emissions are summarized in Table 3-1. Maximum hourly emission rate across all vendors and loads, determined by the approach discussed in Section 3.1, are used to determine the hourly, daily, and annual emission rates for this project. Detailed emission calculations are provided in Appendix C.

	Maximum	Emissions for All Engines ^a	Proposed	Diesel Storage Tanks	Cooling Systems	Project Total	Facility- Wide PTE
Pollutant	(lb/hr)	(lb/day)	(tpy)	(tpy)	(tpy)	(tpy)	(tpy)
PM 10 b	102.41	2457.86	2.20		1.27E-01	2.33	5.92
PM _{2.5} b	102.41	2457.86	2.20		1.27E-01	2.33	5.92
SO2 ^c	3.29	79.04	0.09			0.09	0.20
CO ^d	538.50	12924.04	13.95			13.95	18.13
NO _X ^d	2013.87	48332.85	55.35			55.35	94.88
VOC	38.58	925.86	1.03	<1		2.03	4.12
HAPs	1.15	27.52	0.03	< 0.01		0.04	0.08

^a Emissions calculated follow the operation scenarios in Table 2-1.

^b Diesel filterable PM hourly emissions are the maximum based on engine specifications across all loads and models. PM₁₀ and PM_{2.5} emissions are the filterable PM emission rates plus the CPM emission rate for each. CPM emissions are conservatively assumed to be the same as hydrocarbon emissions from vendor data.

^c SO₂ emissions are calculated conservatively for 100% load (i.e., maximum engine power). SO₂ emissions are based on maximum sulfur content allowed in ULSD (15 ppm) for main gensets.

^d NO_X and CO hourly emissions are the maximum based on engine specifications across all loads and models.

The facility is located in Quincy, Washington, which is in attainment for all criteria pollutants. The following section analyzes the regulatory requirements potentially applicable to the emission sources identified for the IGQ facility expansion project.

4.1. NOC APPLICABILITY

A NOC permit application must be filed and an approval order issued by Ecology prior to the construction or modification of an affected facility per WAC 173-400-110(2)(a), unless the installation meets exemptions under WAC 173-400-110(4) or (5). The proposed project involves construction of 30 main emergency gensets, 2 support emergency gensets, and 120 cooling units. These emission units do not meet any of the exemption criteria under WAC 173-460-110; therefore, the construction of the units requires NOC approval.

The diesel storage tanks do not meet the categorical exemptions under WAC 173-400-110(4); however, "Ecology strongly recommends that an owner or operator contact the permitting authority to determine the exemption status of the storage tanks prior to their installation". As discussed in Section 3.2, the emissions from the diesel storage tanks are expected to be minimal and well below the VOC exemption level. Sabey believes these storage tanks are exempt from NOC approval, and requests Ecology's review and concurrence on this determination.

4.2. NEW SOURCE REVIEW

A project in an attainment area is subject to the Prevention of Significant Deterioration (PSD) permitting program under WAC 173-400-700 if the project is either a "major modification" to an existing "major source," or is a new major source itself.

The IGQ facility is not a listed source category with a major source threshold of 100 tpy. Therefore, the major source threshold for the IGQ facility is 250 tpy of any regulated pollutant. As shown in Table 3-1, the PTE of the IGQ facility will be well below the 250 tpy threshold for all criteria pollutants. Therefore, the IGQ facility is not considered a major source and does not trigger major source review.

4.3. NEW SOURCE PERFORMANCE STANDARDS (NSPS)

WAC 173-400-115 adopts federal NSPS by reference. NSPS apply to certain types of equipment that are newly constructed, modified, or reconstructed after a given applicability date. NSPS applicability is reviewed below for each emission unit for the expansion project.

4.3.1. NSPS Subpart A

All affected sources subject to an NSPS are also subject to the applicable general provisions of NSPS Subpart A unless specifically excluded by the source-specific NSPS. NSPS Subpart A addresses the following for facilities subject to a source-specific NSPS:

- > Initial construction/reconstruction notification
- > Initial startup notification
- > Performance tests
- > Performance test date initial notification

- > General monitoring requirements
- > General recordkeeping requirements
- > Semi-annual monitoring system and/or excess emission reports

The NSPS requirements are different depending on whether the source is classified as a new construction, reconstruction, or modification. The following definitions in 40 CFR 60.2 are pertinent to this classification:

Existing facility means, with reference to a stationary source, any apparatus of the type for which a standard is promulgated in this part, and the construction or modification of which was commenced before the date of proposal of that standard; or any apparatus which could be altered in such a way as to be of that type.

Modification means any physical change in, or change in the method of operation of, an existing facility which increases the amount of any air pollutant (to which a standard applies) emitted into the atmosphere by that facility or which results in the emission of any air pollutant (to which a standard applies) into the atmosphere not previously emitted.

The IGQ Buildings D and E will be newly constructed facilities. Therefore, the new construction classification is used to determine the applicable requirements in the subsequent NSPS regulations.

4.3.2. NSPS Subpart IIII

Subpart IIII applies to non-fire pump compression ignition (CI) internal combustion engines (ICE) manufactured after April 2006 and fire pump CI ICE manufactured after July 1, 2006. Therefore, the emergency gensets are subject to Subpart IIII. The requirements for each of the genset include:

- > Purchase a certified engine.
- > Use ultra-low sulfur diesel (ULSD) with sulfur content less than 15 ppm.
- > Operate and maintain the engines according to manufacturer's emission-related written instructions.
- Operate for less than 100 hours per year for maintenance and testing, 50 of which can be non-emergency operations.
- Install a non-resettable hour meter to record time of operation of the engine and reason the engine was in operation.

As shown in the vendor specifications (Appendix C), the genset options Sabey is proposing are certified Tier 2 engines for the main gensets and certified Tier 3 engines for the support gensets. Sabey will purchase certified engines and will operate in accordance with the requirements set forth under NSPS Subpart IIII.

4.4. NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS

National Emission Standards for Hazardous Air Pollutants (NESHAPs) have been established in 40 CFR Part 61 and Part 63 to control emissions of Hazardous Air Pollutants (HAP) from stationary sources. The applicability of NESHAP rules often depends on a facility's major source status with respect to HAP emissions. Under 40 CFR Part 63, a major source is defined as "any stationary source or group of stationary sources located within a contiguous area and under common control that emits or has the potential to emit considering controls, in the aggregate, 10 tons per year or more of any HAP or 25 tons per year or more of any combination of HAP." The IGQ facility is considered an area source (not a major source) of HAP based on its PTE, as represented in Appendix C. The new emissions units from the IGQ facility expansion project are not subject to any Part 61 NESHAPs.

4.4.1. NESHAP Subpart A

All affected sources subject to a Part 63 NESHAP are also subject to the general provisions of Part 63 Subpart A unless specifically excluded by the source-specific NESHAP. Per NESHAP Subpart A, the following definitions are important when characterizing whether the affected source is new, reconstructed, or existing:

Affected source means the collection of equipment, activities, or both within a single contiguous area and under common control that is included in a section 112(c) source category or subcategory for which a section 112(d) standard or other relevant standard is established pursuant to section 112 of the Act. Each relevant standard will define the "affected source," as defined in this paragraph.

New Source means any affected source the construction or reconstruction of which is commenced after the Administrator first proposes a relevant emission standard under this part establishing an emission standard applicable to such source.

Reconstruction, unless otherwise defined in a relevant standard, means the replacement of components of an affected or a previously non-affected source to such an extent that the fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable new source.

Existing Source means any affected source that is not a new source.

NESHAP Subpart A applies to the IGQ facility because the proposed emergency gensets are considered new sources under Subpart ZZZZ.

4.4.2. NESHAP Subpart ZZZZ

The proposed emergency gensets will meet the requirements of NESHAP Subpart ZZZZ by meeting the applicable requirements of NSPS Subpart IIII. Pursuant to 40 CFR 63.6590(c), "no further requirements apply for such engines under this part." Therefore, compliance with NSPS Subpart IIII will ensure that the facility is also in compliance with NESHAP Subpart ZZZZ.

4.5. STATE AND LOCAL REGULATORY APPLICABILITY

4.5.1. Washington Toxic Air Pollutant Regulations

In Washington, all new sources emitting TAPs are required to show compliance with the Washington TAP program pursuant to WAC 173-460. Ecology has established a de minimis emission rate, a small quantity emission rate (SQER), and an acceptable source impact level (ASIL) for each listed TAP. If the total project-related TAP emissions increase exceeds the de minimis level for a pollutant, then permitting and a control technology review is triggered. If the emissions increase exceeds its respective SQER, further determination of compliance with the ASIL using air dispersion modeling is required. Table 4-1 summarizes the project TAP emissions, and the detailed calculations are included in Appendix C.

Pollutant	Averaging	De Minimis	SQER	Project Total ^a	Modeling	
	Period	(lbs	(lbs/averaging perio		kequired?	
Acetaldehyde	year	3.00E+00	6.00E+01	1.25E+00	De Minimis	
Acrolein	24-hr	1.30E-03	2.60E-02	1.49E-01	Yes	
Benzene	year	1.00E+00	2.10E+01	3.08E+01	Yes	
Benzo(a)anthracene	year	4.50E-02	8.90E-01	2.50E-02	De Minimis	
Benzo(a)pyrene	year	8.20E-03	1.60E-01	1.01E-02	No	
Benzo(b)fluoranthene	year	4.50E-02	8.90E-01	4.36E-02	De Minimis	
Benzo(k)fluoranthene	year	4.50E-02	8.90E-01	8.60E-03	De Minimis	
1,3-Butadiene	year	2.70E-01	5.40E+00	1.36E-02	De Minimis	
Chrysene	year	4.50E-01	8.90E+00	6.01E-02	De Minimis	
Dibenz(a,h)anthracene	year	4.10E-03	8.20E-02	1.38E-02	No	
Formaldehyde	year	1.40E+00	2.70E+01	3.50E+00	No	
Indeno(1,2,3-cd)pyrene	year	4.50E-02	8.90E-01	1.64E-02	De Minimis	
Naphthalene	year	2.40E-01	4.80E+00	5.13E+00	Yes	
Propylene	24-hr	1.10E+01	2.20E+02	5.17E+00	De Minimis	
Toluene	24-hr	1.90E+01	3.70E+02	4.87E+00	De Minimis	
Xylenes	year	8.20E-01	29	7.67E+00	No	
Diesel Engine Exhaust,	Vear	0.032	0.639		Vos	
Particulate	year	0.032	0.037	3.42E+03	165	
SO ₂	1-hr	4.6E-01	1.20E+00	3.29E+00	Yes	
СО	1-hr	1.10E+00	4.30E+01	5.39E+02	Yes	
NO 2 ^b	1-hr	4.60E-01	8.70E-01	2.01E+02	Yes	

Table 4-1. Project TAP Emission Summary

Air dispersion modeling was performed for TAPs exceeding their respective SQERs, including acrolein, benzene, naphthalene, SO₂, CO, NO₂ and diesel engine exhaust particulate (DPM). The results presented in Section 0 demonstrate that the ASILs are met for acrolein, naphthalene, benzene, SO₂ and CO. Sabey will perform a Second Tier Review in accordance to WAC 173-460-090 for DPM and NO₂. The Second Tier Review will be submitted under a separate cover based on this NOC application.

4.5.2. State Regulatory Applicability

The following general Ecology regulations are relevant to the IGQ facility per WAC 173-400-040:

- > No air contaminant shall exceed the opacity limit of 20% for more than 3 minutes in any one hour;
- SO₂ emissions shall be limited to less than 1,000 ppm on a dry basis, corrected to 7% oxygen.

In addition, WAC 173-400-050(1) limits particulate matter emissions of combustion sources to 0.1 grains/dscf. Table 4-2 below demonstrates that all engines under any operating load or scenario would demonstrate compliance with this limit and actual emissions would be lower.

Emission Unit	Maximum PM Emission Rate ^a (lb/hr)	Minimum Flow Rate ^b (scfm)	Maximum PM Emission Rate ^c (gr/dscf)	PM Combustion Limit (gr/dscf)	In Compliance?	
Main Genset	2.12	1,801	0.04	0.1	Yes	
Support Genset	0.19	333	0.03	0.1	Yes	
 ^a Maximum PM filterable emission rate including cold start emissions for a single engine across all loads and models. Based on 100% load for main genset and 50% load for support genset. ^b Minimum flow rate across all loads and models for a single engine. Based on 10% load for both the main genset and support genset. 						
 ^b Minimum flow rate across all loads and models for a single engine. Based on 10% load for both the main genset and support genset. ^c Maximum grain loading rate for the main genset is for the 10% load which has an emission rate of 0.63 lb/hr/engine and a flow. 						

 Table 4-2. Grain Loading Limit Compliance Demonstration

^c Maximum grain loading rate for the main genset is for the 10% load, which has an emission rate of 0.63 lb/hr/engine and a flow rate of 1,801 scfm. Maximum grain loading rate for the support engines is for the 25% load, which has an emission rate of 0.13 lb/hr/engine and a flow rate of 510 scfm.

Under WAC 173-400-113, Ecology requires all new sources or modifications to existing sources to use BACT for all pollutants not previously emitted or whose emissions would increase as a result of the new source or modification. A BACT analysis is included in this section for all emission units subject to NOC permitting.

5.1. BACT METHODOLOGY

In a memorandum dated December 1, 1987, the EPA stated its preference for a "top-down" analysis for PSD applications.⁴ For this minor New Source Review (NSR) BACT analysis, Sabey is using the same top-down approach. The first step in this approach is to determine, for the emission unit in question, the most stringent control available for a similar or identical source or source category. If it can be shown that this level of control is technically, environmentally, or economically infeasible or inappropriate on the basis of energy concerns for the unit in question, then the next most stringent level of control is determined and similarly evaluated. This process continues until the BACT level under consideration cannot be eliminated by any substantial or unique technical, environmental, economic, or energy-related objections.

Presented below are the five basic steps of a top-down BACT review as identified by the EPA.⁵

STEP 1 – IDENTIFY ALL CONTROL TECHNOLOGIES

Available control technologies are identified for each emission unit in question.

STEP 2 – ELIMINATE TECHNICALLY INFEASIBLE OPTIONS

After the identification of control options, an analysis is conducted to eliminate technically infeasible options. A control option is eliminated from consideration if there are process-specific conditions that prohibit the implementation of the control.

STEP 3 – RANK REMAINING CONTROL TECHNOLOGIES BY CONTROL EFFECTIVENESS

Once technically infeasible options are removed from consideration, the remaining options are ranked based on their control effectiveness. If there is only one remaining option, or if all of the remaining technologies could achieve equivalent control efficiencies, ranking based on control efficiency is not required.

STEP 4 – EVALUATE MOST EFFECTIVE CONTROLS AND DOCUMENT RESULTS

Beginning with the most efficient control option in the ranking, detailed economic, energy, and environmental impact evaluations are performed. If a control option is determined to be economically feasible without adverse energy or environmental impacts, it is not necessary to evaluate the remaining options with lower control efficiencies.

The economic evaluation centers on the cost effectiveness of the control option. Costs of installing and operating control technologies are estimated and annualized following the methodologies outlined in the EPA's *Control*

⁴ U.S. EPA, Office of Air and Radiation. Memorandum from J.C. Potter to the Regional Administrators. Washington, D.C. December 1, 1987.

⁵ U.S. EPA. *Draft New Source Review Workshop Manual*, Chapter B. Research Triangle Park, North Carolina. October 1990.

Cost Manual (CCM)⁶ and other industry resources. Cost effectiveness is expressed in dollars per ton of pollutant controlled. Objective analyses of energy and environmental impacts associated with each option are also conducted.

STEP 5 - SELECT BACT

In the final step, one pollutant-specific control option is proposed as BACT for each emission unit under review based on evaluations from the previous step.

Since there have been many BACT analyses performed for other data centers in Washington recently (Vantage Data Center, CyrusOne with permits issued in 2017 and 2019, respectively) ⁷, Sabey completed the BACT analysis based on cost information available in the CCM and in the applications for these similar facilities. Detailed cost calculations are available in Appendix D.

5.2. BACT ANALYSIS FOR NO_X EMISSIONS

Typical NO_X emission control technologies include add-on controls, such as selective catalytic reduction (SCR), Tier 4 integrated control systems, selective non-catalytic reduction (SNCR), non-selective catalytic reduction (NSCR), and other technologies without add-on controls, such as combustion technology meeting EPA standards. Other emerging technologies, including NO_X adsorbers, water injection, ozone injection, and activated carbon adsorption, which are not commercially available for stationary diesel generators, are not discussed in this case.

SCR has higher control effectiveness than SNCR and NSCR for the following reasons:

- SNCR does not use a catalyst for the reaction between ammonia or urea with NO_X to reduce NO_X emissions, unlike SCR. Lack of a catalyst requires a higher temperature to achieve the chemical reaction, which makes SCR applicable to more combustion sources.
- NSCR requires that no excess air is present in the stream and requires a catalyst without a reagent. However, diesel exhaust oxygen levels vary widely depending on engine load, which does not meet the requirement of zero excess air. Therefore, NSCR is not considered technologically applicable to the proposed diesel combustion engines.

Control technologies that are not add-on controls, including combustion technology meeting EPA Tier 2 emission standards for the larger main gensets and Tier 3 emission standards for the smaller support gensets as well as the operating and maintenance requirements under 40 CFR Part 60 Subpart IIII, are considered feasible options for this project.

A cost analysis was performed for the SCR and Tier 4 Integrated Control options for the main gensets and support gensets in accordance to the EPA's CCM methodologies as well as the information available from the applications for similar data centers recently permitted. The cost analysis is based on the following conservative assumptions:

The direct emission control package cost for the main gensets is conservatively determined based on the average unit price of a 3 mega-watt equivalent (MWe) genset from the Vantage application and a 2,250 kWe genset from the CyrusOne application. Costs for the support gensets are estimated using the 0.6 power rule.

⁶ U.S. EPA, Office of Air Quality Planning and Standards. *EPA Control Cost Manual*, 7th edition, updating in progress. <u>https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution</u> ⁷ Vantage Data Center, Approval Order No. 16AQ-E026; CyrusOne Data Center, Approval Order 19AQ-E052

- Indirect costs for SCR and Tier 4 Integrated Control are calculated using the most conservative ratio or fixed-cost approach presented in the Vantage and CyrusOne applications.
- It is conservatively assumed that the costs of operating labor, supervisory labor, and electricity associated with operating the SCR and Tier 4 Integrated Control System are negligible.
- > The acceptable control cost threshold is assumed to be \$12,000 per ton NO_X.⁸

The calculated cost to control per ton of NO_X is \$19,002 for the SCR based on the conservative assumptions listed above for cost calculations. SCR is therefore cost prohibitive for the project. The cost to control per ton of NO_X for the Tier 4 Integrated Control System is \$22,227. Tier 4 Integrated Control is cost prohibitive for the project.⁹ Sabey proposes meeting EPA Tier 2 standards as BACT for NO_X for the main gensets and EPA Tier 3 standards for the support gensets.

5.3. BACT ANALYSIS FOR CO, PM, AND VOC EMISSIONS

Available add-on control technologies for controlling CO, PM, and VOC emissions include diesel oxidation catalyst (DOC), diesel particulate filter (DPF), Tier 4 Integrated Control systems, and three-way catalyst. Stack tests at Titan Data Center in Moses Lake, WA indicate that use of three-way catalysts may result in a NO_X emission increase. Therefore, three-way catalysts are not considered further in this assessment. Technologies without add-on controls, such as meeting EPA Tier 2 standards, are also considered feasible options for this project. The control efficiencies of the feasible control technologies are summarized in Table 5-1.

	DPF Removal	DOC Removal	Tier 4 Removal
Pollutant	%	%	%
Particulate Matter (PM)	90%	25%	88%
Carbon Monoxide (CO)	80%	80%	80%
Volatile Organic Compounds (VOC)	70%	70%	70%

Table 5-1. Criteria Pollutant Control Efficiencies

A cost analysis is performed for DPF, DOC, and Tier 4 Integrated Control for the main and support gensets following similar approaches to the NO_x cost analysis, including the following conservative assumptions:

- The main gensets direct emission control package costs for DPF, DOC, and Tier 4 Integrated Control are conservatively determined based on the average unit price of a 3 MWe genset from the Vantage application and a 2,250 kWe genset from the CyrusOne application. Costs for the support gensets are estimated using the 0.6 power rule.
- Indirect costs for DPF, DOC, and Tier 4 Integrated Control are calculated using the most conservative ratio or fixed-cost approach presented in the Vantage and CyrusOne applications.
- It is conservatively assumed that the operating labor, supervisory labor, and electricity associated with operating the DPF, DOC, and Tier 4 Integrated Control are negligible.
- > It is also conservatively assumed that the maintenance cost will be negligible, even though DPF will require regular cleaning when actually operated.
- The acceptable control cost thresholds are assumed to be \$12,000 per ton PM, \$5,000 per ton CO, and \$12,000 per ton VOC.⁹

⁸ Consistent with Vantage and CyrusOne applications' assessment of acceptable unit costs.

⁹ Consistent with Vantage and CyrusOne BACT cost effectiveness assessments.

The annualized cost of each control technology and the cost effectiveness of each control technology with respect to the quantity of PM, CO, and VOC removed is presented in Table 5-2 below. Detailed control cost calculations are provided in Appendix D.

	Annualizad	Cost Effecti	st Effectiveness (\$/ton removed		Total Reasonable	Reasonable
Technology Cost (\$ /w		РМ	СО	VOC	Annual Cost for	Control
					Combined Pollutants ^a	Device Cost?
DPF	\$431,940	\$280,676	\$38,677	\$595,270	\$83,015	No
DOC	\$96,387	\$225,477	\$8,631	\$132,834	\$69,677	No
Tier 4	\$1,107,454	\$735,982	\$99,163	\$1,526,218	\$680,492	No

Table 5-2. Criteria Pollutant Control Cost Effectiveness

^a Reasonable annual costs are calculated by multiplying Ecology's Acceptable Unit Costs (consistent with recent CyrusOne and Vantage applications) by the calculated total pollutants removed for each pollutant. The sum of the reasonable annual cost for each individual pollutant is then compared to the calculated annualized cost of the given control.

Each \$/ton value is cost prohibitive.⁹ Therefore, Sabey proposes meeting EPA Tier 2 emission standards for the main engines and EPA Tier 3 for the support engines, as well as the operating and maintenance requirements under 40 CFR Part 60 Subpart IIII as BACT for PM, CO, and VOC.

5.4. BACT ANALYSIS FOR SO₂ EMISSIONS

Commercially available add-on control technologies are not generally available for SO_2 emissions from engines. The main source of SO_2 from engines is the sulfur in the fuel. As discussed in Section 4.3.2, the engines are required to fire ULSD with sulfur content less than 15 ppm. Therefore, Sabey proposes using ULSD as BACT for SO_2 emissions.

5.5. BACT ANALYSIS FOR TAP EMISSIONS

WAC 173-460-060 requires all projects with emissions exceeding the de minimis value for a TAP to employ BACT for that TAP, called tBACT. As shown in Table 4-1, there are 11 TAPs with emissions greater than the respective de minimis levels. These TAPs are either also criteria pollutants (i.e. SO₂, CO, and NO₂) or are emitted as PM or VOC. Reasonable annual costs for TAPs that are also criteria pollutants are calculated as described in Section 5.2 to 5.4.

Reasonable annual costs for other TAPs that are emitted as PM or VOC are calculated assuming an expected control efficiency consistent with that for PM or VOC, respectively. Expected control efficiencies are outlined in Table 5-3 below.

	DPF Removal	DOC Removal	Tier 4 Removal	
Pollutant	%	%	%	
TAP Emitted as PM	90%	25%	88%	
TAP Emitted as VOC	70%	70%	70%	

Table 5-3. TAP Control Efficiencies

The annualized cost of each control technology and the total reasonable annual cost of each control technology with respect to the total quantity of TAP removed is presented in Table 5-4 below. Total reasonable annual cost is calculated using the Hanford ceiling cost method¹⁰. Detailed cost calculations are provided in Appendix D.

Technology	Annualized Cost (\$/yr)	Total Reasonable Annual Cost for Combined TAP (\$/yr) ^a	Reasonable Control Device Cost?
SCR ^b	\$946,762	\$92,023	No
DPF	\$431,940	\$120,776	No
DOC	\$96,387	\$40,055	No
Tier 4	\$1,107,454	\$210,315	No

Table 5-4. Total TAP Control Cost Effectiveness

^a Reasonable annual costs are calculated by multiplying the maximum ceiling value (based on the Hanford method) by the calculated total pollutants removed for each pollutant. The sum of the reasonable annual cost for each individual pollutant is then compared to the calculated annualized cost of the given control.

 $^{\rm b}$ SCR only controls the TAP NO₂.

The annualized cost for each control technology is higher than its respective total reasonable annual cost for combined TAP, meaning that each control device is cost prohibitive. Therefore, the proposed tBACT for controlling these 11 TAP is meeting EPA Tier 2 emission standards for main gensets and EPA Tier 3 emission standards for support gensets as well as the operating and maintenance requirements under 40 CFR Part 60 Subpart IIII.

¹⁰ Haass, C, Kovach, J., Kelly,S., & Turner, D. (2010). Evaluation of Best Available Control Technology for Toxics (tBACT), Double Shell Tank Farms Primary Ventilation Systems Supporting Waste Transfer Operations <u>https://www.osti.gov/servlets/purl/991923</u>

As discussed in Section 4.5.1, air dispersion modeling was performed for the TAPs showing emissions greater than their respective SQER. Additionally, an analysis for IGQ facility to demonstrate compliance with the National Ambient Air Quality Standards (NAAQS) for PM₁₀, PM_{2.5}, NO₂, CO, and SO₂ is also completed. This section discusses the methodologies applied for the air dispersion modeling analysis and presents the results for the TAP analysis and NAAQS analysis.

Note that after the modeling was completed and previous NOC application submitted, it was determined by Sabey that the final design of Building D and the associated equipment will require Building D to be shifted 20 feet to the West. Since shifting the building will move the building more to the interior of the property, and it is a very small shift (less than the resolution of current receptor grid at the fenceline) it is expected that modeled impacts will be largely unimpacted, and the current modeling analysis is expected to be a conservative demonstration. Revised modeling has not been conducted. Ecology provided concurrence that no re-modeling was required for this change on April 3, 2020¹¹. Coordinates and figures presented in this section reflect the modeled locations and not the new proposed locations.

6.1. DISPERSION MODEL SELECTION

The American Meteorological Society/Environmental Protection Agency Regulatory Model Improvement Committee (AERMIC) modeling system, the most recent AERMOD dispersion model version 19191 with Plume Rise Model Enhancements (PRIME) advanced downwash algorithms, is used as the dispersion model in the air quality analysis.

6.2. METEOROLOGICAL DATA

Five years of surface meteorological data are taken from the nearest airport, Grant County International Airport (Station ID: KMWH; WBAN ID: 24110) using 1-min ASOS data. The data from the five most recent years (2014 through 2018) is used. The meteorological data is processed using AERMET version 18081. The 1-min wind data was processed using the latest version of AERMINUTE pre-processing tool (version 15272). Quality of the 1-minute data was verified by comparison to the hourly ISHD data from KMWH, which showed only small differences typical of 1-minute and hourly wind data comparisons. The "Ice-Free Winds Group" AERMINUTE option was selected due to the fact that a sonic anemometer was used at KMWH for the entire 2014-2018 period. Additionally, the 1-min wind speed threshold of 0.5 meter per second (m/s) is applied for the 1-min ASOS data according to EPA guidance.¹² The wind rose for the modeled period (2014-2018) is provided in Figure 6-1.

Trinity also reviewed the percentage of calm and missing data for the modeled period. Before applying the 0.5 m/s threshold for the 1-min ASOS data, the total percentage of calm wind data is 0.48%. The AERMOD-ready data shows 0.50% of calm wind data and 0.80% of missing data.

The upper air data is taken from the nearest upper air station in Spokane, Washington (OTX) for the corresponding period. All data is processed using regulatory default options.

¹¹ Tesfamichael Ghidey (Ecology Modeling Group) provided email concurrence to Ashley Jones (Trinity Consultants) on April 3, 2020 that no re-modeling is required.

¹² EPA Memo Use of ASOS meteorological data in AERMOD dispersion modeling, March 8, 2013.





6.3. COORDINATE SYSTEM

The location of the emission sources, structures, and receptors for this modeling analysis are represented in the Universal Transverse Mercator (UTM) coordinate system using the North American 1983, CONUS (NAD83) projection. The UTM grid divides the world into coordinates that are measured in north meters (measured from the equator) and east meters (measured from the central meridian of a particular zone, which is set at 500 km). UTM coordinates for this analysis are based on UTM Zone 11. The location of the proposed IGQ facility is approximately 5,236,150 meters Northing and 286,986 meters Easting in UTM Zone 11.

6.4. TERRAIN ELEVATIONS

Terrain elevations for receptors, buildings, and sources are determined using National Elevation Dataset (NED) supplied by the United States Geological Survey (USGS).¹³ The NED is a seamless dataset with the best available raster elevation data of the contiguous United States. NED data retrieved for this model have a grid spacing of 1/3 arc-second or 10 m. The AERMOD preprocessor, AERMAP version 18081, is used to compute model object

¹³ NED data retrieved from the National Map website at <u>https://viewer.nationalmap.gov/basic/</u>. Data is converted to the GeoTIFF format for use in the AERMOD models.

elevations from the NED grid spacing. AERMAP also calculates hill height data for all receptors. All data obtained from the NED files are checked for completeness and spot-checked for accuracy.

6.5. RECEPTOR GRIDS

Six (6) square Cartesian receptor grids are used in the analysis, in alignment with Ecology's guidance document for TAP reviews.

- Two grids containing 12.5-meter spaced receptors and extending roughly 250 meters from the center of each of the new proposed buildings.
- A grid containing 25-meter spaced receptors extending from 250 meters to 800 meters from the center of the project location.
- A grid containing 50-meter spaced receptors extending from 800 meters to 1,500 meters from the center of the project location.
- A grid containing 100-meter spaced receptors extending from 1,500 meters to 2,100 meters from the center of the project location.
- A grid containing 300-meter spaced receptors extending from 2,100 meters to 4,400 meters from the center of the project location.
- A grid containing 600-meter spaced receptors extending from 4,400 meters to 10,000 meters from the center project location.

In addition, 10-meter spaced receptors are included along the property fenceline. All receptors are placed at the ground level for the NAAQS analysis. The receptors are placed at 1.5 m flagpole height, as requested by Ecology, for the TAP analysis.

6.6. BUILDING DOWNWASH

Emissions from each source are evaluated in terms of their proximity to nearby structures. The purpose of this evaluation is to determine if stack discharges might become caught in the turbulent wakes of these structures. Wind blowing around a building creates zones of turbulence that are greater than if the buildings were absent. The concepts and procedures expressed in the GEP Technical Support document, the Building Downwash Guidance document, and other related documents are applied to all structures at the IGQ facility.

Figure 6-2 shows the buildings included in this modeling analysis. Detailed building parameters are provided in Appendix E.



Figure 6-2. Modeled Buildings and Fenceline

6.7. EMISSION SOURCE PARAMETERS

The sources included for TAP modeling are the 32 gensets. Each of Buildings D and E will have utility yards on the east and west side of each building, with an option for a utility yard also on the south side of each building. One building will have 12 gensets and one building will have 18 gensets. The two support gensets will be located near the loading docks on the south side of each building. The site plan (Appendix B) shows the locations of the utility yards, loading docks and the position of the gensets. Table 6-1 shows the model ID and each genset's UTM location. Note than in addition to the load analysis, a sensitivity analysis to which building configuration having more gensets was also completed, and the "worst case" configuration was determined for each pollutant and averaging period. The table below shows all possible genset locations regardless of configuration.

		UTM Easting		Elevation
Model Unit ID ¹	Description	(m)	(m)	(m)
D1	D1 - Building D	286,886.1	5,236,186.2	396.24
D2	D2 - Building D	286,885.8	5,236,175.6	396.15
D3	D3 - Building D	286,885.2	5,236,167.8	396.09
D4	D4 - Building D	286,883.9	5,236,141.4	395.9
D5	D5 - Building D	286,883.6	5,236,133.9	395.85
D6	D6 - Building D	286,883.0	5,236,123.0	395.76
D7	D7 - Building D	287,099.4	5,236,176.8	395.35
D8	D8 - Building D	287,098.7	5,236,166.2	395.25
D9	D9 - Building D	287,098.1	5,236,157.4	395.16
D10	D10 - Building D	287,096.9	5,236,130.8	394.87
D11	D11 - Building D	287,097.2	5,236,124.9	394.8
D12	D12 - Building D	287,095.9	5,236,113.9	394.7
D13*	D13 - Building D	286,919.3	5,236,101.7	395.37
D14*	D14 - Building D	286,934.9	5,236,101.4	395.28
D15*	D15 - Building D	286,950.6	5,236,101.0	395.22
D16*	D16 - Building D	287,016.4	5,236,097.6	394.89
D17*	D17 - Building D	287,032.0	5,236,096.4	394.83
D18*	D18 - Building D	287,047.7	5,236,095.4	394.74
E1	E1 - Building E	286,589.8	5,236,110.0	395.87
E2	E2 - Building E	286,589.0	5,236,099.8	395.78
E3	E3 - Building E	286,589.0	5,236,092.0	395.65
E4	E4 - Building E	286,587.8	5,236,065.3	395.33
E5	E5 - Building E	286,587.4	5,236,057.8	395.25
E6	E6 - Building E	286,587.0	5,236,046.9	395.14
E7	E7 - Building E	286,803.5	5,236,101.4	395.83
E8	E8 - Building E	286,803.1	5,236,090.8	395.73
E9	E9 - Building E	286,803.1	5,236,082.2	395.62
E10	E10 - Building E	286,801.5	5,236,055.5	395.32
E11	E11 - Building E	286,801.1	5,236,049.6	395.25
E12	E12 - Building E	286,800.7	5,236,038.2	395.08

Table	6-1.	Modeled	Sources
rabie	0-1.	Moueleu	Juices

Model Unit ID 1	Description	UTM Easting (m)	UTM Northing (m)	Elevation (m)				
E12*	E12 Duilding E	206 622 0	E 226 02E 0	204.02				
E13	E15 - Duiluilig E	200,022.9	5,230,025.0	394.03				
E14*	E14 - Building E	286,638.7	5,236,024.9	394.82				
E15*	E15 - Building E	286,654.1	5,236,024.5	394.81				
E16*	E16 - Building E	286,720.1	5,236,021.5	394.88				
E17*	E17 - Building E	286,735.9	5,236,020.7	394.88				
E18*	E18 - Building E	286,751.3	5,236,019.8	394.87				
S1	Support Generator 1	286,991.0	5,236,103.4	395.07				
S2	S2 Support Generator 2 286,693.3 5,236,028.0 394.94							
¹ Note that Model IDs identified with an "*" are only included in a model scenario if the worst-case								
configuration for a pollutant and averaging period identifies its building (Building D or Building E) as								
worst case for the 18 genset configuration. Only one building will have 18 main gensets and the other								
building 12 main g	rensets for a total of 30 gens	sets.	Ū.					

6.8. LOAD ANALYSIS

A load analysis was performed for each pollutant to determine which load would result in the highest offsite concentration for each of the pollutants. The following load analysis was performed for the main gensets:

- For NO_X, PM_{2.5}, CO, and SO₂, highest hourly emissions across all vendors are included for each generator at each of 10%, 25%, 50%, 75% and 100% loads. For each load, the worst-case (i.e., lowest) flow rate and temperature from vendor provided information is applied for all genset modeled at the specified load.
- For filterable PM/DPM, the load analysis was performed for CAT, Cummins, and Kohler at each load where the dispersion parameters are provided in the vendor specifications. The corresponding vendor emission rate, the flow rate and temperature are used.
- For TAPs, the hourly maximum fuel consumption rate from all vendors at each load and corresponding worst-case parameters are used to represent the variations of resultant TAP emissions. TAP emissions are calculated based on the fuel consumption rates.

Since the support gensets may be operated separately from the main gensets, the following load analysis was performed for the support gensets, which mimics the main gensets:

- For NO_X, PM_{2.5}, CO, and SO₂, highest hourly emissions across all vendors are included for each generator at each of 10%, 25%, 50%, 75% and 100% load. For each load, the worst-case (i.e., lowest) flow rate and temperature from vendor provided information is applied for all generators modeled at the specified load.
- For filterable PM/DPM, the load analysis was performed for CAT and Cummins at each load where the dispersion parameters are provided in the vendor specifications. The corresponding vendor emission rate, the flow rate and temperature are used.
- For TAPs, the hourly fuel consumption rate at each load and corresponding worst-case parameters are used to represent the variations of resultant TAP emissions. TAP emissions are calculated based on the fuel consumption rates.

The modeling parameters are available in Appendix E. The load analysis results are summarized in Table 6-2, and more details are provided in Appendix F. Based on the load analysis results, the following are used for compliance demonstration in Sections 6.10 and 6.11:

For NO_X 1-hour, 100% load results in the maximum offsite concentration across all loads on 1-hour basis. For the 1-hour standard the configuration with 12 main gensets at Building D and 18 gensets at Building E resulted in the maximum offsite concentration. Out of all gensets, three engines located at Building E (model IDs E15, E16, E17) are the highest impacting units that result in maximum offsite 1-hour concentrations. These units are further discussed as part of the Monte Carlo analysis in Section 6.10.2.

- For NO_X annual, 100% load results in the maximum offsite concentration across all loads on annual basis. For the annual standard the configuration with 18 main gensets at Building D and 12 gensets at Building E resulted in maximum offsite concentration.
- For PM_{2.5} 24-hour, 100% load results in maximum offsite 24-hour averaged concentration across all loads with the configuration with 12 main gensets at Building D and 18 gensets at Building E. Out of all gensets, three engine scenarios located at Building E are the highest impacting units that result in maximum offsite 1-hour concentrations. These are genset E15 at 10% load, E16 at 75% load, and E16 at 100% load.
- For PM_{2.5} annual, 10% load results in the maximum offsite annual averaged concentration across all loads with the configuration with 12 main gensets at Building D and 18 gensets at Building E.
- For DPM, Cummins DQKAN 100% load results in the maximum annual averaged offsite concentration across all loads and vendors. This maximum occurs in the configuration with 18 main gensets at Building D and 12 main gensets at Building E.
- For CO, 25% load results in maximum offsite concentration across all loads on 1-hour and 8-hour basis. This maximum occurs in the configuration with 12 main gensets at Building D and 18 main gensets at Building E.
- For SO₂, 100% load results in maximum offsite concentration across all loads on 1-hour and 3-hour basis. This maximum occurs in the configuration with 12 main gensets at Building D and 18 main gensets at Building E.
- For TAPs that are not criteria pollutants, 100% load results in maximum offsite 24-hour averaged concentration across all loads, occurring in the configuration with 12 main gensets at Building D and 18 main gensets at Building E.
- For TAPs that are not criteria pollutants, 100% load results in maximum offsite annual averaged concentration across all loads, occurring in the configuration with 18 main gensets at Building D and 12 main gensets at Building E.

				Worst-Case			
Pollutant	Averaging Period	Wo	rst-Case Load ¹	Configuration			
NO _X	1-hr	Main	100%	D12/E18			
		Support	100%				
NO _X	Annual	Main	100%	D18/E12			
		Support	100%				
PM _{2.5}	24-hr	Main	100%	D12/E18			
		Support	10%				
PM _{2.5}	Annual	Main	10%	D12/E18			
		Support	10%				
PM ₁₀	24-hr	Main	100%	D12/E18			
		Support	10%				
СО	1-hr and 8-hr	Main	25%	D12/E18			
		Support	50%				
SO ₂	1-hr and 3-hr	Main	100%	D12/E18			
		Support	100%				
Acrolein	24-hr	Main	100%	D12/E18			
		Support	100%				
Benzene	year	Main	100%	D18/E12			
		Support	100%				
Naphthalene	year	Main	100%	D18/E12			
		Support	100%				
Diesel Engine Exhaust,			100% - Cummins	D18/E12			
Particulate	year	Main	DQKAN				
		Support	50% Cummins				
¹ Determined based on load analysis results presented in Appendix F							

Table 6-2. Load Analysis Results

6.9. NO_X TO NO₂ CONVERSION

 NO_X is formed when nitrogen in ambient air is exposed to high temperatures during the combustion process. At these temperatures, some nitrogen is converted to NO and NO_2 (collectively referred to as NO_X). This project includes NO_X emitted from the gensets from IGQ project. Emission factors for these units are for emissions of NO_X , while the ambient air quality objective is for NO_2 . In order to estimate the amount of NO_2 concentration from the amount of emitted NO_X , the following modeling approaches are applied to AERMOD inputs¹⁴:

- > Plume Volume Molar Ratio Method (PVMRM) in AERMOD;
- In-stack ratio (ISR) of 0.1 for all generators. The ISR is aligned with other recent approved data center analyses, and is a conservative value based on EPA's ISR data base for uncontrolled engines firing diesel or kerosene¹⁵.
- > Ozone background concentration of 52 ppb, based on NW-AIRQUEST at the site location.¹⁶

¹⁶ Northwest Airquest data hosted by Idaho Department of Environmental Quality, available at <u>https://idahodeq.maps.arcgis.com/apps/MapSeries/index.html?appid=0c8a006e11fe4ec5939804b873098dfe</u> and provided by Ranil Dhammapala (Ecology) on January 3, 2020.

¹⁴ Initial approval from Ecology through email on February 21, 2018.

¹⁵ Filtered available entries in Excel file "NO₂_ISR_database.xlsx", EPA NO₂/NO_x in-stack ratio database, available at <u>https://www3.epa.gov/scram001/no2_isr_database.htm</u>, accessed January 27, 2020. The average ISR for RICE firing diesel or kerosene is 0.07.

6.10. NAAQS ANALYSIS

This section discusses the modeling analysis performed to demonstrate compliance with the NO₂, PM₁₀, PM_{2.5}, CO, and SO₂ NAAQS. NAAQS compliance demonstration is required to protect the human health and public welfare.

6.10.1. Background Concentration

The background concentration of a pollutant is based on other industrial sites, residential pollutions, and/or naturally occurring impacts. In order to appropriately predict the overall air quality in the area after the IGQ project is constructed, a background concentration is included for PM₁₀, PM_{2.5}, NO₂, SO₂ and CO for NAAQS compliance demonstration. The background concentrations used for this modeling analysis are summarized in Table 6-3, which are obtained from Ecology to represent both a local and regional concentration to be added to the project modeling analysis.

	Averaging			NAAOS					
Pollutant	Period	Bac	kground ((μg/m ³)					
PM10	24-hour	NA	A	77.6	µg/m ³	150			
PM 2.5	24-hour	NA	A	18.9	µg/m ³	35			
PM 2.5	Annual	NA	A	5.8	µg/m ³	12			
NO ₂ b	1-hour	NA	NA		µg/m ³	188			
NO ₂	Annual	3.5	ppb	6.6	µg/m³	100			
SO ₂	1-hour	2.9	ppb	7.6	µg/m³	196			
SO ₂	3-hour	5.4	ppb	14.1	µg/m³	1,300			
CO	1-hour	1,150	ppb	1,316.5	µg/m³	40,000			
CO	CO 8-hour 810 ppb 927.3 μg/m ³ 10,000								
^a The background concentrations for pollutants other than PM ₁₀ , PM _{2.5} , and NO ₂ are provided in ppb. The concentrations are converted in accordance with EPA's standard condition (i.e., 760 mmHg ambient pressure and 25 °C ambient temperature).									

Table 6-3. Background Concentrations for NAAQS Analysis

^b NO₂ 1-hr value was provided by Ecology (January 3rd) and represents a local and regional combined impact to be added to the project modeled concentration.

6.10.2. Monte Carlo

The 1-hour NO₂ and 24-hour PM_{2.5} NAAQS is in a probabilistic format. The generators will not be operated continuously throughout the year; rather, the generators' emissions will be intermittent and only during testing and emergency operations. The operating scenarios and arrangement of the generators in operation will vary as well as the meteorological conditions that affect the dispersion of the pollutants. Since it is difficult to rank the emissions from various arrangement and operating scenarios of the generators by emissions, the ambient impact analysis was performed using the statistical approach with the Monte Carlo script developed by Ecology, which is run by the software "R".¹⁷ This script takes account for the low probability of all intermittent emission sources occurring on days with poor dispersion meteorological conditions within a year. It processes the post files that AERMOD generates for the intermittent sources, randomly selects the concentrations from the intermittent sources for each receptor for multiple iterations, and then calculates the median 98th percentile 1-hour concentration from all the iterations for all the receptors that is comparable to the 1-hour NO₂ NAAQS and 24-hour PM_{2.5} NAAQS.

¹⁷ The Monte Carlo script is provided by Ranil Dhammapala (Ecology) on January 2, 2020.

The inputs to the Monte Carlo script requires the AERMOD post files that represent all possible monthly and annual operations, including:

- 32 generators (30 main gensets and 2 support gensets) operating simultaneously for emergency, maintenance, or testing operations, for up to 6 calendar days per year.
- Each engine may be tested monthly for 11 months per year. In order to test all 32 generators in a given month, the testing may take up to 3 calendar days per month. The three generators that result in the highest offsite concentrations on hourly basis (model IDs E14, E15, and E16 for NO_X and E15 [10% load] and E16 [75% load and 100% load] for PM_{2.5}) based on the NO_X and PM_{2.5} load analysis are conservatively included to represent the monthly testing scenario.
- Each engine may be operated for annual load testing and maintenance testing for up to 6 hours per year (i.e., 192 engine-hours per year). In order to conservatively represent this operation scenario, the generator that results in the highest offsite concentration on hourly basis (model ID E16, 100% load for both pollutants) based on the NO_X and PM_{2.5} load analysis is modeled for 24 days per year. Based on a conservative 8-hour operating day for maintenance and testing.

Note that on an annual basis each engine is still limited to 55 hours per year of operation.

6.10.3. NO₂ NAAQS Analysis

 NO_2 NAAQS includes a 1-hour standard and an annual standard. The 1-hour NO_2 is in the form of 3-year average of 98th percentile 1-hour daily maximum concentrations, and the annual NO_2 is in the form of annual mean concentration. As discussed in Section 6.7, modeling parameters corresponding to 100% load are used for NO_2 modeling for all engines.

6.10.3.1. 1-hour NO₂ NAAQS Compliance Demonstration

The 1-hour NO₂ NAAQS analysis relied on the Monte Carlo methodology. In order to account for the background concentration presented in Table 6-3, the threshold for the Monte Carlo analysis is determined as the difference of 1-hour NO₂ NAAQS and the background concentration, which is 120 μ g/m³. The source parameters for all generators modeled for the NO₂ NAAQS demonstration are summarized in Table 6-4.

Pollutant	Averaging Period	Load Scenario ¹	Stack Height (m)	Temp (K)	Exit Velocity (m/s)	Diameter (m)	Modeled Emission Rate ² (g/s/genset)	
		100% Main Genset	18.29	724.15	47.56	0.46	8.401	
NO ₂	1-hour	100% Support Genset	3.66	770.48	58.97	0.15	8.632E-01	
¹ Based on load analysis results as discussed in Section 6.7.								
² Maximum l	² Maximum hourly emission rate at 100% load across all vendors is used here for the main genset, which is 66.67 lb/hr/main genset.							

Table 6-4. 1-hour N	O ₂ NAAQS Model	Source Parameters
---------------------	----------------------------	--------------------------

According to Ecology's instructions, the median of all iterations from Monte Carlo output should be used to determine compliance with NAAQS. The results are summarized in Table 6-5, which demonstrates compliance with 1-hour NO_2 NAAQS.

Pollutant	Averaging Period	Maximum Median Concentration ¹ (µg/m ³)	UTM Easting (m)	UTM Northing (m)	Background (μg/m³)	Total Modeled Concentration (μg/m ³)	1-hr NO ₂ NAAQS (μg/m ³)		
NO ₂	1-hour	118.12	286,675. 1	5,235,967. 1	68.0	186.12	188		
¹ The maxim	¹ The maximum median concentration from Monte Carlo output is listed here.								

Table 6-5. 1-hr NO₂ NAAQS Model Result

6.10.3.2. Annual NO₂ NAAQS Compliance Demonstration

Sabey proposes 55 hrs/yr limit on all of the generators. Therefore, an annual emission rate representing annual generator operations are modeled for all generators. The source parameters for all generators are summarized in Table 6-6.

Table 6-6. Annual NO₂ NAAQS Model Source Parameters

			Stack		Exit		Modeled Emission	
	Averaging		Height	Temp	Velocity	Diameter	Rate ²	
Pollutant	Period	Load Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/genset)	
		100% Main Genset	18.29	724.15	47.56	0.46	5.271E-02	
NO ₂	Annual	100% Support Genset	3.66	770.48	58.97	0.15	5.417E-03	
1 Based on lo	1 Based on load analysis results as discussed in Section 6.7							

¹ Based on load analysis results as discussed in Section 6.7.

 $^{\rm 2}\,$ Annual emissions are scaled to 55 hrs/yr based on the maximum hourly emission rate at 100% load.

Annual NO₂ model result is presented in Table 6-7, which shows the maximum modeled concentration plus background will be below the annual NO₂ NAAQS.

Pollutant	Averaging Period	Maximum Modeled Concentration ¹ (µg/m ³)	UTM Easting (m)	UTM Northing (m)	Background (μg/m ³)	Total Modeled Concentration (μg/m ³)	Annual NO2 NAAQS (μg/m ³)	
NO_2	Annual	1.7	287,141	5,236,212	6.6	8.3	100	
¹ The corresponding year with the maximum modeled concentration is 2014.								

Table 6-7. Annual NO₂ NAAQS Model Result

6.10.4. PM_{2.5} NAAQS Analysis

 $PM_{2.5}$ NAAQS includes a 24-hour standard and an annual standard. The 24-hour $PM_{2.5}$ NAAQS is in the form of 3-year average of 98th percentile 24-hour daily maximum concentrations, and the annual $PM_{2.5}$ NAAQS is in the form of annual mean concentration averaged over 3 years. As discussed in Section 6.7, modeling parameters corresponding to 100% load are used for $PM_{2.5}$ 24-hour modeling and those corresponding to 10% load are used for $PM_{2.5}$ annual modeling.

6.10.4.1. 24-hour PM_{2.5} NAAQS Compliance Demonstration

PM_{2.5} 24-hour NAAQS used the Monte Carlo scenario described in Section 6.10.2. In order to conservatively estimate the impact from such scenario, the main generator with the maximum 24-hour offsite impact based on the load analysis results (see Appendix F), model ID E16 operating at 100% load, is modeled assuming 24 hours of operation per day. The source parameters are summarized in Table 6-8.

Pollutant	Averaging Period	Load Scenario ¹	Stack Height (m)	Temp (K)	Exit Velocity (m/s)	Diameter (m)	Modeled Emission Rate ² (g/s/genset)
PM _{2.5}	24-hour	100% Main Genset	18.29	724.15	47.56	0.46	3.412E-01
		10% Support Genset	3.66	540.93	15.91	0.15	4.891E-02
¹ Based on load analysis results as discussed in Section 6.7. Only the engine results in maximum offsite concentration, model ID E16, is modeled in this case.							

Table 6 0	24 hours		NAAOC	Model	Source	Danamatana
1 abie 0-0.	24-110ul I	112.5	NAAQS	Mouer	Juice	r al allietel 5

² Maximum hourly emission rate at 100% load across all vendors is used, which is 2.71 lb/hr.

As shown in Table 6-9, the maximum median concentration from the Monte Carlo analysis plus background will remain below the NAAQS.

Гable 6-9. 24-hou	r PM _{2.5}	NAAQS	Model	Result
-------------------	---------------------	-------	-------	--------

Pollutant	Averaging Period	Maximum Median Concentration ¹ (ug/m ³)	UTM Easting (m)	UTM Northing (m)	Background (ug/m ³)	Total Modeled Concentration (ug/m ³)	24-hour PM _{2.5} NAAQS (ug/m ³)	
PM 2.5	24-hour	5.71	286,685.1	5,235,968	18.9	24.61	35	
¹ The maximum median concentration from Monte Carlo output is listed here.								

6.10.4.2. Annual PM_{2.5} NAAQS Compliance Demonstration

The annual $PM_{2.5}$ NAAQS is in the form of 3-year average of annual arithmetic mean. As discussed in Section 6.7, 10% load for the main gensets and 10% load for the support gensets are the worst-case loads on annual basis for $PM_{2.5}$. Therefore, modeling parameters, including emission rates, corresponding to the 10% load for the main gensets and those corresponding to 10% load for the support gensets are used for annual $PM_{2.5}$ modeling, which are summarized in Table 6-10. The emission rates for all units are scaled to 55 hrs/yr for each generator.
Pollutant	Averaging Period	Load Scenario ¹	Stack Height (m)	Temp (K)	Exit Velocity (m/s)	Diameter (m)	Modeled Emission Rate ² (g/s/genset)
		10% Main Genset	18.29	587.04	11.50	0.46	1.033E-03
PM _{2.5}	Annual	10% Support Genset	3.66	540.93	15.91	0.15	2.993E-04
¹ Based on load analysis results as discussed in Section 6.7.							
² Annual emissions are scaled to 55 hrs/yr based on the maximum hourly emission rate at 10% load across all vendors for the main							
gensets.	gensets.						

Table 6-10. Annual PM_{2.5} NAAQS Model Source Parameters

The 5-year average annual $PM_{2.5}$ model result plus the background is summarized in Table 6-11, which demonstrates compliance with the NAAQS.

Pollutant	Averagin g Period	Maximum Modeled Concentration ¹ (µg/m ³)	UTM Easting (m)	UTM Northing (m)	Background (μg/m ³)	Total Modeled Concentration (μg/m ³)	Annual PM _{2.5} NAAQS (μg/m ³)
PM _{2.5}	Annual	0.1	286,698.5	5,235,962.5	5.8	5.9	12
¹ The highest 1 st high modeled concentration over the 5 modeled years for all receptors is listed here.							

Table 6-11. Annual PM_{2.5} NAAQS Model Result

6.10.5. PM₁₀ NAAQS Compliance Demonstration

PM₁₀ 24-hr NAAQS standard allows one exceedance per year. As discussed in Section 6.7, 100% load model parameters for the main gensets and 50% load parameters for the house gensets are used for PM₁₀ 24-hr NAAQS modeling. All generators are modeled. The input parameters for each generator are summarized in Table 6-12.

Dellesterst	Averaging		Stack Height	Temp	Exit Velocity	Diameter	Modeled Emission Rate ²
Pollutant	Perioa	Load Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/genset)
DM	24 hour	100% Main Genset	18.29	724.15	47.56	0.46	3.412E-01
P IVI 10	24-11001	10% House Genset	3.66	540.93	15.91	0.15	4.891E-02
¹ Based on load analysis results as discussed in Section 6.7.							
² Maximum he	² Maximum hourly emission rate at 100% load across all vendors for the main gensets is used, which is 2.71 lb/hr/main genset.						

Table 6-12. PM₁₀ NAAQS Model Source Parameters

The 6^{th} highest model results, plus the background concentration, are summarized in Table 6-13, which demonstrated compliance with PM₁₀ NAAQS.

	Averaging	H6H Modeled Concentration	UTM Easting	UTM Northing	Background	Total Modeled Concentration	24-hour PM ₁₀ NAAQS
Pollutant	Period	(µg/m³)	(m)	(m)	(µg/m³)	(µg/m³)	(µg/m³)
PM 10	24-hour	69.3	286,673.5	5,235,962.5	77.6	146.9	150
PM10 24-flour 09.5 280,07.5.5 5,255,902.5 77.6 140.9 150 1 The PM10 24-hr NAAQS shall not be exceeded more than once per year. Therefore, the highest 6 th high concentration across all respectors even the 5 modeled ware are listed here. 150							

Table 6-13. PM₁₀ NAAQS Model Results

6.10.6. CO NAAQS Compliance Demonstration

CO NAAQS includes a 1-hour and a 3-hour standard both of which are not to be exceeded once per year (i.e., the 2nd highest modeled results are used for compliance demonstration). As discussed in Section 6.7, 25% load model parameters for the main gensets and 50% load model parameters for the support gensets are used for CO NAAQS modeling. All generators are modeled. The input parameters for each generator are summarized in Table 6-14.

Table 6-14. CO NAAQS Model Source Parameters

Pollutant	Averaging Period	Load Scenario ¹	Stack Height (m)	Temp (K)	Exit Velocity (m/s)	Diameter (m)	Modeled Emission Rate ² (g/s/genset)
	1 h	25% Main Genset	18.29	659.26	18.63	0.46	1.593
CO	1-nour 8-hour	50% Support Genset	3.66	691.21	44.37	0.15	4.541E-01
¹ Based on load analysis results as discussed in Section 6.7.							
² Hourly emission rate for the main genset is based on Tier 2 emission standard under 40 CFR 89.112(a) and the maximum engine							
horsepowe	er of all vendors, w	hich is 12.04 lb/hr.					

The second highest model results, plus the background corresponding to the modeled averaging period, are summarized in Table 6-15, which demonstrates compliance with the CO NAAQS.

Pollutant	Averaging Period	H2H Modeled Concentration ¹ (µg/m ³)	UTM Easting (m)	UTM Northing (m)	Background (µg/m³)	Total Modeled Concentration (µg/m ³)	CO NAAQS (µg/m ³)
60	1-hour	1,426.2	286,645. 2	5,235964.6	1,316.5	2,742.7	40,000
CO	8-hour	997.2	286,655. 2	5,235,965. 5	927.3	1,924.5	10,000
¹ The CO 1-hr and 8-hr NAAQS shall not be exceeded more than once in each year. Therefore, the highest 2 nd high concentration across all receptors are listed here. The listed 1-hr concentration and the listed 8-hr concentration both occur in modeled year 2014.							

Table 6-15.	CO NAAQS	Model Results
-------------	-----------------	----------------------

6.10.7. SO₂ NAAQS Compliance Demonstration

The primary SO₂ 1-hour NAAQS is in the form of 3-year average of 99th percentile of the annual distribution of daily maximum 1-hour concentration. Therefore, the highest 4th high result over the modeled 5-year period is used for SO₂ 1-hour compliance demonstration. The SO₂ 3-hour NAAQS is a secondary standard, which is not to

be exceeded more than once per calendar year. Therefore, the maximum highest 2^{nd} high result over each modeled year is used for SO₂ 3-hour compliance demonstration. As discussed in Section 6.7, 100% load model parameters are used for SO₂ NAAQS modeling. All generators are modeled. The input parameters for each generator are summarized in Table 6-16.

Pollutant	Averaging Period	Load Scenario ¹	Stack Height (m)	Temp (K)	Exit Velocity (m/s)	Diameter (m)	Modeled Emission Rate ² (g/s/genset)
	1-hour	100% Main Genset	18.29	724.15	47.56	0.46	5.566E-03
SO ₂	3-hour	100% Support Genset	3.66	770.48	58.97	0.15	1.240E-01
¹ Based on load analysis results as discussed in Section 6.7.							

² Hourly emission rates are based on AP-42 emission factors and the maximum engine horsepower.

The model results matching the form of the standard for each averaging period, plus the background corresponding to the modeled averaging period, are summarized in Table 6-17, which demonstrates compliance with the SO_2 NAAQS.

Table 6-17. SO2 NAAQS Model Results

Pollutant	Averaging Period	Modeled Concentration ¹ (µg/m ³)	UTM Easting (m)	UTM Northing (m)	Background (µg/m ³)	Total Modeled Concentration (µg/m ³)	SO ₂ NAAQS (μg/m ³)
50	1-hour	94.5	286,754. 9	5,235,973. 7	7.6	102.1	196
502	3-hour	75.6	286,736. 0	5,235,962. 5	14.1	89.7	1,300
¹ The highest	¹ The highest 4 th high result over the modeled 5-year period is used for 1-hour SO ₂ NAAQS compliance demonstration. The highest 2 nd						

high result from the maximum modeled year (in this case 2018) is used for 3-hour SO₂ NAAQS compliance demonstration.

6.11. TAP ANALYSIS

As discussed in Section 4.5.1, dispersion modeling is required for acrolein, benzene, naphthalene, SO_2 , CO, DPM, and NO_2 with following approaches:

- The load analysis performed for TAPs for which emissions are determined based on fuel usage (see Appendix F for acrolein, benzene, and naphthalene) showed that 100% load has the maximum impact on both 24-hour averaging period and annual averaging period concentrations for the main gensets. Therefore, for the main gensets, the 100% load source parameters, including corresponding emission rates, are used for modeling acrolein, benzene, and naphthalene. 100% load is the worst-case load for both 24-hour and annual averaging periods for the support gensets, and the corresponding emission rates and parameters are used for modeling acrolein, benzene, and naphthalene emissions for support gensets. In the case of acrolein, the configuration with 12 main gensets located at Building D and 18 main gensets located at Building E resulted in the highest concentrations; however, for both benzene and naphthalene, the configuration with 18 main gensets at Building D and 12 main gensets at Building E is used.
- A comprehensive load analysis for the main gensets was performed for DPM with the load-specific data across all vendors (see Appendix F). It was determined that the maximum offsite impact results from modeling all engines with Cummins' DQKAN 100% load emission profile. Therefore, the DPM models are set

up using Cummins' DQKAN 100% load emission profile and source parameters for the main gensets. 50% load with the Cummins' DQDAC support genset represents the worst-case load for the support gensets, and the corresponding emission rates and parameters are used for modeling DPM emissions from the support gensets.

SO₂, CO and NO₂ modeling parameters are consistent with the NAAQS analysis for 1-hour averaging period. All engines are modeled with the parameters presented in Table 6-4, Table 6-14, and Table 6-16 for simultaneous operation. Additionally, NO₂ modeling applied the same NO₂ to NO_x conversion approach as described in Section 6.9.

Table 6-18 shows the maximum modeled concentration and corresponding meteorological year for each TAP. Model files are provided in Appendix G.

			Maximum				
			Modeled	UTM	UTM		
	Toxic Air	Averaging	Concentration	Easting	Northing	ASIL	% of
Year	Pollutant	Period	(μg/m³)	(m)	(m)	(µg/m³)	ASIL
2014	Acrolein	24-hr	1.41E-2	286,635.3	5,235,963.8	0.35	4.0%
2014	Benzene	year	5.10E-04	287,141	5,236,212	0.13	0.4%
2014	Naphthalene	year	9.00E-5	287,141	5,236,212	0.029	0.3%
2014	DPM	year	5.39E-2	287,141	5,236,212	0.0033	1,633.3%
2015	SO ₂	1-hr	123.67	286,744.9	5,235,972.9	660	18.7%
2014	CO	1-hr	1,541.59	286,645.2	5,235,964.6	23,000	6.7%
2014	NO ₂	1-hr	1,212.59	281,386	5,244,350	470	258.0%

Table 6-18. Maximum Modeled TAP Concentrations

As shown in Table 6-18, acrolein, benzene, naphthalene, SO_2 , and CO are in compliance with their corresponding ASIL, but DPM and NO_2 are in exceedance of the ASIL. Therefore, a second tier review will be conducted to demonstrate that DPM and NO_2 emissions from the project do not have significant health impacts on the community.



A notice of construction permit is required before installing a new source of air pollution or modifying an existing source of air pollution. This application applies to facilities in Ecology's jurisdiction. Submit this application for review of your project. For general information about completing the application, refer to Ecology Forms ECY 070-410a-g, "Instructions for Ecology's Notice of Construction Application."

Ecology offers up to two hours of free pre-application assistance. We encourage you to schedule a pre-application meeting with the contact person specified for the location of your proposal, below. If you use up your two hours of free pre-application assistance, we will continue to assist you after you submit Part 1 of the application and the application fee. You may schedule a meeting with us at any point in the process.

Upon completion of the application, please enclose a check for the initial fee and mail to:

Department of Ecology Cashiering Unit P.O. Box 47611 Olympia, WA 98504-7611 For Fiscal Office Use Only: 001-NSR-216-0299-000404

C	Check the box for the location of your proposal. For assistance, call the contact listed below:						
	Ecology Permitting Office	Contact					
CRO	Chelan, Douglas, Kittitas, Klickitat, or Okanogan County Ecology Central Regional Office – Air Quality Program	Lynnette Haller (509) 457-7126 <u>lynnette.haller@ecy.wa.gov</u>					
ERO	Adams, Asotin, Columbia, Ferry, Franklin, Garfield, Grant, Lincoln, Pend Oreille, Stevens, Walla Walla or Whitman County Ecology Eastern Regional Office – Air Quality Program	Karin Baldwin (509) 329-3452 <u>karin.baldwin@ecy.wa.gov</u>					
D NWRO	San Juan County Ecology Northwest Regional Office – Air Quality Program	David Adler (425) 649-7267 <u>david.adler@ecy.wa.gov</u>					
	For actions taken at Kraft and Sulfite Paper Mills and Aluminum Smelters Ecology Industrial Section – Waste 2 Resources Program Permit manager:	James DeMay (360) 407-6868 james.demay@ecy.wa.gov					
NWP	For actions taken on the US Department of Energy Hanford Reservation Ecology Nuclear Waste Program	Lilyann Murphy (509) 372-7951 <u>lilyann.murphy@ecy.wa.gov</u>					

Check the box below for the fee that applies to your application.



New project or equipment:

	\$1,500: Basic project initial fee covers up to 16 hours of review.
\square	\$10,000: Complex project initial fee covers up to 106 hours of review.

Change to an existing permit or equipment:

\$200: Administrative or simple change initial fee covers up to 3 hours of review Ecology may determine your change is complex during completeness review of your application. If your project is complex, you must pay the additional \$675 before we will continue working on your application.
\$875: Complex change initial fee covers up to 10 hours of review
\$350 flat fee: Replace or alter control technology equipment under WAC 173-400-114 Ecology will contact you if we determine your change belongs in another fee category. You must pay the fee associated with that category before we will continue working on your application.

Read each	Read each statement, then check the box next to it to acknowledge that you agree.				
	The initial fee you submitted may not cover the cost of processing your application. Ecology will track the number of hours spent on your project. If the number of hours Ecology spends exceeds the hours included in your initial fee, Ecology will bill you \$95 per hour for the extra time.				
\square	You must include all information requested by this application. Ecology may not process your application if it does not include all the information requested.				
\square	Submittal of this application allows Ecology staff to visit and inspect your facility.				



Notice of Construction Application Part 1: General Information

I. Project, Facility, and Company Information

1. Project Name
Intergate Quincy Notice of Construction
2. Facility Name
Intergate Quincy
3. Facility Street Address
2200 M Street NE, Quincy, WA 98848
4. Facility Legal Description
S9 T20N R24E
5. Company Legal Name (if different from Facility Name)
Sabey Data Center Properties
6. Company Mailing Address (street, city, state, zip)
12201 Tukwila International Boulevard, 4th Floor, Seattle, WA 98168

II. Contact Information and Certification

1. Facility Contact Name (who will be onsite)									
Snaun Devine	Shaun Devine								
2. Facility Contact Mailing Address (if different that	n Company Mailing Address)								
Same as company mailing address	,								
3. Facility Contact Phone Number	4. Facility Contact E-mail								
shaund@sabey.com	206-277-5343								
5. Billing Contact Name (who should receive billing	g information)								
Lisa Carr									
6. Billing Contact Mailing Address (if different than	Company Mailing Address)								
Same as company mailing address									
7. Billing Contact Phone Number	8. Billing Contact E-mail								
206-281-8700									
9. Consultant Name (optional – if 3^{rd} party hired to	complete application elements)								
Ashley Jones									
10. Consultant Organization/Company									
Trinity Consultants									
11. Consultant Mailing Address (street, city, state, z	zip)								
1391 N Speer Blvd, Suite 350									
12. Consultant Phone Number	13.Consultant E-mail								
720-638-7647	avjones@trinityconsultants.com								
14. Responsible Official Name and Title (who is response	onsible for project policy or decision-making)								
John Sasser - Senior Vice President, Data Center O	perations								
16. Responsible Official Phone	17. Responsible Official E-mail								
206-277-5302 johnsas@sabey.com									
18. Responsible Official Certification and Signature									
I certify that the information on this application is accurate and complete.									
Signature $\left(\frac{1}{2}\right)$									
/ Part 2: Technical Information									



The Technical Information may be sent with this application form to the Cashiering Unit, or may be sent directly to the Ecology regional office with jurisdiction along with a copy of this application form.

For all sections, check the box next to each item as you complete it.

III. Project Description

Please attach the following to your application.

- Written narrative describing your proposed project.
- Projected construction start and completion dates.
- Operating schedule and production rates.
- K List of all major process equipment with manufacturer and maximum rated capacity.
- Process flow diagram with all emission points identified. N/A
- \boxtimes Plan view site map.

Manufacturer specification sheets for major process equipment components.

Manufacturer specification sheets for pollution control equipment. N/A

Fuel specifications, including type, consumption (per hour & per year) and percent sulfur.

IV. State Environmental Policy Act (SEPA) Compliance

Check the appropriate box below.

SEPA review is complete:

Include a copy of the final SEPA checklist and SEPA determination (e.g., DNS, MDNS, EIS) with your application.

SEPA review has not been conducted:

If review will be conducted by another agency, list the agency. You must provide a copy of the final SEPA checklist and SEPA determination before Ecology will issue your permit. Agency Reviewing SEPA:

If the review will be conducted by Ecology, fill out a SEPA checklist and submit it with your application. You can find a SEPA checklist online at https://ecology.wa.gov/Regulations-Permits/SEPA/Environmental-review/SEPA-document-templates



V. Emissions Estimations of Criteria Pollutants

Does your project generate criteria air pollutant emissions? 🖂 Yes 🗌 No

If yes, please provide the following information regarding your criteria emissions in your application.

 \boxtimes The names of the criteria air pollutants emitted (i.e., NO_x, SO₂, CO, PM_{2.5}, PM₁₀, TSP, VOC, and Pb)

 \boxtimes Potential emissions of criteria air pollutants in tons per hour, tons per day, and tons per year (include calculations)

If there will be any fugitive criteria pollutant emissions, clearly identify the pollutant and quantity

VI. Emissions Estimations of Toxic Air Pollutants

Does your project generate toxic air pollutant emissions? 🖂 Yes 🗌 No

If yes, please provide the following information regarding your toxic air pollutant emissions in your application.

 \boxtimes The names of the toxic air pollutants emitted (specified in <u>WAC 173-460-150¹</u>)

 \boxtimes Potential emissions of toxic air pollutants in pounds per hour, pounds per day, and pounds per year (include calculations)

If there will be any fugitive toxic air pollutant emissions, clearly identify the pollutant and quantity

VII. Emission Standard Compliance

Provide a list of all applicable new source performance standards, national emission standards for hazardous air pollutants, national emission standards for hazardous air pollutants for source categories, and emission standards adopted under Chapter 70.94 RCW.

Does your project comply with all applicable standards identified? Xes No

VIII. Best Available Control Technology

Provide a complete evaluation of Best Available Control Technology (BACT) for your proposal.

¹ <u>http://apps.leg.wa.gov/WAC/default.aspx?cite=173-460-150</u>



IX. Ambient Air Impacts Analyses

Please provide the following:

- Ambient air impacts analyses for Criteria Air Pollutants (including fugitive emissions)
- Ambient air impacts analyses for Toxic Air Pollutants (including fugitive emissions)

Discharge point data for each point included in air impacts analyses (include only if modeling is required)

- 🔀 Exhaust height
- Exhaust inside dimensions (ex. diameter or length and width)
- Exhaust gas velocity or volumetric flow rate
- Exhaust gas exit temperature
- \boxtimes The volumetric flow rate
- Description of the discharges (i.e., vertically or horizontally) and whether there are any obstructions (ex., raincap)
- \boxtimes Identification of the emission unit(s) discharging from the point
- The distance from the stack to the nearest property line
- Emission unit building height, width, and length
- Height of tallest building on-site or in the vicinity and the nearest distance of that building to the exhaust
- Whether the facility is in an urban or rural location

Does your project cause or contribute to a violation of any ambient air quality standard or acceptable source impact level? [No - Tier 2 TAP Analysis will be submitted. Project complies with NAAQS.

DETERMINATION OF NONSIGNIFICANCE

Description of proposal: Construction of approximately 140,000 square foot data center building and associated site work for Phase 1. With Phase 2 likely beginning in 2021 of 550,000 square foot data center and associated site work. A pre-application meeting was held with the applicant and City departments regarding the project and mitigation of utility requirements will be part of the permit process. Additionally the applicant will be required to mitigate air quality through the Department of Ecology Air Quality permitting process.

Proponent: Sabey Intergate. Quincy VI LLC

Location of proposal, including street address, 2200 M Street NE, Quincy, WA 98848

Lead agency: City of Quincy

The lead agency for this proposal has determined that it does not have a probable significant adverse impact on the environment. An environmental impact statement (EIS) is not required under RCW 43.21C.030 (2)(c). This decision was made after review of a completed environmental checklist and other information on file with the lead agency. This information is available to the public on request.

□ There is no comment period for this DNS.

	This DNS is issued after using the optional DNS process in WAC 197-11-355.	There is no further comment period on the DNS.
--	--	--

X This DNS is issued under WAC 197-11-340(2); the lead agency will not act on this proposal for 14 days from the date below. Comments must be submitted by July 18, 2019

Responsible official: Carl Worley

Position/title: Building Official

Address PO Box 338 Quincy WA 98848

Date. July 1, 2019

(OPTIONAL)

X You may appeal this determination to: Carl Worley at 115 First Ave SW no later than July 18, 2019

by (method) Written

Signature

You should be prepared to make specific factual objections. Contact Carl Worley to read or ask about the procedures for SEPA appeals.

 \Box There is no agency appeal.

Carl Worley

Phone: 509 787 3523



1 IGQ CAMPUS SITE PLAN SCALE: 1" = 100'-0"

SABEY SABEY ARCHITECTURE seattle, washington 206.281.8700 sabey.com SABEY DATA CENTER PROPERTIES: INTERGATE.QUINCY **BUILDINGS D, E, AND** FUTURE DEVELOPMENT 2200 M STREET NE QUINCY, WA 98848 MARK DATE DESCRIPTION ISSUE: FOR REFERENCE ONLY PROGRESS DATE: 01/29/20 DRAWN BY: BH CHECKED BY: APPROVED BY: PROJECT NO: FILE: IGQ_SitePlan - Ecology_01-29-20.dwg All drawings and written material appearing herein constitute the original and unpublished work of the Sabey Corporation and the same may not be duplicated, used or disclosed without the written consent of the Sabey Corporation. INTERGATE.QUINCY CAMPUS SITE PLAN

SP-1

APPENDIX C: EMISSION CALCULATIONS AND SUPPORTING DOCUMENTATION

- 1. Emission Calculation Summary
- 2. Engine Specifications Project
- > Caterpillar 3516C 2500 kW Specifications
- > Cummins DQKAF 2250 kW Specifications
- Cummins DQKAN 2500 kW Specifications
- > Kohler KD2250 2250 kW Specifications
- > Kohler KD2500 2500 kW Specifications
- > Caterpillar C9 300 kW Specifications
- > Cummins DQDAC 300 kW Specifications
- 3. Engine Specifications As-Built
- > Caterpillar 3516C 2000 kW Specifications
- > Caterpillar 3512C 1500 kW Specifications
- > Caterpillar C9 300 kW Specifications
- > Caterpillar C9 250 kW Specification
- 4. Cooling Unit Specifications

1. EMISSION CALCULATION SUMMARY

Sabey Data Center Properties | Intergate Quincy Notice of Construction Trinity Consultants

Table C-1. Potential Emission Summary

	Annual Emission Rate							
	(tpy)							
Emission Point	PM	PM ₁₀	PM _{2.5}	SO ₂	NOx	VOC	CO	HAP
Existing Engines and Cooling Units ¹	2.50	3.59	3.59	0.11	39.52	1.09	4.18	0.03
Existing Diesel Storage Tanks						1.00		1.00E-02
New Main Gensets	1.70	2.18	2.18	0.04	54.98	1.02	13.77	0.03
New Support Genset	9.92E-03	0.02	0.02	0.05	0.38	0.02	0.19	6.73E-04
New Diesel Storage Tanks						1.00		1.00E-02
New Cooling Units	1.27E-01	1.27E-01	1.27E-01					
Project Emissions	1.84	2.33	2.33	0.09	55.35	2.03	13.95	0.04
WAC Exemption Levels	1.25	0.75	0.50	2.00	2.00	2.00	5.00	N/A
NSR Required?	Yes	Yes	Yes	No	Yes	Yes	Yes	N/A
Facility-Wide Potential Emissions	4.34	5.92	5.92	0.20	94.88	4.12	18.13	0.08
Title V Threshold		100	100	100	100	100	100	25
Title V Required?	N/A	No	No	No	No	No	No	No
PSD Major Source Threshold		250	250	250	250	250	250	N/A
PSD Major Source?	N/A	No	No	No	No	No	No	No

¹ PTE from existing engines and cooling units are calculated based on the quantity and type of units actually installed and planned. HAP emissions are the sum of PTE for the TAPs that are HAPs too, assuming the unlisted HAPs are emitted in negligible amount.

 $^{2}\,$ WAC exemption levels are listed in WAC 173-400-110 Table 110(5).

Table C-2. Project TAP Emissions

	Project	Existing	
	Emission	Equipment	
	Rate	PTE ¹	Total
Pollutant		(tpy)	
Acenaphthene	9.20E-05	8.31E-05	1.75E-04
Acenaphthylene	1.82E-04	1.65E-04	3.46E-04
Acetaldehyde	6.27E-04	6.32E-04	1.26E-03
Acrolein	1.71E-04	1.62E-04	3.32E-04
Anthracene	2.44E-05	2.22E-05	4.67E-05
Benzene	0.02	1.40E-02	0.03
Benzo(a)anthracene	1.25E-05	1.14E-05	2.39E-05
Benzo(a)pyrene	5.07E-06	4.59E-06	9.66E-06
Benzo(b)fluoranthene	2.18E-05	1.97E-05	4.14E-05
Benzo(g,h,l)perylene	1.10E-05	9.95E-06	2.09E-05
Benzo(k)fluoranthene	4.30E-06	3.89E-06	8.20E-06
1,3-Butadiene	6.80E-06	9.47E-06	1.63E-05
Chrysene	3.01E-05	2.72E-05	5.72E-05
Dibenz(a,h)anthracene	6.89E-06	6.26E-06	1.31E-05
Fluoranthene	8.04E-05	7.31E-05	1.53E-04
Fluorene	2.56E-04	2.34E-04	4.90E-04
Formaldehyde	1.75E-03	1.68E-03	3.43E-03
Indeno(1,2,3-cd)pyrene	8.18E-06	7.42E-06	1.56E-05
Naphthalene	2.56E-03	2.32E-03	4.88E-03
Phenanthrene	8.05E-04	7.29E-04	1.53E-03
Propylene	5.92E-03	5.56E-03	1.15E-02
Pyrene	7.36E-05	6.68E-05	1.40E-04
Toluene	5.58E-03	5.07E-03	1.07E-02
Xylenes	3.83E-03	3.48E-03	7.32E-03
Diesel engine exhaust, particulate	1.71	0.55	2.26
SO ₂	0.09	0.11	0.20
со	13.95	4.18	18.13
NO ₂	5.54	3.95	9.49

Table C-3a. Operation Scenario Summary

	Maximum Operatio	ons for Each Engine	Maximum Operations for All Engines ²			
Operation Scenario	(hr/day/engine) (hr/yr/engine)		(engine-hr/hr)	(engine-hr/day)	(engine-hr/yr)	
Main Genset Running at Any Load ¹	24	55	30	720	1650	
Support Genset Running at Any Load	24	55	2	48	110	

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing), the maximum number of days of such operation will be 6 days in any given year while keeping the total number of hours per engine per calendar year equal to or below 55. Maintenance and testing runs outside of these 6 days will be operated for a single engine at any hour, up to 24 engine-hours in any day.

² The project includes 30 main gensets and 2 support genset.

Table C-3b. Criteria Pollutants Emission Estimate - Main Gensets

		Maximum Engine Emission Rate Across Any			
		Load/Vendor ¹			Annual Total for
		Warm Engine	Cold-Start		All Engines
Pollutant	Emission Factor	(lb/hr/engine)	(lb/hr/engine)	(tpy/engine) ⁵	(tpy)
Particulate Matter (PM) ²	Maximum Vendor Hourly Emission Rate	2.01	2.12	0.06	1.70
Condensable PM ²	Maximum Vendor Hourly Emission Rate for Total Hydrocarbon	1.20	1.27	0.03	1.02
Particulate Matter <10 microns (PM $_{10}$) 2	Maximum Vendor Hourly Emission Rate	2.57	2.71	0.07	2.18
Particulate Matter < 2.5 microns (PM $_{2.5}$) ²	Maximum Vendor Hourly Emission Rate	2.57	2.71	0.07	2.18
Sulfur Dioxide (SO ₂) ³	1.21E-05 lb/hp-hr per AP-42	0.04	0.04	1.21E-03	0.04
Carbon Monoxide (CO) ⁴	Maximum Vendor Hourly Emission Rate	15.63	17.71	0.46	13.77
Nitrogen Oxides (NO _X) ⁴	Maximum Vendor Hourly Emission Rate	66.67	66.60	1.83	54.98
Volatile Organic Compounds (VOC)	Maximum Vendor Hourly Emission Rate	1.20	1.27	0.03	1.02

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing), the maximum number of days of such operation will be 6 days in any given year while keeping the total number of hours per engine per calendar year equal to or below 55. Maintenance and testing runs outside of these 6 days will be operated for a single engine at any hour, up to 24 engine-hours in any day.

² Diesel PM hourly emissions are the maximum based on engine specifications across all loads and vendors (see Load Emissions tables) for conservatism. PM₁₀ and PM_{2.5} emissions are the diesel PM emission rates plus the condensable PM emission rate. Condensable PM emissions are conservatively assumed to be the same as hydrocarbon emissions from vendor data, which is also conservatively assumed to be the maximum hourly emission rate across all loads and vendors.

³ SO₂ emissions are calculated conservatively assuming constant operation at 100% load (i.e., maximum engine power). SO₂ emissions are based on maximum sulfur content allowed in ULSD (15 ppm) and are calculated according to methodology presented in AP-42, Chapter 3.4, Table 3.4-1.

⁴ NO_x and CO hourly emissions are the maximum based on engine specifications across all loads and vendors (see Load Emissions tables) for conservatism.

⁵ Emission calculations conservatively assumes 28 1-hour cold-start periods per year.

Table C-3c. Criteria Pollutants Emission Estimate - Support Genset

			Maximum Engine Emission Rate Across Any			
	Load/Vendor ¹			Annual Total for		
			Warm Engine	Cold-Start		All Engines
Pollutant	Emission Fa	ictor	(lb/hr/engine)	(lb/hr/engine)	(tpy/engine) ⁵	(tpy)
Particulate Matter (PM) ²	Maximum Vendor Hour	y Emission Rate	0.18	0.19	4.96E-03	9.92E-03
Condensable PM ²	Maximum Vendor Hourly Total Hydroc	Emission Rate for arbon	0.29	0.31	8.28E-03	1.66E-02
Particulate Matter <10 microns (PM $_{10}$) ²	Maximum Vendor Hour	y Emission Rate	0.37	0.39	1.04E-02	2.08E-02
Particulate Matter < 2.5 microns (PM $_{2.5}$) ²	Maximum Vendor Hour	y Emission Rate	0.37	0.39	1.04E-02	2.08E-02
Sulfur Dioxide (SO ₂) ³	2.05E-03 lb	/hp-hr per AP-42	0.98	0.98	2.71E-02	5.41E-02
Carbon Monoxide (CO) ⁴	Maximum Vendor Hour	y Emission Rate	3.18	3.60	0.09	0.19
Nitrogen Oxides (NO _X) ⁴	Maximum Vendor Hour	y Emission Rate	6.85	6.84	0.19	0.38
Volatile Organic Compounds (VOC)	Maximum Vendor Hour	y Emission Rate	0.29	0.31	8.28E-03	1.66E-02

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing), the maximum number of days of such operation will be 6 days in any given year while keeping the total number of hours per engine per calendar year equal to or below 55. Maintenance and testing runs outside of these 6 days will be operated for a single engine at any hour, up to 24 engine-hours in any day.

² Diesel PM hourly emissions are the maximum based on engine specifications across all loads and vendors (see Load Emissions tables) for conservatism. PM₁₀ and PM_{2.5} emissions are the diesel PM emission rates plus the condensable PM emission rate. Condensable PM emissions are conservatively assumed to be the same as hydrocarbon emissions from vendor data, which is also conservatively assumed to be the maximum hourly emission rate across all loads and vendors.

³ SO₂ emissions are calculated conservatively assuming constant operation at 100% load (i.e., maximum engine power). SO₂ emissions are calculated according to methodology presented in AP-42, Chapter 3.3, Table 3.3-1.

⁴ NO_x and CO hourly emissions are the maximum based on engine specifications across all loads and vendors (see Load Emissions tables) for conservatism.

⁵ Emission calculations conservatively assumes 28 1-minute cold-start periods per year.

Table C-3d. Fuel Consumption Summary

		Maximum Hourly Scenario		Maximum Daily Scenario		Annual Scenario	
Operation Mode ¹	Hourly Fuel Consumption Rate ² (gal/hr)	Maximum Number of Engines Running in Any Single Hour	Subtotal (gal/hr)	Maximum Number of Engines-Hours in Any Single Day	Subtotal (gal/day)	Number of Engines-Hours in a Year	Subtotal (gal/yr)
Main Genset Maximum Load	173.50	30	5,205	720	124,920	1650	286,275
Support Genset Maximum Load	23.07	2	46	48	1,107	110	2,538
Total	196.57		5,251		126,027		288,813

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing), the maximum number of days of such operation will be 6 days in any given year while keeping the total number of hours per engine per calendar year equal to or below 55. Maintenance and testing runs outside of these 6 days will be operated for a single engine at any hour, up to 24 engine-hours in any day.

² The maximum hourly fuel consumption rate among all vendors at 100% load is used to determine the daily and annual fuel consumptions for conservatism.

Table C-3e. Maximum Emissions for All Engines

	Maximum Emission for All Engines					
	Hourly Total for All	Daily Totals for All	Annual Total for			
	Engines	Engines	All Engines			
Pollutant	(lb/hr)	(lb/day)	(tpy)			
Particulate Matter (PM)	63.83	1532.00	1.71			
Condensable PM	38.58	925.86	1.03			
Particulate Matter <10 microns (PM ₁₀)	82.01	1968.22	2.20			
Particulate Matter < 2.5 microns (PM $_{2.5}$)	82.01	1968.22	2.20			
Sulfur Dioxide (SO ₂)	3.29	79.04	0.09			
Carbon Monoxide (CO)	538.50	12924.04	13.95			
Nitrogen Oxides (NO _X)	2013.87	48332.85	55.35			
Volatile Organic Compounds (VOC)	38.58	925.86	1.03			
Hazardous Air Pollutants (HAPs)	1.15	27.52	0.03			

CAT C9	GenSet Power (kW): 300									
Engine size (hp): 480 Tier		Tier:		3						
	F	actor at Vai	ious Load	% (g/hp-h	r)	Ηοι	ırly Emissior	ıs at Various	Load % (lb/	'hr)
	100	75	50	25	10	100	75	50	25	10
NO _x	4.27	2.92	2.13	1.94	2.61	4.48	2.31	1.19	0.64	0.48
CO	0.45	0.46	0.96	1.36	2.3	0.47	0.37	0.53	0.45	0.42
нс	0.11	0.15	0.32	0.51	0.79	0.11	0.12	0.18	0.17	0.14
PM	0.06	0.08	0.26	0.29	0.34	0.07	0.07	0.15	0.10	0.06
			Exl	haust Flow	Rate (acfm)	2,460.9	2,109.4	1,810.5	1,299.8	851.2
			Ex	haust Flow	Rate (scfm)	936.3	865.5	767.9	569.3	404.7
			Exh	aust Tempe	erature (°F)	927.2	826.3	784.5	745.0	650.3
			Fuel Const	umption Ra	te (gal/hr)	22.7	17.6	13.6	8.7	5.2

Cummins DQDAC			GenSet Po	wer (kW):	300					
Eligine siz	e (np):	Factor at Va	rious Load	% (g/hp-h	r)	o Hourly Emissions at Various Load % (lb/hr)				
	100	75	50	25	10	100	75	50	25	10
NO _X	6.83	3.45	2.21	2.08	2.21	6.85	2.60	1.11	0.52	0.22
CO	0.60	1.46	6.34	6.40	6.26	0.60	1.10	3.18	1.60	0.63
НС	0.08	0.09	0.22	0.43	2.92	0.08	0.07	0.11	0.11	0.29
PM	0.08	0.10	0.35	0.50	0.75	0.08	0.08	0.18	0.13	0.08
			Ex	haust Flow	Rate (acfm)	2,279.4	2,118.6	1,714.8	1,099.6	615.0
			Ex	haust Flow	Rate (scfm)	829.7	813.2	727.0	510.0	333.3
			Exl	Exhaust Temperature (°F)		990	915	785	678	514
			Fuel Co	mbustion Ra	ate (gal/hr)	23.07	17.65	12.23	6.82	3.34

CAT 3516	С			GenSet Po	wer (kW):	2500				
Engine siz	ze (hp):	3,633		Tier:		2				
		Factor at Var	ious Load	l % (g/hp-hi	r)	Hourly Emissions at Various Load % (lb/hr)			/hr)	
	100	75	50	25	10	100	75	50	25	10
NO _x	6.38	5.15	3.74	3.50	6.47	50.59	31.09	15.44	7.87	7.02
CO	0.76	0.48	0.58	1.47	4.26	6.01	2.88	2.41	3.30	4.62
HC	0.14	0.18	0.29	0.40	0.89	1.10	1.10	1.20	0.90	0.96
PM	0.05	0.05	0.07	0.14	0.29	0.41	0.27	0.29	0.31	0.31
			Ех	khaust Flow I	Rate (acfm)	19,578.8	15,893.2	12,413.0	7,844.6	4,800.2
			Ez	khaust Flow	Rate (scfm)	7,514.3	6,362.1	4,998.6	3,206.9	2,288.2
			Ex	haust Tempe	erature (°F)	915.20	858.50	850.70	831.10	647.30
			Fuel Co	mbustion Ra	ate (gal/hr)	173.5	134.9	98.4	57.9	31.3

¹ Exhaust flow characteristics are obtained from Tier 2 Performance Data sheet for CAT 3516C.

Cummins	DQKAF			GenSet Power (kW):		2250				
Engine siz	e (hp):	3,280		Tier:		2				
		Factor at Va	rious Load	d % (g/hp-h	r)	Hourly Emissions at Various Load % (lb/hr)			/hr)	
	100	75	50	25	10	100	75	50	25	10
NO _x	8.88	6.03	4.55	5.25	8.70	64.21	32.70	16.45	9.49	6.29
CO	0.74	0.40	0.56	1.42	4.66	5.35	2.17	2.02	2.57	3.37
НС	0.07	0.03	0.12	0.26	0.66	0.51	0.16	0.43	0.47	0.48
PM	0.10	0.08	0.18	0.40	0.83	0.72	0.43	0.65	0.72	0.60
			E	xhaust Flow	Rate (acfm)	16,546	14,174	11,190	6,594	4,150
			E	xhaust Flow	Rate (scfm)	6,445.0	5,689.0	4,610.6	2,932.1	2,072.4
			Ех	xhaust Temperature (°F)		895	855	821	727	597
			Fuel C	ombustion Ra	ate (gal/hr)	154	121	88	48	26.80

Cummins	DQKAN			GenSet Po	wer (kW):	2500				
Engine siz	ze (hp):	3,640		Tier:		2				
		Factor at Var	ious Load	l % (g/hp-hi	r)	Hourly Emissions at Various Load % (lb/hr)			/hr)	
	100	75	50	25	10	100	75	50	25	10
NO _X	7.96	5.76	5.07	4.89	6.03	63.88	34.67	20.34	9.81	4.84
CO	1.50	1.26	1.04	1.62	3.26	12.04	7.58	4.17	3.25	2.62
HC	0.07	0.09	0.14	0.26	0.60	0.56	0.54	0.56	0.52	0.48
PM	0.25	0.25	0.23	0.43	0.70	2.01	1.50	0.92	0.86	0.56
			Ех	khaust Flow I	Rate (acfm)	18,269	15,122	10,902	6,482	4002
			E	khaust Flow	Rate (scfm)	6,506.2	5,538.7	4,112.9	2,613.6	1,800.8
			Ex	haust Tempe	erature (°F)	1022	981	939	849	713
			Fuel Co	ombustion Ra	ate (gal/hr)	173.1	133.6	91.1	50.6	26.8

Kohler KD	02250			GenSet Po	wer (kW):	2250				
Engine siz	e (hp):	3,352		Tier:		2				
Engine siz	e (kW):	2,500								
		Factor at Va	rious Loa	d % (g/kWh)	Но	urly Emissior	ıs at Various	Load % (lb	/hr)
	100	75	50	25	10	100	75	50	25	10
NO _x	9.0	5.6	5.8	6.1	9.7	49.60	23.14	15.98	8.40	5.35
CO	1.3	2.6	2.2	8.1	10.9	7.16	10.75	6.06	11.16	6.01
HC	0.14	0.15	0.22	0.35	0.89	0.77	0.62	0.61	0.48	0.49
PM	0.07	0.18	0.13	0.47	0.28	0.39	0.74	0.36	0.65	0.15
			Ex	haust Flow R	ate (kg/hr)	15017	14404	9978	5904	4042
			Ex	khaust Flow I	Rate (acfm)	18,132	17,296	12,031	7,148	4,469
			E	khaust Flow	Rate (scfm)	7,340.1	7,040.5	4,877.1	2,885.8	1,975.7
			Ex	Exhaust Temperature (°F)		843.8	836.6	842.0	847.4	734.0
			Fuel Co	mbustion Ra	ate (gal/hr)	167.10	136.90	95.20	55.40	

¹ The exhaust flow rate is converted using the following approach:

 $Volume rate = \frac{\frac{\text{mass in kg/hr} \times 1000 \text{ g/kg}}{\text{MW of exhaust air (g/mol)}} \times \text{Gas Constant (m³·Pa/(K·mol))} \times \text{Temperature(K)}}{\text{Ambient Pressure (Pa)}} \times (\frac{\text{ft}}{0.3048 \text{ m}})^3 \times \frac{1 \text{ hr}}{60 \text{ min}}$

8.314 m³-Pa/(K-mol) Gas constant MW of exhaust 28.9647 g/mol (assuming equal to ambient air)

Ambient pressure 101325 Pa

Kohler KD2500Engine size (hp):3,621Engine size (kW):2,700				GenSet Pov	wer (kW):	2500				
		3,621		Tier:		2				
		Factor at Va	rious Loa	d % (g/kWh)	Hou	rly Emissio	ns at Various	Load % (lb	/hr)
	100	75	50	25	10	100	75	50	25	10
NO _X	11.2	5.3	5.7	5.9	7.8	66.67	23.66	16.97	8.78	4.64
CO	1.0	3.5	1.9	7.4	8.3	5.95	15.63	5.66	11.01	4.94
HC	0.14	0.12	0.21	0.34	0.84	0.83	0.54	0.63	0.51	0.50
PM	0.10	0.20	0.15	0.40	0.45	0.60	0.89	0.45	0.60	0.27
			Ex	haust Flow R	ate (kg/hr)	15085	15390	10714	6183	4140
			E	xhaust Flow F	Rate (acfm)	18,340	18,916	12,865	7,599	4,674
			E	xhaust Flow I	Rate (scfm)	7,373.3	7,522.4	5,236.8	3,022.2	2,023.6
			Ex	khaust Tempe	erature (°F)	852.80	867.20	836.60	867.20	759.20
			Fuel C	uel Combustion Rate (gal/hr)		172.00	151.00	102.80	58.70	

² The exhaust flow rate is converted using the following approach:

Volume rate-	$\frac{\text{mass in kg/hr} \times 1000 \text{ g/kg}}{\text{MW of exhaust air (g/mol)}} \times \text{Gas Constant } \left(\text{m}^3 \cdot \text{Pa/(K·mol)}\right) \times \text{Temperature}$
volume rate=	Ambient Pressure (Pa)

 $\frac{\text{Perature}(K)}{(0.3048 \text{ m})^3 \times \frac{1 \text{ hr}}{60 \text{ min}}}$ 9

MW of exhaust 28.9647 g/mol (assuming equal to ambient air) Ambient pressure 101325 Pa

^{8.314} m³-Pa/(K-mol) Gas constant

Table C-5a. Cold Start Scaling Factors

		Cold Start Emission	Staady State	
			Steauy-State	
	Spike Duration	Spike	(Warm) Emissions ⁺	Cold-Start Scaling
Pollutant	(seconds) ¹	(ppm)	(ppm)	Factor
PM+HC	14	900	30	4.27
NO _X	8	40	38	0.94
СО	20	750	30	9.00

¹ Spike duration, cold-start emission spike, and steady-state (warm) emissions based on data from California Energy Commission (CEC) "Air Quality Implications of Backup Generators in California. The cold-start scaling factor is derived as the ratio of the spike concentration and duration to the steadystate emissions for the initial 60 seconds. An example calculation is provided below for HC. Since a cold-start curve was not developed by CEC, it is assumed that the PM will experience the same trend as HC.

Table C-5b. Cold Start Emission Rates

		Worst-case Emission Rate (lb/hr/engine)							
		Main Genset			Support Genset				
	Startup Emission					Startup Emission			
Pollutant	Warm	Cold-Start	Rate ¹	Warm	Cold-Start	Rate ¹			
НС	1.20	5.12	1.27	0.29	1.25	0.31			
NO _X	66.67	62.46	66.60	6.85	6.42	6.84			
СО	15.63	140.64	17.71	3.18	28.62	3.60			
DEEP/PM	2.01	8.56	2.12	0.18	0.75	0.19			
PM ₁₀ /PM _{2.5}	2.57	10.96	2.71	0.37	1.57	0.39			

¹ Startup hourly emission rate assumes one minute of cold-start emissions and 59 minutes of warm engine emissions.

Table C-5c. Cold Start Emissions

	Annual Emissions	Annual Emissions from
	from Cold Start Hours -	Cold Start Hours -
	Main Gensets	Support Gensets
Pollutant	(tpy)	(tpy)
НС	0.53	8.65E-03
NO _X	27.97	1.92E-01
СО	7.44	1.01E-01
DEEP	0.89	5.18E-03
PM ₁₀ /PM _{2.5}	1.14	1.09E-02
Calculations conservatively assume	28	cold starts per engine,

¹ Calculations conservatively assume

cold starts per engine,

per year.

Table C-6. Project Cooling Unit Emissions

Value	РМ	PM ₁₀	PM _{2.5}
Hours of Operation (hr/yr)	8,760	8,760	8,760
Cooling Units	120	120	120
Total Water Consumption Flowrate (gal/hr)	241	241	241
Recirculation Flowrate (gal/min-unit)	84	84	84
Total Annual Throughput ¹ (tpy water recirculated)	23,149,285	23,149,285	23,149,285
Total Dissolved Solids (TDS) ² (ppm)	550	550	550
Drift Loss ² (wt%)	0.001%	0.001%	0.001%
Total Emissions (tpy)	1.27E-01	1.27E-01	1.27E-01

¹ Recirculation flowrate was provided by Munters Corporation on March 17, 2020.

² Total Dissolved Solids (TDS) were provided by Munters Corporation on December 20, 2019. Drift loss is conservatively assumed to be the drift rate limit listed in the existing site permit.

 $^3\,\,\rm PM_{2.5}$ and $\rm PM_{10}$ are conservatively assumed to be equal to total PM.

Table C-7. HAP and TAP Emissions

Pollutant				Diesel Fired Industrial Engines for Main Gensets ¹	Main	Genset Emiss	ions ²	Diesel Fired Industrial Engines for Support Gensets ¹	Suppor	t Genset Emi	ssions ²	Averaging Period	De Minimis	SQER	Project Emissions	Modeling Required? ³
	CAS Number	HAP?	TAP?	(lb/MMBtu)	(lb/hr)	(lb/day)	(tpy)	(lb/MMBtu)	(lb/hr)	(lb/day)	(tpy)			(lb/avg period)		
Acenaphthene 4	83-32-9	Yes	No	4.68E-06	3.34E-03	0.08	9.18E-05	1.42E-06	8.98E-06	2.15E-04	2.47E-07	-	-	-	-	
Acenaphthylene 4	208-96-8	Yes	No	9.23E-06	6.58E-03	0.16	1.81E-04	5.06E-06	3.20E-05	7.68E-04	8.80E-07	-	-	-	-	
Acetaldehyde 4	75-07-0	Yes	Yes	2.52E-05	0.02	0.43	4.94E-04	7.67E-04	4.85E-03	0.12	1.33E-04	year	3.00E+00	6.00E+01	1.25	De Minimis
Acrolein	107-02-8	Yes	Yes	7.88E-06	5.62E-03	0.13	1.55E-04	9.25E-05	5.85E-04	1.40E-02	1.61E-05	24-hr	1.30E-03	2.60E-02	0.15	Yes
Anthracene 4	120-12-7	Yes	No	1.23E-06	8.77E-04	0.02	2.41E-05	1.87E-06	1.18E-05	2.84E-04	3.25E-07	-	-	-	-	
Benzene	71-43-2	Yes	Yes	7.76E-04	0.55	13.28	0.02	9.33E-04	5.90E-03	0.14	1.62E-04	year	1.00E+00	2.10E+01	30.76	Yes
Benzo(a)anthracene 4	56-55-3	Yes	Yes	6.22E-07	4.44E-04	1.06E-02	1.22E-05	1.68E-06	1.06E-05	2.55E-04	2.92E-07	year	4.50E-02	8.90E-01	0.02	De Minimis
Benzo(a)pyrene 4	50-32-8	Yes	Yes	2.57E-07	1.83E-04	4.40E-03	5.04E-06	1.88E-07	1.19E-06	2.85E-05	3.27E-08	year	8.20E-03	1.60E-01	1.01E-02	No
Benzo(b)fluoranthene 4	205-99-2	Yes	Yes	1.11E-06	7.92E-04	0.02	2.18E-05	9.91E-08	6.26E-07	1.50E-05	1.72E-08	year	4.50E-02	8.90E-01	0.04	De Minimis
Benzo(g,h,l)perylene 4		Yes	No	5.56E-07	3.96E-04	9.52E-03	1.09E-05	4.89E-07	3.09E-06	7.42E-05	8.50E-08	-	-	-	-	
Benzo(k)fluoranthene 4	207-08-9	Yes	Yes	2.18E-07	1.55E-04	3.73E-03	4.27E-06	1.55E-07	9.80E-07	2.35E-05	2.69E-08	year	4.50E-02	8.90E-01	8.60E-03	De Minimis
1,3-Butadiene	106-99-0	Yes	Yes					3.91E-05	2.47E-04	5.93E-03	6.80E-06	year	2.70E-01	5.40E+00	1.36E-02	De Minimis
Chrysene	218-01-9	Yes	Yes	1.53E-06	1.09E-03	0.03	3.00E-05	3.53E-07	2.23E-06	5.36E-05	6.14E-08	year	4.50E-01	8.90E+00	0.06	De Minimis
Dibenz(a,h)anthracene 4	53-70-3	Yes	Yes	3.46E-07	2.47E-04	5.92E-03	6.79E-06	5.83E-07	3.69E-06	8.84E-05	1.01E-07	year	4.10E-03	8.20E-02	1.38E-02	No
Fluoranthene 4	206-44-0	Yes	No	4.03E-06	2.87E-03	0.07	7.90E-05	7.61E-06	4.81E-05	1.15E-03	1.32E-06	-	-	-	-	
Fluorene ⁴	86-73-7	Yes	No	1.28E-05	9.13E-03	0.22	2.51E-04	2.92E-05	1.85E-04	4.43E-03	5.08E-06	-	-	-	-	
Formaldehyde 4	50-00-0	Yes	Yes	7.89E-05	0.06	1.35	1.55E-03	1.18E-03	7.46E-03	0.18	2.05E-04	year	1.40E+00	2.70E+01	3.50	No
Indeno(1,2,3-cd)pyrene	193-39-5	Yes	Yes	4.14E-07	2.95E-04	7.09E-03	8.12E-06	3.75E-07	2.37E-06	5.69E-05	6.52E-08	year	4.50E-02	8.90E-01	0.02	De Minimis
Naphthalene 4	91-20-3	Yes	Yes	1.30E-04	0.09	2.22	2.55E-03	8.48E-05	5.36E-04	1.29E-02	1.47E-05	year	2.40E-01	4.80E+00	5.13	Yes
Phenanthrene	85-01-8	Yes	No	4.08E-05	0.03	0.70	8.00E-04	2.94E-05	1.86E-04	4.46E-03	5.11E-06	-	-	-	-	
Propylene 4	115-07-1	No	Yes	2.79E-04	0.20	4.77	5.47E-03	2.58E-03	0.02	0.39	4.48E-04	24-hr	1.10E+01	2.20E+02	5.17	De Minimis
Pyrene 4	129-00-0	Yes	No	3.71E-06	2.65E-03	0.06	7.28E-05	4.78E-06	3.02E-05	7.25E-04	8.31E-07	-	-	-	-	
Toluene	108-88-3	Yes	Yes	2.81E-04	0.20	4.81	5.51E-03	4.09E-04	2.59E-03	0.06	7.11E-05	24-hr	1.90E+01	3.70E+02	4.87	De Minimis
Xylenes	1330-20-7	Yes	Yes	1.93E-04	0.14	3.30	3.78E-03	2.85E-04	1.80E-03	0.04	4.95E-05	24-hr	8.20E-01	1.60E+01	3.35	No
Diesel engine exhaust, parti 5		No	Yes	See Table C-3b	63.46	109.61	1.70	See Table C-3c.	0.37	4.41	9.92E-03					Yes
culate												year	2.70E-02	5.40E-01	3,421.84	
SO ₂	7446-09-05	No	Yes	See Table C-3b.	1.33	2.34	0.04	See Table C-3c.	1.97	24.60	0.05	1-hr	4.60E-01	1.20E+00	3.29	Yes
CO 6	630-08-0	No	Yes	See Table C-3b.	531.29	890.70	13.77	See Table C-3c.	7.21	80.34	0.19	1-hr	1.10E+00	4.30E+01	538.50	Yes
NU ₂	10102-44-0	No	Yes	See Table C-3b.	200.02	4,800.40	5.50	See Table C-3c.	1.37	32.89	0.04	1-hr	4.60E-01	8.70E-01	201.39	Yes
	Total HAP Emissions:		1.12	26.93	0.03		0.02	0.59	6.73E-04							
	Total TAP Emissions:				797.37	5,833.43	21.04		10.96	143.20	0.29					

1. Emission factors are from AP-42 Tables 3.4-3 and 3.4-4.

2. Diesel heat content 0.137 MMBtu/gal per AP-42, Appendix A. Fuel consumption rate is provided in Table 1c. Emissions in this table represent the maximum hourly, daily, and annual emission for each pollutant.

3. Modeling is required if the project emissions are greater than the respective Small Quantity Emission Rate.

4. These are categorized as polycyclic organic matter (POM), which is a HAP.

5. Diesel particulate matter is assumed to be equivalent to filterable particulate matter.

6. SO₂. CO and NO_X emissions with maximum operation scenario (when all emergency generators are in operation) are listed here. It is conservatively assumed that 10% of NO x are emitted in the form of NO₂.

Table C-8a. Existing Gensets Operation Scenario Summary

ſ		Maximum Operatio	ons for Each Engine	Maximum Operations for All Engines			
	Operation Scenario	(hr/day/engine)	(hr/yr/engine)	(engine-hr/hr)	(engine-hr/day)	(engine-hr/yr)	
ſ	Main Genset Running at Any Load ¹	24	57.5	34	816	1955	
	Support Genset Running at Any Load	24	57.5	3	72	173	

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing).

² The project includes 34 main gensets and 3 support genset.

Table C-8b. Existing Gensets Criteria Pollutants Emission Estimate - Main Gensets

			Total Maximum	Emission Rate for	r Main Gensets ¹
			Warm Engine	Cold-Start	Annual Total for All Engines
Pollutant	Emiss	(Total lb/hr)	(Total lb/hr)	(tpy) ⁴	
Particulate Matter (PM) ²	Vendor Hou	rly Emission Rate	18.18	19.17	0.54
Condensable PM ²	Vendor Hourly E Hyd	mission Rate for Total rocarbon	36.32	38.30	1.07
Particulate Matter <10 microns $(PM_{10})^2$	Vendor Hou	rly Emission Rate	54.50	57.47	1.61
Particulate Matter < 2.5 microns $(PM_{2.5})^2$	Vendor Hou	rly Emission Rate	54.50	57.47	1.61
Sulfur Dioxide $(SO_2)^3$	1.21E-05	lb/hp-hr per AP-42	1.16	1.16	3.33E-02
Carbon Monoxide (CO)	Vendor Hou	rly Emission Rate	134.63	152.58	4.12
Nitrogen Oxides (NO _x)	Vendor Hou	rly Emission Rate	1364.70	1363.26	39.22
Volatile Organic Compounds (VOC)	Vendor Hou	rly Emission Rate	36.32	38.30	1.07

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing).

² PM₁₀ and PM_{2.5} emissions are the diesel PM emission rates plus the condensable PM emission rate. Condensable PM emissions are conservatively assumed to be the same as hydrocarbon emissions from vendor data.

³ SO₂ emissions are calculated conservatively assuming constant operation at 100% load (i.e., maximum engine power). SO ₂ emissions are based on maximum sulfur content allowed in ULSD (15 ppm) and are calculated according to methodology presented in AP-42, Chapter 3.4, Table 3.4-1.

⁴ Emission calculations conservatively assumes 28 1-hour cold-start periods per year.

Table C-8c. Existing Gensets Criteria Pollutants Emission Estimate - Support Genset

		Total Maximum	Engine Emission F Gensets ¹	late for Support
		Warm Engine	Cold-Start	Annual Total for All Engines
Pollutant	Emission Factor	(Total lb/hr)	(Total lb/hr)	(tpy) ⁴
Particulate Matter (PM) ²	Maximum Vendor Hourly Emission Rate	0.45	0.47	1.33E-02
Condensable PM ²	Maximum Vendor Hourly Emission Rate for Total Hydrocarbon	0.64	0.67	1.89E-02
Particulate Matter <10 microns (PM $_{10}$) ²	Maximum Vendor Hourly Emission Rate	1.09	1.15	3.22E-02
Particulate Matter < 2.5 microns (PM $_{2.5}$) ²	Maximum Vendor Hourly Emission Rate	1.09	1.15	3.22E-02
Sulfur Dioxide (SO ₂) 3	2.05E-03 lb/hp-hr per AP-42	2.62	2.62	7.52E-02
Carbon Monoxide (CO)	Maximum Vendor Hourly Emission Rate	1.79	2.03	0.05
Nitrogen Oxides (NO _x)	Maximum Vendor Hourly Emission Rate	10.78	10.77	0.31
Volatile Organic Compounds (VOC)	Maximum Vendor Hourly Emission Rate	0.64	0.67	1.89E-02

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing).

² PM₁₀ and PM_{2.5} emissions are the diesel PM emission rates plus the condensable PM emission rate. Condensable PM emissions are conservatively assumed to be the same as hydrocarbon emissions from vendor data.

³ SO₂ emissions are calculated conservatively assuming constant operation at 100% load (i.e., maximum engine power). SO ₂ emissions are calculated according to methodology presented in AP-42, Chapter 3.3, Table 3.3-1.

⁴ Emission calculations conservatively assumes

1-minute cold-start periods per year.

Table C-8d. Existing Gensets Fuel Consumption Summary

	Maximum Total	Maximum Total	Maximum Total
	Hourly Fuel	Daily Fuel	Annual Fuel
	Consumption Rate	Consumption Rate	Consumption Rate
Genset Type ¹	(gal/hr)	(gal/day)	(gal/yr)
Main Genset	4491.60	107,798	258,267
Support Genset	61.50	1,476	3,536
Total	4553.10	109 274	261.803

28

¹ This operating scenario includes all categories of operations, including emergency run, maintenance and testing runs. When all engines are required to be operated at the same time (e.g., emergency operation, certain testing).

	Table C-9. Existing delisets Load Emission Tables													
CAT C9				GenSet Po	wer (kW):	300		Quantity:	1					
Engine size	e (hp):	480												
	l	Factor at Va	rious Load	% (g/hp-h	r)	Но	urly Emission	ns at Various	Load % (lb/	′hr)				
	100	75	50	25	10	100	75	50	25	10				
NO _X	4.27	2.92	2.13	1.94	2.61	4.48	2.31	1.19	0.64	0.48				
CO	0.45	0.46	0.96	1.36	2.3	0.47	0.37	0.53	0.45	0.42				
НС	0.11	0.15	0.32	0.51	0.79	0.11	0.12	0.18	0.17	0.14				
PM	0.06	0.08	0.26	0.29	0.34	0.07	0.07	0.15	0.10	0.06				
			Ex	haust Flow I	Rate (acfm)	2,460.9	2,109.4	1,810.5	1,299.8	851.2				
Exhaust Temperature (°F)							826.3	784.5	745.0	650.3				
			Fuel Con	sumption Ra	ate (gal/hr)	22.7	17.6	13.6	8.7	5.2				

Table C-9, Existing Gensets Load Emission Tables

¹ Factors, hourly emission rates, and exhaust flow characteristics are obtained from the Performance Data section in "CAT C9 300kW Technical Data.pdf".

CAT C9				GenSet Po	wer (kW):	250		Quantity:	2	
Engine siz	e (hp):	398		Tier:		3				
Factor at Various Load % (g/hp-				l % (g/hp-h	r)	Hou	ırly Emissio	ns at Various	Load % (lb,	/hr)
	100	75	50	25	10	100	75	50	25	10
NO _X	3.14	2.38	2.16	2.27	3.22	3.15	1.78	1.11	0.70	0.55
CO	0.68	0.90	1.01	2.30	3.89	0.59	0.60	0.47	0.63	0.60
HC	0.17	0.29	0.44	0.57	1.03	0.17	0.22	0.23	0.19	0.18
PM	0.16	0.22	0.23	0.40	0.49	0.14	0.15	0.11	0.11	0.08
			Exhaust Flow Rate (acfm)			2,245.6	1977	1616	1077	721
		Exhaust Temperature (°F)				852	791	756	721	612
		Fuel Combustion Rate (gal/hr			ate (gal/hr)	19.40	15.50	11.60	7.30	4.40

Two different years of CAT C9 engines are present on site. This data represents a worst case across both data sheets.

CAT 3516C			GenSet Po	wer (kW):	2000		Quantity:	23				
Engine siz	e (hp):	2,937										
Factor at Various Load % (g/hp-hr)						Hourly Emissions at Various Load % (lb/hr)						
	100	75	50	25	10	100	75	50	25	10		
NO _X	6.56	4.67	3.82	5.04	7.13	42.45	22.75	12.81	9.31	6.47		
CO	0.54	0.39	0.60	2.12	4.36	3.48	1.88	2.00	3.91	3.95		
НС	0.15	0.23	0.34	0.49	1.08	0.93	1.13	1.13	0.90	0.98		
PM	0.04	0.05	0.08	0.31	0.49	0.23	0.22	0.27	0.57	0.45		
-			E	xhaust Flow	Rate (acfm)	15,292.8	12,897.9	10,138.7	6,328.1	4,478.2		
	Exhaust Temperature (°F)			752.10	684.60	654.00	641.70	552.80				
Fuel Combustion Rate (gal/hr			ate (gal/hr)	138.0	107.5	77.5	44.8	26.4				

¹ Exhaust flow characteristics are obtained from Performance Data sheet for 2000 kW CAT 3516C.

CAT 3512	С			GenSet Po	wer (kW):	1500		Quantity:	6	
Engine siz	ze (hp):	2,206		Tier:		2				
Factor at Various Load % (g/hp-hr)				r)	Ηοι	ırly Emissio	ns at Various	Load % (lb	/hr)	
	100	75	50	25	10	100	75	50	25	10
NO _X	6.09	4.09	3.95	5.33	8.34	29.35	14.84	9.89	7.39	5.70
CO	0.80	0.66	1.36	2.88	5.59	3.85	2.41	3.40	3.98	3.82
нс	0.15	0.22	0.29	0.42	0.97	0.72	0.78	0.73	0.58	0.66
PM	0.04	0.06	0.12	0.27	0.33	0.20	0.20	0.31	0.37	0.23
			Ez	khaust Flow	Rate (acfm)	10,909.2	9,156.1	6,856.9	4,354.9	3,012.8
Exhaust Temperature (°F			erature (°F)	759.0	700.6	686.4	648.1	526.2		
Fuel Combustion Rate (gal/hr				ate (gal/hr)	104.6	82.0	58.1	33.9	19.7	

Table C-10a. Existing Genset Cold Start Scaling Factors

	Spike Duration	Cold-Start Emission Spike ¹	Steady-State (Warm) Emissions ¹	Cold-Start Scaling
Pollutant	(seconds) ¹	(ppm)	(ppm)	Factor
PM+HC	14	900	30	4.27
NO _x	8	40	38	0.94
СО	20	750	30	9.00

1 Spike duration, cold-start emission spike, and steady-state (warm) emissions based on data from California Energy Commission (CEC) 'Air Quality Implications of Backup Generators in California. The cold-start scaling factor is derived as the ratio of the spike concentration and duration to the steady-state emissions for the initial 60 seconds. An example calculation is provided below for HC. Since a cold-start curve was not developed by CEC, it is assumed that the PM will experience the same trend as HC.

Table C-10b. Existing Genset Cold Start Emission Rates

	Worst-case Emission Rate (lb/hr)										
		Main Genset		Support Genset							
			Startup Emission			Startup Emission					
Pollutant	Warm	Cold-Start	Rate 1	Warm	Cold-Start	Rate 1					
HC	36.32	154.97	38.30	0.64	2.73	0.67					
NO _X	1364.70	1278.51	1363.26	10.78	10.10	10.77					
CO	134.63	1211.67	152.58	1.79	16.11	2.03					
DEEP/PM	18.18	77.57	19.17	0.45	1.92	0.47					
PM ₁₀ /PM _{2.5}	54.50	232.53	57.47	1.09	4.65	1.15					

¹ Startup hourly emission rate assumes one minute of cold-start emissions and 59 minutes of warm engine emissions.

Table C-10c. Existing Genset Cold Start Emissions

	Annual Emissions from Cold Start Hours - Main Gensets	Annual Emissions from Cold Start Hours - Support Gensets		
Pollutant	(tpy)	(tpy)		
HC	0.54	9.45E-03		
NO _X	19.09	1.51E-01		
CO	2.14	2.84E-02		
DEEP	0.27	6.64E-03		
PM ₁₀ /PM _{2.5}	0.80	1.61E-02		
¹ Calculations conservatively assume	28	cold starts per engine,		

per year.

Table C-11. Existing Cooling Unit Emissions

		Annu	Annual Emission Rate (tpy)				
Emission Point	Quantity	РМ	PM ₁₀	PM _{2.5}			
Permitted Cooling Units	176	2.32	2.32	2.32			
Existing Cooling Units	148	1.95	1.95	1.95			

¹ 176 cooling units were permitted for the site, but only 148 have actually been constructed to date. PTE for exisiting cooling units is therefore calculated for units that have actually been installed.

Pollutant				Diesel Fired Industrial Engines for Main Gensets ¹	Main	Genset Emiss	ions ²	Diesel Fired Industrial Engines for Support Gensets ¹	Suppor	't Genset Emis	ssions ²	Averaging Period
	CAS Number	HAP?	TAP?	(lb/MMBtu)	(lb/hr)	(lb/day)	(tpy)	(lb/MMBtu)	(lb/hr)	(lb/day)	(tpy)	
Acenaphthene 4	83-32-9	Yes	No	4.68E-06	2.88E-03	0.07	8.28E-05	1.42E-06	1.20E-05	2.87E-04	3.44E-07	-
Acenaphthylene 4	208-96-8	Yes	No	9.23E-06	5.68E-03	0.14	1.63E-04	5.06E-06	4.26E-05	1.02E-03	1.23E-06	-
Acetaldehyde 4	75-07-0	Yes	Yes	2.52E-05	0.02	0.37	4.46E-04	7.67E-04	6.46E-03	0.16	1.86E-04	year
Acrolein	107-02-8	Yes	Yes	7.88E-06	4.85E-03	0.12	1.39E-04	9.25E-05	7.79E-04	0.02	2.24E-05	24-hr
Anthracene 4	120-12-7	Yes	No	1.23E-06	7.57E-04	0.02	2.18E-05	1.87E-06	1.58E-05	3.78E-04	4.53E-07	-
Benzene	71-43-2	Yes	Yes	7.76E-04	0.48	11.46	1.37E-02	9.33E-04	7.86E-03	0.19	2.26E-04	year
Benzo(a)anthracene 4	56-55-3	Yes	Yes	6.22E-07	3.83E-04	9.19E-03	1.10E-05	1.68E-06	1.42E-05	3.40E-04	4.07E-07	year
Benzo(a)pyrene 4	50-32-8	Yes	Yes	2.57E-07	1.58E-04	3.80E-03	4.55E-06	1.88E-07	1.58E-06	3.80E-05	4.55E-08	year
Benzo(b)fluoranthene ⁴	205-99-2	Yes	Yes	1.11E-06	6.83E-04	0.02	1.96E-05	9.91E-08	8.35E-07	2.00E-05	2.40E-08	year
Benzo(g,h,l)perylene 4		Yes	No	5.56E-07	3.42E-04	8.21E-03	9.84E-06	4.89E-07	4.12E-06	9.89E-05	1.18E-07	-
Benzo(k)fluoranthene 4	207-08-9	Yes	Yes	2.18E-07	1.34E-04	3.22E-03	3.86E-06	1.55E-07	1.31E-06	3.13E-05	3.75E-08	year
1,3-Butadiene	106-99-0	Yes	Yes					3.91E-05	3.29E-04	7.91E-03	9.47E-06	year
Chrysene	218-01-9	Yes	Yes	1.53E-06	9.41E-04	0.02	2.71E-05	3.53E-07	2.97E-06	7.14E-05	8.55E-08	year
Dibenz(a,h)anthracene 4	53-70-3	Yes	Yes	3.46E-07	2.13E-04	5.11E-03	6.12E-06	5.83E-07	4.91E-06	1.18E-04	1.41E-07	year
Fluoranthene ⁴	206-44-0	Yes	No	4.03E-06	2.48E-03	0.06	7.13E-05	7.61E-06	6.41E-05	1.54E-03	1.84E-06	-
Fluorene ⁴	86-73-7	Yes	No	1.28E-05	7.88E-03	0.19	2.26E-04	2.92E-05	2.46E-04	5.90E-03	7.07E-06	-
Formaldehyde 4	50-00-0	Yes	Yes	7.89E-05	0.05	1.17	1.40E-03	1.18E-03	9.94E-03	0.24	2.86E-04	year
Indeno(1,2,3-cd)pyrene	193-39-5	Yes	Yes	4.14E-07	2.55E-04	6.11E-03	7.32E-06	3.75E-07	3.16E-06	7.58E-05	9.08E-08	year
Naphthalene 4	91-20-3	Yes	Yes	1.30E-04	0.08	1.92	2.30E-03	8.48E-05	7.14E-04	0.02	2.05E-05	year
Phenanthrene	85-01-8	Yes	No	4.08E-05	0.03	0.60	7.22E-04	2.94E-05	2.48E-04	5.95E-03	7.12E-06	-
Propylene 4	115-07-1	No	Yes	2.79E-04	0.17	4.12	4.94E-03	2.58E-03	0.02	0.52	6.25E-04	24-hr
Pyrene 4	129-00-0	Yes	No	3.71E-06	2.28E-03	0.05	6.56E-05	4.78E-06	4.03E-05	9.67E-04	1.16E-06	-
Toluene	108-88-3	Yes	Yes	2.81E-04	0.17	4.15	4.97E-03	4.09E-04	3.45E-03	0.08	9.91E-05	24-hr
Xylenes	1330-20-7	Yes	Yes	1.93E-04	0.12	2.85	3.41E-03	2.85E-04	2.40E-03	0.06	6.90E-05	year
Diesel engine exhaust, parti ⁵ culate		No	Yes	See Table C-8b.	19.17	437.31	0.54	See Table C-8c	0.47	10.82	1.33E-02	year
SO ₂ 6	7446-09-05	No	Yes	See Table C-8b.	1.16	27.81	0.03	See Table C-8c	2.62	62.78	0.08	1-hr
CO 6	630-08-0	No	Yes	See Table C-8b.	152.58	3,249.07	4.12	See Table C-8c	2.03	43.20	0.05	1-hr
NO ₂	10102-44-0	No	Yes	See Table C-8b.	136.47	3,275.28	3.92	See Table C-8c	1.08	25.87	0.03	1-hr
Total HAP Emissions:			0.97	23.24	0.03		0.03	0.78	9.38E-04			
Total TAP Emissions:					310.47	7,015.69	8.64		6.25	143.96	0.18	

Table C-12. Existing HAP and TAP Emissions

1. Emission factors are from AP-42 Tables 3.4-3 and 3.4-4.

2. Diesel heat content

0.137 MMBtu/gal per AP-42, Appendix A. Fuel consumption rate is provided in Table 1c. Emissions in this table represent the maximum hourly, daily, and annual emission for each pollutant.

3. Modeling is required if the project emissions are greater than the respective Small Quantity Emission Rate.

4. These are categorized as polycyclic organic matter (POM), which is a HAP.

5. Diesel particulate matter is assumed to be equivalent to filterable particulate matter.

6. SO₂, CO and NO_x emissions with maximum operation scenario (when all emergency generators are in operation) are listed here. It is conservatively assumed that 10% of NO_x are emitted in the form of NO₂.

2. ENGINE SPECIFICATIONS - PROJECT

Sabey Data Center Properties | Intergate Quincy Notice of Construction Trinity Consultants



TECHNICAL DATA CATERPILLAR 3516C PACKAGED GENERATOR SET RATED 2500EKW STANDBY POWER, 277/480 VOLT, 3-PHASE, 60 Hz, UL LISTED

PREPARED FOR: SABEY CORPORATION

JOB: SABEY IGQ - DOE PERMIT GENERATOR

> MICHAEL VA PROJECT ENGINEER OCTOBER 2019 REV. 1



(This Page Intentionally Left Blank)



CAT CUT/DATA SHEETS



(This Page Intentionally Left Blank)
Cat[®] 3516C Diesel Generator Sets





 Bore – mm (in)
 170 (6.69)

 Stroke – mm (in)
 215 (8.46)

 Displacement – L (in³)
 78 (4764.73)

 Compression Ratio
 14.7:1

 Aspiration
 TA

 Fuel System
 EUI

 Governor Type
 ADEM™ A3

Image shown may not reflect actual configuration



Standard Features

Cat® Diesel Engine

- Meets U.S. EPA Stationary Emergency Use Only (Tier 2) emission standards
- Reliable performance proven in thousands of applications worldwide

Generator Set Package

- Accepts 100% block load in one step and meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

Alternators

- Superior motor starting capability minimizes
 need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

Cooling System

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- · Tested to ensure proper generator set cooling

Emissions Performance

U.S. EPA Stationary Emergency Use Only (Tier 2)

EMCP 4 Control Panels

- · User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements

Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

Worldwide Product Support

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region

Optional Equipment

Engine

Air Cleaner

Single elementDual element

Muffler

□ Industrial grade (15 dB)

Starting

- Standard batteries
 Oversized batteries
 Standard electric starter(s)
 Heavy duty electric starter(s)
 Air starter(s)
 Jacket water heater
- Alternator

Output voltage

 □ 380∨
 □ 6300∨

 □ 440∨
 □ 6600∨

 □ 480∨
 □ 6900∨

 □ 600∨
 □ 12470∨

 □ 2400∨
 □ 13200∨

 □ 4160∨
 □ 13800∨

Temperature Rise

- (over 40°C ambient)
- □ 150°C
 □ 125°C/130°C
 □ 105°C
- □ 80°C

Winding type

Random woundForm wound

Excitation

- Internal excitation (IE)
- Permanent magnet (PM)

Attachments

- □ Anti-condensation heater
- Stator and bearing temperature monitoring and protection

Power Termination

Туре

Bus bar
Circuit breaker
1600A 2000A
2500A 3000A
3200A 4000A
5000A
IEC UL
3-pole 4-pole
Manually operated
Electrically operated

Trip Unit

LSI LSI-G LSIG-P

Control System

Controller

EMCP 4.2B
 EMCP 4.3
 EMCP 4.4

Attachments

Local annunciator module
 Remote annunciator module
 Expansion I/O module
 Remote monitoring software

Charging

Battery charger – 10A
 Battery charger – 20A
 Battery charger – 35A

Vibration Isolators

RubberSpringSeismic rated

Cat Connect

- Connectivity
- Ethernet
- □ Cellular □ Satellite

Extended Service Options

Terms

2 year (prime)
 3 year
 5 year
 10 year

Coverage

- Silver
- Gold
- □ Platinum
- Platinum Plus

Ancillary Equipment

- Automatic transfer switch (ATS)
- Uninterruptible power supply (UPS)
- Paralleling switchgear
- Paralleling controls

Certifications

- UL2200
- CSA
- □ IBC seismic certification
- □ OSHPD pre-approval

Note: Some options may not be available on all models. Certifications may not be available with all model configurations. Consult factory for availability.





Package Performance

Performance		Missio	n Critical
Frequency		60) Hz
Gen set power rating with fan		2500 el	
Gen set power rating with fan @ 0.8 power factor		3125 kVA	
Emissions	Ī	EPA ES	E (TIER 2)
Performance number	Ī	EM1	895-02
Fuel Consumption			
100% load with fan – L/hr (gal/hr)		656.8	(175.3)
75% load with fan - L/hr (gal/hr)		510.8	(134.9)
50% load with fan - L/hr (gal/hr)		372.4	(98.4)
25% load with fan - L/hr (gal/hr)		219.3	(57.9)
Cooling System			
Radiator air flow restriction (system) – kPa (in. water)		0.12	(0.48)
Radiator air flow – m³/min (cfm)		2800.0	(98881)
Engine coolant capacity – L (gal)		233.0	(61.6)
Radiator coolant capacity – L (gal)		268.8	(71.0)
Total coolant capacity – L (gal)		501.8	(132.6)
Inlet Air			
Combustion air inlet flow rate – m ³ /min (cfm)		242.2	(7212.2)
Exhaust System			
Exhaust stack gas temperature – °C (°F)		490.7	(915.2)
Exhaust gas flow rate – m ³ /min (cfm)		554.5	(19578.8)
Exhaust system backpressure (maximum allowable) – kPa (in. water)		6.7	(27.0)
Heat Rejection			
Heat rejection to jacket water – kW (Btu/min)		826	(46992)
Heat rejection to exhaust (total) – kW (Btu/min)		2502	(142265)
Heat rejection to aftercooler – kW (Btu/min)		786	(44723)
Heat rejection to atmosphere from engine – kW (Btu/min)		161	(9146)
Heat rejection from alternator – kW (Btu/min)		121	(6853)
Emissions* (Nominal)			
NOx mg/Nm ³ (g/hp-h)		2349.1	(5.32)
CO mg/Nm ³ (g/hp-h)		195.4	(0.42)
HC mg/Nm ³ (g/hp-h)		42.1	(0.10)
PM mg/Nm ³ (g/hp-h)		14.1	(0.04)
Emissions* (Potential Site Variation)			
NOx mg/Nm ³ (g/hp-h)		2818.9	(6.38)
CO mg/Nm ³ (g/hp-h)		351.8	(0.76)
HC mg/Nm ³ (g/hp-h)		55.9	(0.14)
PM mg/Nm ³ (g/hp-h)		19.7	(0.05)

*mg/Nm³ levels are corrected to 5% O₂. Contact your local Cat dealer for further information.



Weights and Dimensions



Dim "A"	Dim "B"	Dim "C"	Dry Weight
mm (in)	mm (in)	mm (in)	kg (lb)
7033 (276.9)	2766 (108.9)	3018 (118.8)	17 590 (38,780)

Note: For reference only. Do not use for installation design. Contact your local Cat dealer for precise weights and dimensions.

Ratings Definitions

Standby

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Mission Critical

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 85% of the mission critical power rating. Typical peak demand up to 100% of rated power for up to 5% of the operating time. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Prime

Output available with varying load for an unlimited time. Average power output is 70% of the prime power rating. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year.

Continuous

Output available with non-varying load for an unlimited time. Average power output is 70-100% of the continuous power rating. Typical peak demand is 100% of continuous rated kW for 100% of the operating hours.

Applicable Codes and Standards

AS1359, CSA C22.2 No100-04, UL142, UL489, UL869, UL2200, NFPA37, NFPA70, NFPA99, NFPA110, IBC, IEC60034-1, ISO3046, ISO8528, NEMA MG1-22, NEMA MG1-33, 2014/35/EU, 2006/42/EC, 2014/30/EU.

Note: Codes may not be available in all model configurations. Please consult your local Cat dealer for availability.

Data Center Applications

Tier III/Tier IV compliant per Uptime Institute requirements. ANSI/TIA-942 compliant for Rated-1 through Rated-4 data centers.

Fuel Rates

Fuel rates are based on fuel oil of 35° API [16°C (60°F)] gravity having an LHV of 42,780 kJ/kg (18,390 Btu/lb) when used at 29°C (85°F) and weighing 838.9 g/liter (7.001 lbs/U.S. gal.)

www.cat.com/electricpower ©2019 Caterpillar All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

CAT, CATERPILLAR, LET'S DO THE WORK, their respective logos, "Caterpillar Yellow", the "Power Edge" and Cat "Modern Hex" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

CAT[®] RETROFIT SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM

Horizontal Design



Serviceability

- SCR catalyst hatch is hinged for ease of service during checks and fully removable for access during SCR catalyst removal and replacement.
- DOC/DPF hatch can be lifted by one technician without the need for cranes.
- Nut strips provide ease in securing of hatches after service.
- Catalysts are packaged in lightweight, easy-to-handle modules.

Performance

- Dual wall reactor housing with standard insulation blanket provides superior heat retention for maximum emissions reduction.
- Closed loop dosing control system ensures highest levels of emissions reductions at lowest cost.
- Integral silencer design provides high levels of sound reduction.

Flexibility

• Addition of DOC or DPF catalysts can be performed at a later date with no changes to unit.

Support

 One source for warranty on complete package that includes worldwide Cat[®] dealer coverage on engine and aftertreatment.

Durability

- Reactor housing is constructed of stainless steel for superior life in indoor and outdoor installations.
- Standard powder-coated steel dosing cabinet provides protection in indoor environments while an optional stainless steel cabinet provides additional durability in corrosive indoor environments.
- Specialized mounting feet allow natural thermal expansion during operation, reducing the potential for stress cracking.

Ease of Installation

- Mounting bosses provide easy installation of harnesses on site as well as a durable method of retention during operation.
- Integral lifting eyes reduce guesswork and potential safety issues involved with moving the unit by providing attachment points that promote stability.
- Integrated mixing tube and silencing provide easy installation.

Safety

- Standard insulation blanket reduces surface temperature for additional safety.
- E-stop on dosing cabinet enhances safety by providing the ability to completely shut down the SCR system in an emergency situation.



CAT[®] RETROFIT SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM Horizontal Design

Housing			
Construction	409 Stainless Steel		
Configuration	Bottom-in, Top-out		
Inlet / Outlet Type	Flange		
Lifting Lugs	Qty. 4 at Corners		
Access Hatch (SCR)	Side Mounted, Hinged		
Access Hatch (DOC / DPF)	Top Mounted, Liftable		

Catalysts (SCR)			
Construction	Ceramic		
Catalysts Serviceable	Yes		
Sulfur Tolerance (Diesel)	ULSD (<15 PPM)		
Biodesel	Up to B20		
Fuel Quality (Gas)	Pipeline Quality Natural Gas		

Catalysts (Optional DOC/DPF)			
Construction	Ceramic		
Catalysts Serviceable	Yes		
Sulfur Tolerance (Diesel)	ULSD (<15 PPM)		
Biodesel	Up to B20		
Fuel Quality (Gas)	Pipeline Quality Natural Gas		

Dosing Cabinet			
Construction (Standard)	Powder-coated Steel		
Construction (Optional)	Stainless Steel		

Performance		
Max. NOx Reduction	Up to 95%	
Max. CO Reduction	Up to 95%	
Max. HC Reduction	Up to 90%	
Max. PM Reduction	Over 85%	
Silencing Capability	Up to 45 dB(A)	

Contact your Cat dealer in situations where standard features listed above do not meet required project specifications.

	Weights (Est.) (SCR Housing	with SCR Catalys	sts)
3x3x3		2600 kg	5732 lbs
4x3x3		3200 kg	7055 lbs
4x4x3		3450 kg	7607 lbs
5x4x3		4000 kg	8819 lbs

Weights (Est.) (SCR Housing w	vith SCR and DC	OC Catalysts)
3x3x3	2763 kg	6092 lbs
4x3x3	3400 kg	7496 lbs
4x4x3	3687 kg	8129 lbs
5x4x3	4300 kg	9481 lbs

Weights (Est.) (SCR Housing wit	h SCR Catalysts	and DPF Filters)
3x3x3	2800 kg	6173 lbs
4x3x3	3500 kg	7717 lbs
4x4x3	3800 kg	8378 lbs
5x4x3	4400 kg	9701 lbs

Inlet/Outlet (Number/Size)					
Inlet			Outlet		
3x3x3	1 x	305 mm/12.0 in	3x3x3	1 x	508 mm/20.0 in
4x3x3	2 x	406 mm/16.0 in	4x3x3	1 x	508 mm/20.0 in
4x4x3	2 x	508 mm/20.0 in	4x4x3	1 x	610 mm/24.0 in
5x4x3	2 x	508 mm/20.0 in	5x4x3	1 x	610 mm/24.0 in

Dimensions				
	Length	Width	Height	
3x3x3	4024 mm/158.4 in	1935 mm/76.2 in	1819 mm/71.6 in	
4x3x3	4024 mm/158.4 in	2390 mm/94.1 in	1948 mm/76.7 in	
4x4x3	4024 mm/158.4 in	2390 mm/94.1 in	1948 mm/76.7 in	
5x4x3	4024 mm/158.4 in	2868 mm/112.9 in	1948 mm/76.7 in	

BUILT FOR IT."

CAT, CATERPILLAR, BUILT FOR IT, their respective logos, "Caterpillar Yellow" and the "Power Edge" trade dress, as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission. PEHJ0461-00 ©2015 Caterpillar All rights reserved.







Pi cture shown may not reflect actual configuration

Full range of attachments

- Wide range of system expansion attachments, designed specifically to work with the EMCP 4
- Flexible packaging options for easy and cost effective installation

World wide product support

- Cat dealers provide extensive pre and post sale support
- Cat dealers have over 1,600 dealer branch stores operating in 200 countries

Features

- A 33 x 132 pixel, 3.8 inch, white backlit graphical display denotes text alarm/event descriptions, set points, engine and generator monitoring, and is visible in all lighting conditions.
- Textual display with support for 26 languages
- Advanced engine monitoring is available on systems with an ADEM[™] controller.
- Integration with the CDVR and IVR provides enhanced system performance
- Fully featured power metering, protective relaying, engine and generator parameter viewing, and expanded AC metering are all integrated into this controller.
- Real-time clock allows for date and time stamping of diagnostics and events in the control's logs as well as service maintenance reminders based on engine operating hours or calendar days. Up to 40 diagnostic events are stored in the non-volatile memory

EMCP 4.2B GENERATOR SET CONTROLLER

The Cat® EMCP 4.2B offers fully featured power metering, protective relaying and engine and generator control and monitoring. Engine and generator controls, diagnostics, and operating information are accessible via the control panel keypads; diagnostics from the EMCP 4 optional modules can be viewed and reset through the EMCP 4.2B.

Features

- Ability to view and reset diagnostics on EMCP 4 optional modules via the control panel removes the need for a separate service tool for troubleshooting
- Set points and software stored in non-volatile memory, preventing loss during a power outage
- Five levels of security allow for configurable operator privileges
- Programmable security levels for groups of setpoints.
- Programmable kW Relays (3)
- Programmable weekly exerciser timer
- Dealer configurable resistive maps
- Default overview screen
- Real (kW) Load histogram
- Auto mains failure
- Programmable logic functionality
- Selectable units
 - Temperature: °C or °F
 - o Pressure: psi, kPa, bar
 - Fuel Consumption: Liter/hr or Gal/hr (U.S. or U.K.)



Standard Features

- Voltage (L-L, L-N)
- Current (Phase)
- Average Volt, Amp, Frequency
- kW, kVAr, kVA (Average, Phase, %)
- Power Factor (Average, Phase)
- kW-hr, kVAr-hr (total)
- Excitation voltage and current (with CDVR)
- Desired Voltage, Excitation Command, Operating Mode (with IVR)
- Generator stator and bearing temp (with optional module)
- kW load histogram

Generator Protection

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under frequency (81 O/U)
- Reverse Power (kW) (32)
- Reverse Reactive Power (kVAr) (32RV)
- Overcurrent (50/51)
- Thermal Damage Curve

Engine Monitoring

- Coolant temperature
- Oil pressure
- Engine speed (RPM)
- Battery voltage
- Run hours
- Crank attempt and successful start counter
- Enhanced engine monitoring (with electronic engines)

Engine Protection

- Control switch not in auto (alarm)
- High coolant temp (alarm and shutdown)
- Low coolant temp (alarm)
- Low coolant level (alarm)
- High engine oil temp (alarm and shutdown)
- Low, high, and weak battery voltage
- Overspeed
- Overcrank
- Low Oil Pressure

Control

- Run / Auto / Stop control
- Speed and voltage adjust
- Local and remote emergency stop
- Remote start/stop
- Cycle crank

Inputs & Outputs

- Two dedicated digital inputs
- Three analog inputs
- Six programmable digital inputs
- Eight relay out
- Two programmable digital outputs

Communications

- Primary and accessory CAN data links
- RS-485 annunciator data link
- Modbus RTU (RS-485 Half duplex)

Language Support

Arabic, Bulgarian, Czech, Chinese, Danish, Dutch, English, Estonian, Finnish, French, German, Greek, Hungarian, Italian, Icelandic, Japanese, Latvian, Lithuanian, Norwegian, Polish, Portuguese, Romanian, Russian, Spanish, Swedish, Turkish

Environmental

- Control module operating temperature: -40°C to 70°C
- Display operating temperature: -20°C to 70°C
- Humidity: 100% condensing 30°C to 60°C
- Storage temperature: -40°C to 85°C
- Vibration: Random profile, 24-1000 Hz, 4.3G rms

Standards

- UL Recognized
- CSA C22.2 No.100,14, 94
- Complies with all necessary standards for CE Certification
 - 98/37/EC Machinery Directive
 - BS EN 60204-1 Safety of Machinery 89/336/EEC EMC Directive
 - BS EN 50081-1 Emissions Standard
 - BS EN 50082-2 Immunity Standard
 - 73/23/EEC Low Voltage Directive
 EN 50178 LVD Standard
 - EN 50178 LVD Standard
- IEC529, IEC60034-5, IEC61131-3
- MIL STND 461



Optional Modules

RS-485 annunciator

192		
CAT		
00		
and Or	••	
miner DL		
-0-		
- +5		
man A		
and and the		
sector into		
reason Fise		
erune bu		
martine [2]	((α)
man 1		

The EMCP 4 RS-485 Annunciator serves to display generator set system alarm conditions and status indications. The annunciator has been designed for use on the long distance annunciator datalink and is used for remote (up to 4000 feet) application.

The remote monitoring software allows the user to configure data monitoring and data acquisition processes for monitoring, graphing, and logging of generator set data.

Remote monitoring software



The EMCP remote monitoring software package is a PC based program which allows the user to monitor and control a generator set, and is capable of running on a Windows based operating system. The remote monitoring software allows the user to configure data monitoring and data acquisition processes for monitoring, graphing, and logging of generator set data.

Programmable logic software



The EMCP programmable logic software package is a PC based program which allows the configuration of the programmable logic blocks, and is capable of running on a Windows based operating system. The programmable logic software allows the user to configure logic to change the operation of the EMCP control and interfaces within a limited scope.



Optional Modules (Continued)

Digital input/output module



The Digital Input/Output (DI/O) module serves to provide expandable Input and Output event capability of the EMCP 4 and is capable of reading 12 digital inputs and setting 8 relay outputs.

The DI/O module has been designed for use on the accessory Communication Network and may be used in either local (package mounted) or remote (up to 800 feet) application.

> Materials and specifications are subject to change without notice. CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

> > cat.com/powergeneration ©2018 Caterpillar All rights reserved.



INTEGRATED VOLTAGE REGULATOR

The Integrated Voltage Regulator (IVR) is designed to provide robust, precise closed-loop control of the generator voltage, optimized transient performance and industry leading feature specification.

Caterpillar is leading the power generation marketplace with power solutions engineered to deliver unmatched flexibility, expandability, reliability and cost-effectiveness.

WORLDWIDE PRODUCT SUPPORT

- Worldwide parts availability through the Cat dealer network
- Over 1,800 dealer branch stores operating in 200 countries
- · The best product support record in the industry
- Cat dealers provide extensive post sale support including maintenance and repair agreements

COMPLETE SYSTEM INTEGRATION

Fully designed and factory tested to work seamlessly with Cat generators using Self Excitation (SE), Internal Excitation (IE) or Permanent Magnet (PMG) excitation systems and EMCP controls.

FEATURES

When used with an Excitation Module, EMCP 4.3/4.4 and IVR-compatible EMCP 4.1/4.2 (B) controllers offers:

- Automatic Voltage Regulation (AVR)
- Programmable stability settings
- Soft start control with an adjustable time setting in AVR control mode
- Dual Slope, Configurable Under Frequency (Volts/Hz) regulation
- Three-phase or single-phase generator voltage (RMS) sensing/regulation in AVR mode
- Setpoint adjustment from the EMCP display or Cat ET ServiceTool
- IVR Operating Status and Voltage Bias Overview screens to provide an enhanced level of user interface
- Integrated Voltage Regulator event monitoring

EMCP 4.3/4.4 and IVR-compatible EMCP 4.2 (B) controllers also offer:

- Power Factor Regulation (PF)
- Reactive Droop compensation
- Line drop compensation



INTEGRATED VOLTAGE REGULATOR FEATURE SPECIFICATION

		EMCP 4.2(B)		
SPECIFICATIONS				
No Load to Full Load Regulation	+0.5%	+0.25%	+0.25%	+0.25%
Configurable Volts / Hz Characteristic	•	•	•	•
Configurable Knee Frequency	•	•	•	•
Regulator ResponseTime	10 ms	10 ms	5 ms	5 ms
Single and Three Phase Sensing	•	•	•	•
Voltage Adjustment Range	± 30%	± 30%	± 30%	± 30%
CONTROL				
Characteristic	•	•	•	•
Excitation Enable Disable Selection	•	•	•	•
Line Loss (1 ² R) Compensation	_	•	•	•
Reactive Droop Compensation	_	•	•	•
Power Factor Control Mode		•	•	•
PROTECTION I ALARMS				
Generator Overvoltage	•	•	•	•
Generator Under voltage	•	•	•	•
Over Excitation	•	•	•	•
Loss of Sensing	•	•	•	•
Generator Reverse VARs	_	•	•	•
Event Log	•	•	•	•
METERING	1	1	1	
EMCP AC Metering	•	•	•	•
EMCP Power Metering	_	•	•	•
Excitation Command Percentage	•	•	•	•
Operating Mode Status Indication	•	•	•	•
VOLTAGE ADJUSTMENT	1	1	1	1
EMCP 4 Display Voltage Bias	•	•	•	•
Digital Input (Raise I Lower) Voltage Bias ¹	•	•	•	•
Potentiometer Voltage Bias ¹	•	•	•	•
Analog Voltage Bias -Voltage Range ¹	OV to SV	OV to SV	-10V to +10V	-10V to +10V
Analog Voltage Bias - Current Range ¹	-	-	0mA to 20mA	0mA to 20mA
Analog Voltage Bias - PWM Range ¹	-	-	0% to 100%	0% to 100%
SCADA (Modbus) Voltage Bias	-	•	•	•

¹Requires an available input on the EMCP 4.



EXCITATION MODULE SPECIFICATION

The Integrated Voltage Regulator consists of an EMCP 4 interfacing with an Excitation Module. There are a range of Excitation Modules available to match Cat generator sets.



Figure 3: EM25 Excitation Module

EXCITATION MODULE TECHNICAL SPECIFICATION

	EM10	EM15	EM25			
Compatible Generator Excitation Types	Self Excitation (SE)					
	Internal Excitation (IE)					
	Permanent Magnet (PMG)					
Nominal Field Current Output	6 Amps	7 Amps	13 AMPS			
Maximum (forcing) Field Current Output	10 Amps	15 Amps	25 AMPS			
Maximum AC Voltage Input	180Vrms	240Vrms	270 Vrms			

For more information on the Excitation Module refer to the component spec sheet.



EMCP 4 DISPLAY

EXAMPLE SCREENS - EMCP 4.1/4.2



Figure 4: Voltage Bias Overview Screens

EXAMPLE SCREENS - EMCP 4.3/4.4

IVR OVER	VIEW						
OPERATING MODE:							
	4.5%						
	VIAND						
COMPENS	DROOP						
GENSET			PAGE DOWN				

Figure 5: IVR Overview Screen

VOLTAGE BIAS OVERVIEW						
ACTIVE VOLTAGE BIASING:						
MANUAL 10.0%						
ANALOG INPUT 2.0%						
DROOP - 2.0%						
TOTAL BIAS 10.0%						
GENSET		PAGE UP				

Figure 6: Voltage Bias Overview Screen

BUILT FOR IT.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

www.Cat.com/electricpower

"Control Caterpillar. All rights reserved. Materials and specifications are subject to change without notice. CAT, CATERPILLAR, their respective logos, ADEM, S+0+S, BUILT FOR IT, "Caterpillar Yellow", the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.





Excitation Module EM25

Picture shown may not reflect actual configuration

The EM25 Excitation Module is a power electronics component designed to provide excitation current to the generator that is controlled by the Integrated Voltage Regulator (IVR) feature in the EMCP 4 controls.

Features

- Over-excitation protection limit can be adjusted via a potentiometer (IEXC.)
- Green status LED indicating unit is powered on
- Red status LED indicating excitation current limiting (flashing) or shutdown (solid)

When used with EMCP 4.2B/4.3/4.4 and IVRcompatible EMCP 4.1/4.2 controllers, the Integrated Voltage Regulator system offers:

- Automatic Voltage Regulation (AVR)
- Programmable stability settings
- Soft start control with an adjustable time setting in AVR control mode
- Dual Slope Under Frequency (Volts / Hz)
 regulation
- Three-phase or single-phase generator voltage (RSM) sensing/regulation in AVR mode

EMCP 4.2B/4.3/4.4 and IVR-compatible EMCP 4.1/4.2 controllers also offer:

- Power Factor Regulation (PF)
- Generator paralleling with reactive droop compensation.
- Line drop compensation.

Complete System Integration

Fully designed and factory tested to work seamlessly with Cat generators using Self Excitation (SE), Internal Excitation (IE) or Permanent Magnet (PMG) excitation systems and EMCP controls.

Worldwide Product Support

- Worldwide parts availability
- Over 1,800 dealer branch stores operating in 200 countries
- The best product support record in the industry
- Cat dealers provide extensive post sale support including maintenance and repair agreements.



Specifications

Electrical	
Generator Excitation Types	Self Excitation / Internal Excitation / Permanent Magnet (PMG)
Max. Continuous Field Current Output	13 Amps
Max. Forcing Field Current Output	25 Amps
Max. AC Voltage Input (X1:X2, Z1:Z2)	270 Vrms
Environmental	
Operating Temperature Range	−40 °C (−40 °F) to +70 °C (+158 °F)
Storage Temperature Range	−40 °C (−40 °F) to +85 °C (+185 °F)
Relative Humidity Tolerance	95% non-condensing humidity
Salt Spray	5% salt (NaCl) solution for 120 hrs
Vibration	4.5 G-rms, 24-2000 Hz in 3 orthogonal planes
Electromagnetic Compatibility	RF Immunity (Radiated & Conducted) RF Emissions (Radiated & Conducted) Electrical Transients
Weight	900 g ± 100 g
Power Consumption (at Max. Continuous Rating)	<900 VA
Conformity	
UL	UL Recognized (U.S. and Canada) File No. E334232
CE Integration Certificate	In conformity with the applicable requirements of the following Standards: EN 50178 EN 60204-1 EN 61000-6-2 EN 61000-6-4



Over- Excitation Protection

- If a short-circuit fault occurs at the generator terminals, the EM25 will allow the excitation current to rise to the upper limit value set by the adjustment potentiometer (max. 25 Amps.)
- The excitation current will be clamped at the upper limit value for 10 seconds (fixed internally).
- After 10 seconds, the excitation current is reduced to a value of 10% of the potentiometer setting.





Outline Drawing

(Dimensions in mm)



ATTACHMENTS



Example Connection Diagram (Permanent Magnet Excitation)



3-way Connector Functions

Terminal	Label	Function
P3-1	Shield	Excitation Command Shield
P3-2	CS+	Excitation Command Positive Input
P3-3	20	Evolution Command Negative Input

4-way Connector Functions (PMG Excitation):

Terminal	Label	Function
P4-1	X2	Excitation Power Supply Input (PMG Phase B)
P4-2	Z1	Not Connected
P4-3	X1	Excitation Power Supply Input (PMG Phase A)
P4-4	Z2	Excitation Power Supply Input (PMG Phase C)

(1) External fuses required with EM25 module

(2) Recommend 600V, 15A fast acting fuses (KTK-15)

4-way Connector Functions (Self-Excitation):

Terminal	Label	Function
P4-1	X2	Excitation Power Supply Input (single-phase)
P4-2	Z1	NotConnected
P4-3	X1	Excitation Power Supply In put (single-phase)
P4-4	Z2	NotConnected

4-way Connector Functions (Internal Excitation):

Terminal	Label	Function
P4-1	X2	Excitation Power Supply Input (Aux Winding 1 - Positive)
P4-2	Z1	Excitation Power Supply Input (Aux Winding 2 - Positive)
P4-3	X1	Excitation Power Supply Input (Aux Winding 1 - Negative)
P4-4	Z2	Excitation Power Supply Input (Aux Winding 2 - Negative)

Materials and specifications are subject to change without notice.

CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

(This Page Intentionally Left Blank)





Molded Case and Insulated Case Circuit Breakers: C27-C175 North America built packages (50/60Hz)

> NW-Frame 1200-5000A (UL),

Picture shown may not reflect actual configuration

Features

- Moisture and fungus protection
- Clear indication of breaker status
- Reinforced insulation
- Shunt trip
- Auxiliary contacts
- Load side extension bars
- Maintenance-free operation
- Exceptional characteristics under short-circuit conditions
- Adjustable trip settings

Conformity with International Standards

Circuit Breakers have been designed to comply with the international standard IEC 60947-2 as well as these other major standards:

NW-Frame

UL 489 NEMA AB1 CSA 22.2 No. 5096 NMX J-266-ANCE ANSI C37.13, C37.16, C37.17, C37.50 UL 1066 (cULus Listed) NEMA SG3



Standard Features

Standards

- UL-CSA
 - o L-Frame
 - o P-Frame
 - o R-Frame
 - o NW-Frame
- IEC
 - NS-Frame

Shunt trip

- The shunt trip provides a means of tripping the circuit breaker electronically
- Shunt trip ratings
- Voltage: 24VDC
- Coil Burden (Holding/Inrush): 4.5/200 VA
- Power Consumption: 4.5 VA

Auxiliary contacts

The auxiliary contacts provide a means of remote circuit breaker position indication and consists of (1) Form C Contact (1 Normally open and 1 Normally closed contact) with the following current ratings: 6A @ 240-480 VAC, 50/60Hz

Trip units

All circuit breakers come equipped with True RMS Current Sensing.

The trip units for each of the circuit breaker ratings sample the current waveform to provide true RMS protection through the 15th harmonic. This true RMS sensing gives accurate values for the magnitude of a nonsinusoidal waveform. Therefore, the heating effects of harmonically distorted waveforms are accurately evaluated. The trip system comes equipped with a set of current transformers (CT's) to sense current, a trip unit to evaluate the current, and a tripping solenoid to trip the circuit breaker. Additionally, each trip unit comes equipped with Active Thermal Imaging which is active 20 minutes before and after tripping.

Customer cable connections

Connections include bus for installation flexibility.

Optional Features

Electrically-operated Circuit Breakers

Circuit breakers that are electrically-operated come with a two-step stored energy mechanism and come standard with a motor assembly. Motor assemblies provide on and off control from remote locations.

These assemblies contain a spring-charging motor, a shunt trip, and shunt close. Motor Assembly Voltage Rating: 24-30VDC

Undervoltage trip

Undervoltage trip option trips the circuit breaker when the voltage drops to a value between 35% and 70% of the control voltage.

An attempt to close the circuit breaker when the UV is not energized produces no movement in the main contacts.

Closing is allowed when the supply voltage of the UV trip reaches 85% of the rated voltage.

- Voltage Rating: 24-30VAC/VDC
- Operating Threshold:
 - Opening: 0.35 to 0.7Vn
 Closing: 0.85 Vn
- Power Consumption: 4.5VA
- Circuit Breaker Response Time at Vn: 50ms +/- 10



Circuit Breakers Table (Continued)

Cat Part Number	Frame and Rating (Amps)	IEC/UL	No. Poles	Operation	Trip Unit	Circuit Breaker Characteristics	Options	Instantaneous Override (kA RMS) +/- 10%
								-
								-
								-
								-
2449913	4000A NW-Frame ICCB	UL	6P	EO	6.0P LSIG-P	Table 8	4 Aux Contact, Shunt Trip, Modbus	170



Circuit Breakers Characteristics (Continued)



Table 8



P, R, NS-Frame Long-Short Trip Curve and NW-Frame Long-Short Trip Curve



Long-time Pickup and Delay Short-time Pickup and I²t OFF Delay

The time-current curve information is to be used for application and coordination purposes only. Curves apply from -30°C to +60°C ambient temperature.

Notes:

1. There is a thermal-imaging effect that can act to shorten the long-time delay. The thermalimaging effect comes into play if a current above the long-time delay pickup value exists for a time and then is cleared by the tripping of a downstream device or the circuit breaker itself. A subsequent overload will cause the circuit breaker to trip in a shorter time than normal. The amount of time delay reduction is inverse to the amount of time that has elapsed since the previous overload. Approximately 20 minutes is required between overloads to completely reset thermalimaging.

2. The end of the curve is determined by the interrupting rating of the circuit breaker.

3. With zone-selective interlocking on, short-time delay utilized and no restraining signal, the maximum unrestrained short-time delay time band applies regardless of the setting.

4. Total clearing times shown include the response times of the trip unit, the circuit breaker opening, and the extinction of the current.

5. For a withstand circuit breaker, instantaneous can be turned OFF. See Page 22 for instantaneous trip curve. See tables on pages 03-18 for instantaneous override values..

6. Overload indicator illuminates at 100%.



P, R, NS-Frame Instant Curve and NW-Frame Instant Trip Curve



MULTIPLES OF SENSOR RATING (In)

Instantaneous Pickup 2x-15x and OFF

The time-current curve information is to be used for application and coordination purposes only.

Curves apply from -30° to +60°C ambient temperature.

Notes:

1. The end of the curve is determined by the interrupting rating of the circuit breaker.

2. Total clearing times shown include the response times of the trip unit, the circuit breaker opening, and the extinction of the current.

3. The instantaneous region of the trip curve shows maximum total clearing times. Actual clearing times in this region can vary depending on the circuit breaker mechanism design and other factors. The actual clearing time can be considerably faster than indicated. Contact your local Sales Office for additional information.

4. For a withstand circuit breaker, instantaneous can be turned OFF. See tables on pages 03-18 for instantaneous override values.

5. See page 22 for long-time pickup, long-time delay, short-time pickup, and short time delay trip curves.

TIME IN SECONDS



P, R, NS-Frame Gound Curve and NW-Frame Ground Fault Trip Curve



Ground-fault I²t OFF and ON In ≤ 400 A

The time-current curve information is to be used for application and coordination purposes only.

Curves apply from -30°C to +60°C ambient temperature.

Materials and specifications are subject to change without notice.

CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

©2018 Caterpillar cat.com/powergeneration All rights reserved.

(This Page Intentionally Left Blank)





Features

- Electronically current limited at 105% of rated output
- Alarm system
- Digital Display
- Lightning and voltage transient protection
- Protection of connected equipment against load dump
- Constant voltage, current limited, 4-rate automatic equalization
- IP 20 housing
- Temperature Compensation
- On board temperature sensor with remote port
- AC isolated from DC
- Auto AC line compensation
- Output regulated by sensed battery voltage

Dimensions							
Width	Depth	Height	Weight				
354 mm (13.93 in)	173 mm (6.83 in)	332 mm (13.06 in)	19.1 kg (42 lb)				

UL 20 Amp Battery Charger

This battery charger offers accurate, automatic charging of lead-acid and nickel cadmium batteries. The output voltage automatically adjusts to changing input, load, battery and ambient conditions. This prevents battery over-charging and consequent loss of battery electrolyte.

Standard features include AC line compensation, precision voltage regulation, current limiting, automatic 2-rate charging, voltmeter and ammeter, temperature compensation and UL Listing.

The user interface is easy to understand with digital metering, NFPA 110 alarms and a battery fault alarm.

Specification

Input supply	110 – 120 V 208 – 240V
AC and DC fuses	(2 input and 2 output)
Output voltage	24V
Output amps	20A
Input Frequency	50 / 60 Hz
Operating temperature	−20°C(−4°F) to +60°C(140°F)

Housing constructed of rustproof anodized aluminum.

Standards

- C-UL listed to UL 1236
- NFPA 70, NFPA 110
- CSA 22.2 No 107 certified
- UL 1564
- CE DOC to EN 60335
- IBC Seismic Certification

Feature code: BTC 20A2



NFPA 110 alarm package as follows:

- AC on Green led (indication)
- AC fail Red led and form C contact (2A)
- Float mode LED LED
- Fast charge LED
- Temp comp active
- Low battery volts Red LED and Form C contact
- High battery volts Red LED and Form C contact
- Charger fail Red LED and Form C contact
- Battery fault Red LED and Form C contact - Battery disconnected
 - Battery polarity reversed
 - Mismatched charger battery voltage
 - Open or high resistance charger to battery connection
 - Open battery cell or excessive internal resistance

Information contained in this publication may be considered confidential. Discretion is recommended when distributing. Materials and specifications are subject to change without notice.

CAT, CATERPILLAR, LET'S DO THE WORK, their respective logos, "Caterpillar Yellow," the "Power Edge" and Cat "Modern Hex" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.





Picture shown may not reflect actual configuration

Electric Starting Motor

for C27, C32, 3512, 3516, C175-16 and C175-20

U.S. Sourced

Electric Starting Motors are used for improved engine start capability. Battery-powered electric motors utilize low voltage direct current and provide fast, convenient, pushbutton starting with lightweight, compact, engine-mounted components.

Design

- Splash-proof and environmentally protected.
- Seamless one-piece solenoid case is sealed for corrosion protection.
- Positive-engagement shift mechanism assures pinion-to-ring gear engagement prior to cranking, minimizing milled ring gears and pinions.
- Epoxy impregnation and glass banding give starter armature exceptional rotation strength.
- Positive spring retention in the six wide, onepiece brushes gives uniform pressure and brush wear for extended service life.
- Extra-large brush leads are used to handle the high current experienced during the cranking of high-power diesel engines.
- Rotatable drive housing, with 12 positions, allows easy repositioning of the solenoid switch.
- Totally Enclosed Shift mechanism.
- Bearing Lubrication and Sealing: Three sintered-bronze bearing extra-large oil reservoirs.

Specifications

- System Voltage: 24 V
- Rotation: Clockwise
- Polarity: Insulated
- Mounting: SAE #3
- Pinion Data:
 - No Teeth/Pinion Blank: 11/12
 Pitch: 6/8
- Output: 24V: 9.0 kW
- Weight: 34 kg (75 lbs)
- Operation temperature range
 25°C to +121°C
- Pressure Angle: 20°
- Oil Sealed: ± 6 PSI
- Water Sealed: ± 6 PSI and 3500 PSI Pressure Wash

Option

 Heavy-Duty Applications: Two or more units can be tandem-mounted for starting large engines.





Available Options

	Model	Single	Dual	Quadruple
	C27		+	
	C32		+	
	3512	+	+	
	3512B	+	+	
	3512C	+	+	
	3516		+	
	3516B		+	
\geq	3516C		+	
	C175-16		+	+
	C175-20		+	+

Dimensions Drawing





Materials and specifications are subject to change without notice. CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

> cat.com/electricpower ©2017 Caterpillar All rights reserved.





JACKET WATER HEATER With Pump

3516

Picture shown may not reflect actual configuration

Caterpillar offers a factory-installed jacket water heater for improved cold-starting capability.

The Jacket Water Heater with the pump is a complete coolant preheater with thermostat, pump and all required controls.

Forced circulation of the coolant delivers uniform heating throughout the entire engine, extends element life and offers a significant reduction in electrical consumption.

The Jacket Water Heater operates automatically when provided contacts are supplied with a 24 Volt DC signal from the engine.

FEATURES

- Factory Installed
- Complete with hoses, thermostat and pump
- Base frame mounting minimizes engine induced vibration
- Automatically disconnected when engine is running via the generator space heater relay
- Supplied with UL recognized components
- Thermostat is factory pre-set to 54°C (130°F)

HEATER DESIGN DESCRIPTION

The jacket water heater package is designed to efficiently pre-heat the engine by heating and circulating the engine's coolant.

This design results in the following benefits

- Increase life of heater hoses, engine seals, • and heating elements.
- Improve heat transfer efficiency from elements to engine coolant.
- More uniform engine temperature distribution. •
- Application of a thermostat with a reduced thermal differential.
- Lower customer utility costs and increased heater reliability.
- Heater thermostat's setpoint is preset from the factory.

HEATER OPERATION/WIRING

A 38 L/pm (10 gpm) pump is located at the heater outlet to pull the coolant through the heater. A fixed thermostat is located inside Element enclosure box, near the outlet of Heater and responds to the temperature of the coolant inside the tank. The figure below shows the general design.



- B. Pump/motor
- F. Element assembly
- G. Thermostat
- D. Power and control wiring entrance

C. Suction (behind unit)



SPECIFICATIONS

	Voltage			
	480			
Rating	9 kW			
Frequency	60			
Phase	Three phase			
Amps	11			
Flow Rate	38 L/pm (10 gmp)			
Pump Rating	97W			
Fixed Thermostat	38°C - 54°C (100°F - 130°F)			
Length	533.7 mm (21")			
Width	307.56 mm (12.1")			
Height	325.8 mm (12.8")			
Weight	25.76 kg (56.8 lbs)			







Wiring Diagram - 480 V JWH



Materials and specifications are subject to change without notice. CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

(This Page Intentionally Left Blank)




Primary Fuel Filter with water separator

3516C*

* excluding 3516C EPA Tier 2 (2750 ekW)

Picture shown may not reflect actual configuration

General Description

Fuel contamination, either in the form of dirt or water, will find its way into your fuel system no matter how careful you are. Even a small amount of dirt or water corrosion can start problems. Water or particulates can cause microscopic surface damage that is then focused on by the high-pressure fuel flow, which causes wear that will eventually lead to reduced efficiency and complete breakdown.

Using fuel filter with water separator you will achieve system cleanliness for reliable engine operation.

Features

- The high-grade aluminum components and powdercoat paints mean that corrosion is never a worry.
- A durable single bolt mounting bracket doubles resistance to vibration fatigue.
- Sheds water and keeps engines waterproof, rustproof and dirtproof.
- Polymer bowl withstands impact and temperature extremes.
- Self-venting drain. A single twist makes draining clean, fast and easy.
- Unique media to increase dirt holding capacity and extend filter life
- Treated media that separates and coalesces water from fuel

Specifications

- Filtration Rating: 30 micron
- Two filters on-line
- Ports: 3/4"-14 NPT
- Maximum Pressure: 1.03 bar (15 psi)
- Max Flow Rate: 1362 lph (360 gph)
- Height: 545.3 mm (21.47")
- Width: 419.1 mm (16.5") with Bracket
- Depth: 304.8 mm (12.0") with Bracket
- Weight: 11.8 kg (26.0 lbs)

Filter Element Specifications

- Effective media area: 9980 cm²
- Weight: 0.59 kg (1.3 Lbs.)
- Length: 213 mm (8.38")
- Diameter 109 mm (4.29")



General Dimensions Drawing



Materials and specifications are subject to change without notice. CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.



TECHNICAL DATA



(This Page Intentionally Left Blank)



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY 2019 MODEL YEAR CERTIFICATE OF CONFORMITY WITH THE CLEAN AIR ACT

OFFICE OF TRANSPORTATION AND AIR QUALITY ANN ARBOR, MICHIGAN 48105

Certificate Issued To: Caterpillar Inc. (U.S. Manufacturer or Importer) Certificate Number: KCPXL78.1NZS-014	Effective Date: 07/24/2018 Expiration Date: 12/31/2019	Byron J. Bunker, Division Director Compliance Division	Issue Date: 07/24/2018 Revision Date: N/A
Model Year: 2019 Manufacturer Type: Original Engine Manufacturer Engine Family: KCPXL78.1NZS	Mob Emis Fuel After Non-	ile/Stationary Indicator: Stationary sions Power Category: kW>560 Type: Diesel • Treatment Devices: No After Treatment Devices Installed after Treatment Devices: Electronic Control, Engine Design Modifica	ation

Pursuant to Section 111 and Section 213 of the Clean Air Act (42 U.S.C. sections 7411 and 7547) and 40 CFR Part 60, and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following engines, by engine family, more fully described in the documentation required by 40 CFR Part 60 and produced in the stated model year.

This certificate of conformity covers only those new compression-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 60 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 60.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 60. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 60.

the set

AL PROT

This certificate does not cover engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.

(This Page Intentionally Left Blank)

TIER 2 PERFORMANCE DATA

PERFORMANCE DATA[EM1895]

September 18, 2019

Change Level: 04

Performance Number: EM1895

SALES MODEL: BRAND: ENGINE POWER (BHP): GEN POWER (BHP): COMPRESSION RATIO: RATING LEVEL: PUMP QUANTITY: FUEL TYPE: MANIFOLD TYPE: GOVERNOR TYPE: ELECTRONICS TYPE: CAMSHAFT TYPE: IGNITION TYPE: INJECTOR TYPE: FUEL INJECTOR: UNIT INJECTOR:	3516C CAT 3,634 2,500.0 14.7 MISSION CRITICAL STANDBY 1 DIESEL DRY ADEM3 ADEM3 ADEM3 STANDARD CI EUI 3920221 64.34	COMBUSTION: ENGINE SPEED (RPM): HERTZ: FAN POWER (HP): ASPIRATION: AFTERCOOLER TYPE: AFTERCOOLER CIRCUIT TYPE: INLET MANIFOLD AIR TEMP (F): JACKET WATER TEMP (F): TURBO CONFIGURATION: TURBO CONFIGURATION: TURBO CONFIGURATION: TURBO CONFIGURATION: TURBO CHARGER MODEL: CERTIFICATION YEAR: CRANKCASE BLOWBY RATE (FT3/HR): FUEL RATE (RATED RPM) NO LOAD (GAL/HR): PISTON SPD @ RATED ENG SPD (FT/MIN):	DIRECT INJECTION 1,800 60 130.1 TA ATAAC JW+OC, ATAAC 122 210.2 PARALLEL 4 GT6041BN-48T-1.10 2006 3,619.4 16.2 2,539.4
UNIT INJECTOR TIMING (IN): REF EXH STACK DIAMETER (IN): MAX OPERATING ALTITUDE (FT):	64.34 12 2,953	PISTON SPD @ RATED ENG SPD (FT/MIN):	2,539.4

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET
OIL AND GAS	LAND PRODUCTION	PACKAGED GENSET

General Performance Data

THIS STANDBY RATING IS FOR A STANDBY ONLY ENGINE ARRANGEMENT. RERATING THE ENGINE TO A PRIME OR CONTINUOUS RATING IS NOT PERMITTED.

THE INLET MANIFOLD AIR TEMP LISTED IN THE HEADER, AND IN THE GENERAL PERFORMANCE DATA, IS THE AVERAGE INLET MANIFOLD TEMP FRONT TO REAR ON THE ENGINE.

GENSET	PERCENT	ENGINE	BRAKE MEAN	BRAKE SPEC	VOL FUEL	INLET MFLD	INLET MFLD	EXH MFLD	EXH MFLD	ENGINE
POWER WITH	LOAD	POWER	EFF PRES	FUEL	CONSUMPTN	PRES	TEMP	TEMP	PRES	OUTLET TEMP
FAN			(BMEP)	CONSUMPTN	(VFC)					
				(BSFC)						
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
2,500.0	100	3,633	336	0.334	173.5	78.1	121.9	1,235.6	67.6	915.2
2,250.0	90	3,283	303	0.335	157.1	71.3	119.4	1,190.0	61.3	881.2
2,000.0	80	2,935	271	0.339	142.3	64.3	116.9	1,158.9	55.3	864.0
1,875.0	75	2,760	255	0.342	134.9	60.7	115.8	1,145.6	52.3	858.5
1,750.0	70	2,586	239	0.346	127.6	57.0	114.7	1,133.3	49.3	854.6
1,500.0	60	2,237	207	0.354	113.0	49.5	112.7	1,112.4	43.2	851.2
1,250.0	50	1,889	174	0.365	98.4	41.3	111.0	1,091.8	36.8	850.7
1,000.0	40	1,547	143	0.373	82.5	31.4	109.4	1,061.5	29.3	856.6
750.0	30	1,203	111	0.385	66.2	21.7	107.9	1,010.3	22.1	848.2
625.0	25	1,029	95	0.394	57.9	17.2	107.2	968.3	18.7	831.1
500.0	20	854	79	0.403	49.2	12.7	106.4	902.0	15.5	796.1
250.0	10	497	46	0.441	31.3	4.8	104.1	700.7	9.8	647.3

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
2,500.0	100	3,633	85	466.7	7,212.2	19,578.8	32,046.3	33,260.4	7,001.7	6,362.4
2,250.0	90	3,283	78	443.0	6,831.8	17,980.7	30,219.3	31,318.8	6,593.0	6,013.7
2,000.0	80	2,935	70	417.8	6,404.5	16,560.6	28,284.6	29,277.2	6,151.5	5,625.4
1,875.0	75	2,760	66	404.7	6,173.3	15,893.2	27,261.3	28,202.4	5,928.1	5,427.1
1,750.0	70	2,586	63	391.2	5,929.9	15,232.6	26,196.0	27,086.8	5,698.4	5,222.0
1,500.0	60	2,237	55	363.5	5,411.9	13,879.0	23,947.5	24,739.5	5,205.5	4,779.1
1,250.0	50	1,889	46	334.6	4,843.3	12,413.0	21,444.3	22,133.2	4,657.5	4,283.2
1,000.0	40	1,547	36	297.5	4,121.4	10,609.5	18,262.0	18,840.0	3,963.0	3,647.2
750.0	30	1,203	25	249.8	3,423.0	8,763.8	15,175.3	15,640.3	3,294.6	3,037.8
625.0	25	1,029	21	223.4	3,104.6	7,844.6	13,765.1	14,171.8	2,988.1	2,760.8
500.0	20	854	16	197.2	2,791.2	6,823.5	12,376.2	12,722.2	2,671.7	2,476.1
250.0	10	497	7	152.3	2,237.9	4,800.2	9,917.6	10,136.8	2,132.0	1,999.8

PERFORMANCE DATA[EM1895]

Heat Rejection Data

GENSET	PERCENT	ENGINE	REJECTION	REJECTION	REJECTION	EXHUAST	FROM OIL	FROM	WORK	LOW HEAT	HIGH HEAT
POWER WITH	LOAD	POWER	TO JACKET	то	TO EXH	RECOVERY	COOLER	AFTERCOOLE	RENERGY	VALUE	VALUE
FAN			WATER	ATMOSPHERE		TO 350F				ENERGY	ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
2,500.0	100	3,633	46,992	9,146	142,265	79,907	19,835	44,723	154,077	372,403	396,702
2,250.0	90	3,283	44,242	8,557	127,929	70,449	17,960	39,380	139,243	337,204	359,207
2,000.0	80	2,935	41,477	8,162	116,879	63,561	16,262	34,167	124,444	305,311	325,233
1,875.0	75	2,760	40,076	8,007	111,588	60,518	15,425	31,612	117,053	289,608	308,505
1,750.0	70	2,586	38,657	7,874	106,293	57,637	14,588	29,085	109,651	273,881	291,752
1,500.0	60	2,237	35,755	7,684	95,729	52,220	12,915	24,201	94,874	242,485	258,307
1,250.0	50	1,889	32,626	7,527	85,184	46,626	11,245	19,401	80,109	211,118	224,893
1,000.0	40	1,547	29,235	7,262	72,693	40,153	9,427	13,873	65,583	176,995	188,544
750.0	30	1,203	25,476	6,784	59,425	32,726	7,565	8,706	51,005	142,037	151,305
625.0	25	1,029	23,394	6,435	52,542	28,568	6,621	6,496	43,653	124,317	132,429
500.0	20	854	21,006	5,995	44,739	23,683	5,624	4,534	36,223	105,594	112,484
250.0	10	497	15,737	5,026	27,795	12,371	3,578	1,916	21,071	67,181	71,564

Sound Data

SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779.

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	2,500.0	1,875.0	1,250.0	625.0	250.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	3,633	2,760	1,889	1,029	497
TOTAL NOX (AS NO2)		G/HR	22,948	14,101	7,004	3,568	3,185
TOTAL CO		G/HR	2,726	1,304	1,092	1,496	2,098
TOTAL HC		G/HR	500	499	543	408	437
PART MATTER		G/HR	185.5	123.7	132.1	139.5	141.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,818.9	2,229.5	1,544.3	1,352.7	2,230.2
TOTAL CO	(CORR 5% O2)	MG/NM3	351.8	213.9	252.3	594.6	1,552.7
TOTAL HC	(CORR 5% O2)	MG/NM3	55.9	72.8	108.8	140.7	282.4
PART MATTER	(CORR 5% O2)	MG/NM3	19.7	16.5	25.8	48.5	88.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,373	1,086	752	659	1,086
TOTAL CO	(CORR 5% O2)	PPM	281	171	202	476	1,242
TOTAL HC	(CORR 5% O2)	PPM	104	136	203	263	527
TOTAL NOX (AS NO2)		G/HP-HR	6.38	5.15	3.74	3.50	6.47
TOTAL CO		G/HP-HR	0.76	0.48	0.58	1.47	4.26
TOTAL HC		G/HP-HR	0.14	0.18	0.29	0.40	0.89
PART MATTER		G/HP-HR	0.05	0.05	0.07	0.14	0.29
TOTAL NOX (AS NO2)		LB/HR	50.59	31.09	15.44	7.87	7.02
TOTAL CO		LB/HR	6.01	2.88	2.41	3.30	4.62
TOTAL HC		LB/HR	1.10	1.10	1.20	0.90	0.96
PART MATTER		LB/HR	0.41	0.27	0.29	0.31	0.31

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	2,500.0	1,875.0	1,250.0	625.0	250.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	3,633	2,760	1,889	1,029	497
TOTAL NOX (AS NO2)		G/HR	19,123	11,751	5,837	2,974	2,654
TOTAL CO		G/HR	1,515	725	607	831	1,165
TOTAL HC		G/HR	376	375	408	307	329
TOTAL CO2		KG/HR	1,740	1,340	966	559	296
PART MATTER		G/HR	132.5	88.4	94.3	99.6	100.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,349.1	1,857.9	1,286.9	1,127.3	1,858.5
TOTAL CO	(CORR 5% O2)	MG/NM3	195.4	118.8	140.1	330.3	862.6
TOTAL HC	(CORR 5% O2)	MG/NM3	42.1	54.8	81.8	105.8	212.3
PART MATTER	(CORR 5% O2)	MG/NM3	14.1	11.8	18.4	34.7	63.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,144	905	627	549	905

TIER 2 PERFORMANCE DATA

PERFORMANCE DATA[EM1895]

TOTAL CO	(CORR 5% O2)	PPM	156	95	112	264	690
TOTAL HC	(CORR 5% O2)	PPM	79	102	153	197	396
TOTAL NOX (AS NO2)		G/HP-HR	5.32	4.30	3.12	2.92	5.39
TOTAL CO		G/HP-HR	0.42	0.26	0.32	0.82	2.37
TOTAL HC		G/HP-HR	0.10	0.14	0.22	0.30	0.67
PART MATTER		G/HP-HR	0.04	0.03	0.05	0.10	0.20
TOTAL NOX (AS NO2)		LB/HR	42.16	25.91	12.87	6.56	5.85
TOTAL CO		LB/HR	3.34	1.60	1.34	1.83	2.57
TOTAL HC		LB/HR	0.83	0.83	0.90	0.68	0.72
TOTAL CO2		LB/HR	3,836	2,955	2,130	1,233	654
PART MATTER		LB/HR	0.29	0.19	0.21	0.22	0.22
OXYGEN IN EXH		%	9.4	10.4	11.3	12.2	14.4
DRY SMOKE OPACITY		%	1.7	1.4	1.9	2.5	3.8
BOSCH SMOKE NUMBER			0.58	0.49	0.62	0.92	1.27

Regulatory Information

EPA EMERGENCY STATI	ONARY	2011		
GASEOUS EMISSIONS DA	ATA MEASUREMENTS PROVIDED T	O THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 S	UBPART IIII AND ISO 8178 FOR MEASURING HC,
CO, PM, AND NOX. THE "I	MAX LIMITS" SHOWN BELOW ARE	VEIGHTED CYCLE AVERAGES AND ARE I	N COMPLIANCE WITH THE EMERGENCY S	STATIONARY REGULATIONS.
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 6.4 PM: 0.20

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	NORMAL	
ALTITUDE (FT)												
0	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	
1,000	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,561	3,634	
2,000	3,634	3,634	3,634	3,634	3,634	3,634	3,634	3,604	3,541	3,480	3,634	
3,000	3,628	3,628	3,628	3,628	3,628	3,603	3,537	3,474	3,413	3,354	3,628	
4,000	3,504	3,504	3,504	3,504	3,504	3,471	3,408	3,347	3,289	3,232	3,504	_
5,000	3,384	3,384	3,384	3,384	3,384	3,344	3,283	3,225	3,168	3,113	3,384	
6,000	3,269	3,269	3,269	3,269	3,269	3,221	3,162	3,105	3,051	2,998	3,269	
7,000	3,159	3,159	3,159	3,159	3,159	3,101	3,044	2,990	2,937	2,887	3,159	
8,000	3,052	3,052	3,052	3,052	3,041	2,985	2,930	2,878	2,827	2,779	3,052	_
9,000	2,950	2,950	2,950	2,950	2,926	2,872	2,820	2,769	2,721	2,674	2,950	
10,000	2,851	2,851	2,851	2,851	2,815	2,763	2,713	2,664	2,617	2,544	2,851	

Cross Reference

Test Spec	Setting	Engine Arrangement	Engineering Model	Engineering Model Version	Start Effective Serial Number	End Effective Serial Number
4577176	LL1858	5084280	GS336	-	SBK02483	
4581567	LL6760	5157721	PG243	-	LYM00001	

Supplementary Data

Туре	Classification	Performance Number
SOUND	SOUND PRESSURE	DM8779

PERFORMANCE DATA[EM1895]

Engine performance tolerance values below are representative of a

Parameters Reference:DM9600-11 PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

September 18, 2019

typical production engine tested in a calibrated dynamometer test cell at SAF J1995 standard reference conditions. Caternillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted. PERFORMANCE PARAMETER TOLERANCE FACTORS: Power +/- 3% Torque +/- 3% Exhaust stack temperature +/- 8% Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10% Exhaust flow +/- 6% Specific fuel consumption +/- 3% Fuel rate +/- 5% Specific DEF consumption +/- 3% DEF rate +/- 5% Heat rejection +/- 5% Heat rejection exhaust only +/- 10% Heat rejection CEM only +/- 10% Heat Rejection values based on using treated water. Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications. On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed. These values do not apply to C280/3600. For these models, see the tolerances listed below. C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5% TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque +/- 0.5% Speed +/- 0.2% . Fuel flow +/- 1.0% Temperature +/- 2.0 C degrees Intake manifold pressure +/- 0.1 kPa OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS REFERENCE ATMOSPHERIC INLET AIR FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature. MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions. REFERENCE EXHAUST STACK DIAMETER The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available. REFERENCE FUEL DIESEL Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 deg C (84.2 deg F), where the density is 838.9 G/Liter (7.001 Lbs/Gal). GAS Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

Page 4 of 5

PERFORMANCE DATA[EM1895]

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for

atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a

setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS 1. For constant-speed marine engines for ship main propulsion, including,diesel-electric drive, test cycle E2 shall be applied,

for controllable-pitch propeller sets

test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied.

Applied. 4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied. HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500 HIGH DISPLACEMENT (HD) DEFINITIONS: 3500: EM1500 RATING DEFINITIONS: Agriculture : TM6008 Fire Pump : TM6009

Generator Set : TM6035 Generator (Gas) : TM6041 Industrial Diesel : TM6010 Industrial (Gas) : TM6040 Irrigation : TM5749 Locomotive : TM6037 Marine Auxiliary : TM6036 Marine Prop (Except 3600) : TM5747 Marine Prop (3600 only) : TM5748 MSHA : TM6042 Oil Field (Petroleum) : TM6011 Off-Highway Truck : TM6039

On-Highway Truck : TM6038 SOUND DEFINITIONS: Sound Power : DM8702

Sound Pressure : TM7080

Date Released : 07/10/19

(This Page Intentionally Left Blank)

TIER 4 COMPLIANCE EMISSION DATA

3516C (EM1895)

Rated speed PSV: 1800 rpm

Genset Power (w/ fan)	ekW	2500	1875	1250	625	250
Engine Power	bhp	3633	2760	1889	1029	497
% Load	%	100	75	50	25	10
Volumetric Fuel Consumption	gal/hr	173.5	135	98	58	31
Wet Exhaust Mass Flow	lb/hr	33260	28202	22133	14172	10137
Volumetric Exhaust Flow (Wet)	cfm	19579	15893	12413	7845	4800
Exhaust Temperature	deg F	915	859	851	831	647
Total NOx (as NO2)	lb/hr	50.59	31.09	15.44	7.87	7.02
% Reduction	%	90	90	90	90	90
Post Catalyst NOx (as NO2)	lb/hr	5.06	3.11	1.54	0.79	0.70
Total CO	lb/hr	6.01	2.88	2.41	3.3	4.62
% Reduction	%	80	80	80	80	80
Post Catalyst CO	lb/hr	1.20	0.58	0.48	0.66	0.92
Total HC	lb/hr	1.1	1.1	1.2	0.9	0.96
% Reduction	%	80	80	80	80	80
Post Catalyst HC	lb/hr	0.22	0.22	0.24	0.18	0.19
Total PM	lb/hr	0.41	0.27	0.29	0.31	0.31
% Reduction	%	85	85	85	85	85
Post Catalyst PM	lb/hr	0.06	0.04	0.04	0.05	0.05

(This Page Intentionally Left Blank)

Systems Data Reference Number: EM1895

CATERPILLAR®

September 18, 2019 For Help Desk Phone Numbers <u>Click Here</u>

AIR INTAKE SYSTEM		
THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E	MISSIONS CERTIF	TED ENGINES
TO ASSURE REGULATORY COMPLIANCE.		1
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH CLEAN ELEMENT	15	IN-H20
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH DIRTY ELEMENT	25	IN-H20
MAXIMUM PRESSURE DROP FROM COMPRESSOR OUTLET TO MANIFOLD INLET (OR MIXER INLET FOR EGR)	5.9	IN-HG
MAXIMUM ALLOWABLE STATIC WEIGHT ON AIR INLET	101.4	LB
MAXIMUM ALLOWABLE STATIC WEIGHT ON AIR INLET (AIR SHUT OFF INCLUDED)	19.8	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON AIR INLET	11.8	LB-FT
MAXIMUM ALLOWABLE STATIC WEIGHT ON TURBO OUTLET CONNECTION	0	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON TURBO OUTLET CONNECTION	0	LB-FT
COOLING SYSTEM		
ENGINE ONLY COOLANT CAPACITY	61.6	GAL
MAXIMUM ALLOWABLE JACKET WATER OUTLET TEMPERATURE	210	DEG F
REGULATOR LOCATION FOR JW (HT) CIRCUIT	OUTLET	
MAXIMUM UNINTERRUPTED FILL RATE	5.0	G/MIN
ENGINE SPEC SYSTEM		
CYLINDER ARRANGEMENT	VEE	
NUMBER OF CYLINDERS	16	
CYLINDER BORE DIAMETER	6.7	IN
PISTON STROKE	8.5	IN
TOTAL CYLINDER DISPLACEMENT	4765	CU IN
STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END	CCW	
STANDARD CYLINDER FIRING ORDER	1-2-5-6-3-4- 9-10-15-16- 11-12-13- 14-7-8	
NUMBER 1 CYLINDER LOCATION	RIGHT FRONT	
STROKES/COMBUSTION CYCLE	4	
EXHAUST SYSTEM		
THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL ENTO ASSURE REGULATORY COMPLIANCE.	MISSIONS CERTIF	TED ENGINES
MAXIMUM ALLOWABLE SYSTEM BACK PRESSURE	27	IN-H20
MANIFOLD TYPE	DRY	
MAXIMUM ALLOWABLE STATIC WEIGHT ON EXHAUST CONNECTION	61.7	LB
MANUNA ALLOWARD F CTATES RENDERED MOMENT ON EVIDAUET		

FUEL SYSTEM

MAXIMUM FUEL FLOW FROM TRANSFER PUMP TO ENGINE	443.8	G/HR
MAXIMUM ALLOWABLE FUEL SUPPLY LINE RESTRICTION	8.9	IN-HG
MAXIMUM ALLOWABLE FUEL TEMPERATURE AT TRANSFER PUMP INLET	151	DEG F
MAXIMUM FUEL FLOW TO RETURN LINE FROM ENGINE	429.8	G/HR
MAXIMUM ALLOWABLE FUEL RETURN LINE RESTRICTION	8.0	IN-HG
NORMAL FUEL PRESSURE IN A CLEAN SYSTEM	60.2	PSI
FUEL SYSTEM TYPE	EUI	
MAXIMUM TRANSFER PUMP PRIMING LIFT WITHOUT PRIMING PUMP	12.1	FT
MAXIMUM HEAT REJECTION TO FUEL	722	BTU/MIN
LUBE SYSTEM		
CRANKCASE VENTILATION TYPE	TO ATM	
MOUNTING SYSTEM		
CENTER OF GRAVITY LOCATION - X DIMENSION - FROM REAR FACE OF BLOCK - (REFERENCE TM7077)	47.2	IN
CENTER OF GRAVITY LOCATION - Y DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)	8.0	IN
CENTER OF GRAVITY LOCATION - Z DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)	0.0	IN
MASS MOMENT OF INERTIA - X AXIS	10621	LB IN SEC2
MASS MOMENT OF INERTIA - Y AXIS	123910	LB IN SEC2
MASS MOMENT OF INERTIA - Z AXIS	132761	LB IN SEC2
STARTING SYSTEM		
MINIMUM CRANKING SPEED REQUIRED FOR START	120	RPM

TEST SPEC [LF3210]

SEPTEMBER 18, 2019

For Help Desk Phone Numbers Click here

Reference Number: 4581567

Make from Spec:

Effective Serial Number: LYM00128 V

Test Spec Data				
Description	Measure	Nominal	Ceiling	Floor
Corr Full Load Power 🮯	hp	3,701	3,775	3,627
Full Load Speed 🧐	RPM	1800	1810	1790
Governor Setting Speed	RPM			
High Idle Speed 🞯	RPM	1818	1836	1800
Low Idle Speed @	RPM	900	910	890
FL Static Fuel Setting 🞯	in	1.209		
Corrected Fuel Rate	GAL/HR	177.0	185.8	168.1
CSFC 🧐	LB/HP.H	0.338	0.357	0.320
Adjusted Boost 🥝	IN_HG	80.0	92.0	68.0
Torque Check Speed 🔞	RPM			
Corr Torg Rise at TC RDM (9)	%			
	GAL/HR			
CSFC at TC RPM S				
ADJ Boost at TC RPM 🤎				
Power Loss/Cyl 🧐	% C FL PWR			
Specific Blowby 🧐	CU FT/HP.H			
Temp Jacket Water Pump Inlet 🧐	F	192	197	186
Delta T Jacket Water (out-in) 🧐	F	16	25	7
Inlet Manifold Temp 🞯	F	122	127	116
Water Temp to Scac 🧐	F			
Scac Water Flow 🥝	GAL/MIN			
Oil Pressure 🥥	PSI	63	87	43
Oil Pressure Low Idle 🮯	PSI	59	87	34
Fuel Pressure	PSI	75	102	51
Inlet Fuel Pressure	PSI		6	
Inlet Fuel Temp	F	86	91	80
Inlet Air Pressure	IN_HG		31	26
Inlet Air Restriction	IN_HG		1.18	
Inlet Air Temperature	F		122	50
Fuel Density	DEG API		36.0	34.0
Boost Constant				
Governor Setting Constant				
Governor Setting Torque	% RTD TRQ	90.0	91.0	89.0
High Idle Stability	RPM			
Low Idle Stability	RPM			
Set Point RPM	RPM	1820	1830	1810
Adjusted Boost (Gas Blending) 🧐	HG			
Corrected Fuel Rate - Diesel (Gas Blending) 🞯	GAL/HR			
Corrected Fuel Rate - Gas (Gas Blending 🧐	BTU/MIN			
Full Load Fueling (Gas Blending) 🙆	MM3/ST			
Gas Substitution Ratio (Gas Blending) 🙆	%			
Corr Full Load Power (Gas Blending)	НР			
Full Load Speed (Gas Blending) 🞯	RPM			
		1	İ	1

Exhaust Back Pressure	PSI		
TQ CK Exhaust Back Pressure	PSI		
Ataac Delta Pressure	PSI		

Engine Reference Information			
Description	Measure	Data	
FL Static/FT Static Fuel Settings	in	1.209 /	
Fuel Valve Part Number			
Unit Injector Part Number		3920221	
Timing Dimension Field Service	in	2.533	
Timing Dimension Factory			
Torque Control Group Number		Change Level:	
Fuel Pump/Gov Grp Part Number		1008780	
Fuel Pump Type		EUI	
Flyweight Part Number/Attitude			
Turbo Part No and Model		2870421 / GT6041BN-48T-1.1	
Advertised Power / Governor Speed		3,634hp 1,800 RPM	
Compression Ratio		14.7	
Torque Rise Cam Part Number			
Manifold Type		DRY	
Engine Flash File Part Number		5224589	
Rating Number		1	
Flash File Change Number			
ASM Flash File Part Number			
ISM Flash File Part Number			
Advisor Flash File Part Number			
Secondary Module Flash File Part Number			
Messenger Flash File Part Number			
Tandem Software Flash File Part Number			
Governor Type		ADEM3	

Torque Control Group Spring Data

Part No	Thickness	Quantity
No data found		

Torque Control Group Spacer Data

Part No	Thickness	Quantity
No data found		

Timing Data Mechanical Advance Part Number: Chg. Level: Advance: 0.0 DEG Dog Leg Differentials: RPM: KW:				
Description	Measure	Spec	Minimum	Maximum
Timing Static @ 0 RPM BTDC	DEG			

Application/Performance Data		
Description	Measure	Data
Application Identification		297 GS MISSION CRI
Engine Sales Model and Series		3516 C
Combustion System type		DI
Aspiration Type		ТА
Engine Source Factory Ref Number		88
Power Setting PL/PP Ref Number		LL6760
Engine Perf Data Ref No and Change Level		EM1895
Multi Engine Torq/Rating		
Emissions Family		
Generator Rating W/O Fan	EKW	
Generator	HZ	60
Brakesaver test		

Certified Engine Rating	hp	
Engineering Model Ref		PG243
Low Idle In-Veh Speed	RPM	
Sales Model		
Machine Facility		
Usage		
Transmission		
Description		GS
Serial Number Prefixs		

Altitude Derating Information						
Description	Measure	Data				
Altitude - Maximum	FT	2,952				
Engine Power (ADV)	hp					
Engine Power (Test)	hp	3,634				
High Idle Speed	RPM					
FL Static Fuel Setting	in					
FT Static Fuel Setting	in					
Corrected Fuel Rate	GAL/HR	177.0				
FL Boost Pressure	IN_HG					

Spec Number vs. Arrangement Number Cross Reference				
Arrangement	5157721			

_

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 09/18/2019 9:41:27 AM © Caterpillar Inc. 2019 All Rights Reserved. <u>Data Privacy Statement</u>.

(This Page Intentionally Left Blank)

RADIATOR PERFORMANCE DATA [LF3756]

SEPTEMBER 18, 2019

For Help Desk Phone Numbers Click here

Component Performance Number: EM2773						
Radiator Data	Engine Data	Combination Data				
Radiator Part Number: 5258746	Performance Number: EM1895	Pully Ratio: 0.39				
Radiator Type: ASF56.0CV	Sales Model: 3516	Fan Power: 130.07893 hp				
Front Area: 55.97 ft2	EKW: 2500					
Radiator Dry Weight: 6,686.6 lbs	Rating: MCSTNDBY					
Radiator Wet Weight: 7,319.3 lbs	Speed: 1800					
Radiator Water Capacity High Temp Circuit: 71.0 gal	Settings: NA					
Radiator Water Capacity Low Temp Circuit: NA gal	Radiator Water Capacity Low Temp Circuit: NA gal IM ATAAC Temp Deg F: 122					
Center of Gravity (X): 25.28 in (Distance from front factor	e of core)					
Center of Gravity (Y): 58.94 in (Distance from bottom o	f radiator support)					
Center of Gravity (Z): 0.78 in (Distance from center line	e of core)					

Ambient Restrictions (1/2 inH2O)		Ambient Restrictions (3/4 inH2O)		t inH2O)	Air Flow	Air Flow	
984 Feet	2460 Feet	4921 Feet	984 Feet	2460 Feet	4921 Feet	Kestrictions (1/2 mm20)	Kestrictions (3/4 mm20)
	Max A	Ambient P	re-alarm	Deg F -		sc	fm
113	107	98	107	104	95	101000	96303

No Graph data available ...

Reference Number: EM2773	No notes found
Parameters Reference: TM6016	RADIATOR CORE DATA CONDITIONS: CORE AIR FLOW RESISTANCE DATA IS FOR A FREE STANDING CORE ONLY. ADDITIONAL AIR FLOW RESISTANCE DUE TO SHROUDS, DUCTING, COOLERS AND ENGINE COMPONENTS MUST BE ADDED IN ORDER TO CALCULATE TOTAL SYSTEM PERFORMANCE. CORE PERFORMANCE DATA IS BASED ON AN AIR DENSITY OF 1.20 KG/M3 (.075 LB/CU FT). AMBIENT CAPABILITY: THE AMBIENT CAPABILITY AND ALTITUDE CAPABILITY LISTED ON THIS PAGE REFLECTS THE THE CAPABILITY OF THE COOLING SYSTEM AT THE MAXIMUM GENERATOR SET RATING. THE AMBIENT AND ALTITUDE CAPABILITY MUST BE VERIFIED FOR THE ENGINE AND GENERATOR IN THE ENGINE PERFORMANCE SECTION OF TMI. NON-TIER 4 AMBIENT CAPABILITY CALCULATIONS ARE BASED ON A 50/50 GLYCOL COOLANT MIX AND 4°C (7°F) AIR TO CORE RISE. TIER 4 AMBIENT CAPABILITY CALCULATIONS ARE BASED ON A 50/50 GLYCOL COOLANT MIX AND 6°C (9°F) AIR TO CORE RISE. ASSUME 3°C ADDITIONAL AMBIENT CAPABILITY WITH TREATED WATER INSTEAD OF 50/50 GLYCOL AS COOLANT. THE CORE AIRFLOW VS CORE RESISTANCE CHARTS REPRESENT CORE ONLY DATA. ALL OTHER DATA IS FOR THE COMPLETE PACKAGE.
	LAST UPDATED : 05/13/2010

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 09/18/2019 9:51:47 AM © Caterpillar Inc. 2019 All Rights Reserved. <u>Data Privacy Statement</u>.

GENERATOR DATA

SEPTEMBER 18, 2019

For Help Desk Phone Numbers Click here

Engine: 3516 Fuel: Diesel Frequency: 60	Generator Fr Generator Ar Excitation Ty	Selecte ame: 1844 rangement: 3723056 pe: Permanent Magne	ed Moc Gens Gens et Pwr.	lel et Rating (kW et Rating (kV Factor: 0.8	/): 2500.0 A): 3125.	Line V 0 Phase Rated	Voltage: 480 voltage: 27 Current: 37	7 758.8
Duty: STANDBY	Connection: S	SERIES STAR	Appl	ication: EPG		Status 	s: Current : : :0749 /40681 /9309)
	Concrator Sp	Spec In	rormat	ion				
Frame: 1844 T	vne SR5	No of Rearings. 2		G	enerato	r Efficie	ency	
Winding Type:	FORM WOUN	D Flywheel: 21 0		Per Unit Lo	ad	kW	Efficiency	/ %
Connection: SE	RIES STAR	Housing: 00		0.25	6	25.0	92.8	
Phases: 3		No of Leads: 6		0.5	12	250.0	95.3	
Poles: 4		Wires ner Lead: 8		0.75	18	375.0	95.8	
Sync Speed: 180	00	Generator Pitch: ().6667	1.0	25	500.0	95.7	
Rea	ctances			 D/	er Unit	Ohm]
SUB	FRANSIENT - D	IRECT AXIS X"d		0	1194	0.008	8	
SUB	FRANSIENT - O	UADRATURE AXIS X	"	0.	1139	0.0084	4	
TRA	NSIENT - SATU	RATED X' _d	4	0.	1804	0.013	3	
SYNC	CHRONOUS - D	IRECT AXIS X _d		2.3	8673	0.2114	4	
SYNC	CHRONOUS - Q	UADRATURE AXIS X	q	1.2	2709	0.093	7	
NEG	ATIVE SEQUEN	ICE X ₂		0.	1166	0.008	6	
ZERO) SEQUENCE X	0		0.0	0081	0.000	6	
Time	e Constants					Seco	nds	
OPE	N CIRCUIT TF	ANSIENT - DIRECT	AXIS	T' _{d0}		5.3930)	
SHO	RT CIRCUIT 1	RANSIENT - DIREC	CT AXI	S T'd		0.3395	5	
OPE	N CIRCUIT SU	BSTRANSIENT - DI	RECT	AXIS T" _{d0}		0.0079)	
SHO	RT CIRCUIT S	SUBSTRANSIENT - I	DIREC	Г AXIS T" _d		0.0066	Ď	
OPE	N CIRCUIT SU	BSTRANSIENT - Q	JADRA	ATURE AXIS	T" _{q0}	0.0071		
SHO	RT CIRCUIT S	SUBSTRANSIENT - (QUADI	RATURE AXI	S T"a	0.0060)	
EXC	ITER TIME CO	DNSTANT T _e				0.2580)	
ARM	IATURE SHOI	RT CIRCUIT T _a				0.0414	Ļ	
Short Circui	t Ratio: 0.48	Stator Resistance $= 0$.0012 (Ohms Field	d Resistan	ce = 0.9	0703 Ohms	Ī
Vol	tage Regulati	on		G	enerato	r Excita	ation	
tage level adjustn	nent: +/-	5.0%			No Lo	oad l	Full Load, (rated)
tage regulation, s	teady state: +/	- 0.5%				\$	Series	Paral
tage regulation w	ith 3% speed of	change: +/- 0.5%	Excita	tion voltage:	12.98 V	/olts	52.73 Volts	Vol
veform deviation line - line, no load: less than 3.0%				ation current	1.19 A	mps	3.99 Amps	Am
phone influence	factor: less tha	in 50						

Selected Model

Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current

Version: 41205 /40749 /40681 /9309



	Selected	d Model	
Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version: 41205 /40749 /40681 /9309

Generator Cooling Requirements - Temperature - Insulation Data						
Cooling Requ	irements:	Temperature Da	ta: (Ambient 40 ⁰ C)			
Heat Dissipat	ed: 112.3 kW	Stator Rise:	125.0 ⁰ C			
Air Flow:	199.2 m ³ /min	Rotor Rise:	125.0 ⁰ C			
	Insula	tion Class: H				
Insu	lation Reg. as shippe	ed: 100.0 MΩ minim	um at 40 0 C			
	Thermal Lir	mits of Generator				
	Frequency: Line to Line V	Voltage: 480 Volts				
	B BR 80/40 2500.0 kVA F BR -105/40 2844.0 kVA					
	H BR - 125/40 3125.0 kVA F PR - 130/40 3125.0 kVA					
	H PR - 150/40) 3438.0 kVA				

Selected Model					
Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480		
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277		
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8		
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current		
			** •		

Version: 41205 /40749 /40681 /9309

Starting Capability & Current Decrement Motor Starting Capability (0.4 pf)





Instantaneous 3 Phase Fault Current: 31132 Amps Instantaneous Line - Line Fault Current: 27270 Amps Instantaneous Line - Neutral Fault Current: 45568 Amps

Selected Model				
Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480	
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277	
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8	
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current	
			Version: 41205 /40749 /40681 /9309	

Generator Output Characteristic Curves Open Circuit Curve



41205 /40749 /40681 /9309



Selected Model

Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version:

Generator Output Characteristic Curves Zero Power Factor Curve





Selected Model				
Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480	
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277	
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8	
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current	
			Version: 41205 /40749 /40681 /9309	

Reactive Capability Curve

https://tmiwebclassic.cat.com/tmi/servlet/cat.edis.tmiweb.gui.TMIDirector?Action=buildt... 09/18/2019



Operating Chart

	Selected	NIODEI	
Engine: 3516	Generator Frame: 1844	Genset Rating (kW): 2500.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 3723056	Genset Rating (kVA): 3125.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Permanent Magnet	Pwr. Factor: 0.8	Rated Current: 3758.8
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version: 41205 /40749 /40681 /9309

General Information

DM7825 Caterpillar SR5 Generators (50 Hz, 60 Hz) Data for 1400, 1600, 1700, 1800 and 1900 frames Caterpillar SR5 generators built by Leroy Somer - USA and Leroy Somer France.

Refer to DM7821 for explanation of all generator data in Technical Marketing Information (TMI) except generator efficiency for which the explanation is given below.

GENERATOR EFFICIENCY

Generator efficiency is the percentage of engine flywheel (or other prime mover) power that is converted into electrical output. The generator efficiency shown is calculated by the summation of all losses method, and is determined in accordance with the IEC Standard 60034. The efficiency considers only the generator. There is no consideration of engine or parasitic losses here.

Refer to DM7829 for low and medium voltage protective setting values a nd limits.

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 09/18/2019 9:56:14 AM © Caterpillar Inc. 2019 All Rights Reserved. <u>Data Privacy Statement</u>.



ENGINEERING DRAWINGS



(This Page Intentionally Left Blank)



- 6

- 6

4

PRICING AR	FLOW TYPE	CATALYTIC TYPE
547-2600 CHG 00		
547-2590 CHG 00	SIDE IN	5X4X3 (EH9)
547-2580 CHG 00		

- 8

CONVERTER GP-CATALYTIC DWG # 559-1243 CHG 01 METRIC [INCH] FRONT VIEW BOTTOM IN 535-6800 CHG 01 SHOWN SCALE 1:10

4

	F
	E
	D
	С
	В
IEDIDIA INI-PROP IE2966B IDENT IE2722E DRAWING IE0198W BRAND MARKINGS IE0013G CONFIDENTIALITY IE0012A INTERPRETATION N IE0011 IE0011 INTPR & TOL E Caterpilar: Confidential Green PROD. OTHER PROD. OTHER IMENSIONS ARE IN mm VERSION PRIMARY DIMENSIONS ARE IN mm TYPE DIMENSIONS W/O TOL ARE BASIC TYPE SECONDARY THIRD ANGLE PROJECTION SHEET OF THIRD ANGLE SHEET OF PROJECTION SHEET OF THIRD ANGLE SHEET OF THIRD ANGLE SHEET OF PROJECTION SHEET OF THIRD ANGLE SHEET OF THIRD ANGLE SHEET OF INSTL - ATTACHMENT OF MODULES S59 - I243 VER CHG S59 - I243 OIL OIL I INSTL	A

METRIC

559-1243

- 6



4

6

7

01

- 8 -

CONVERTER GP-CATALYTIC DWG # 559-1243 CHG 01 METRIC [INCH] RIGHT SIDE VIEW BOTTOM IN 535-6800 CHG 01 SHOWN SCALE 1:10

4



ł	<u> </u>								4
	HT Tr								
`			1E5167A	INT-PR	OP				
			1E2966B	IDENT					
			1E2722E	DRAWIN	6				
			E0 98W	BRAND	MAR	KING	S		
			E00 3G	CONFID	ENT	IALI	ΓY		
			1E0012A	INTERP	RET	ATIO	N		
		NO	1E0011	INTPR	& T	ΌL Π			
		T E	Caterpillar: Co	onfidentia	l Gra	een			
		PROD. OTHER RECORDS					1		
		UNLESS OTHERWISE SPECIFIED VERSIO			FR5 LON	PRIMARY	Х		
		DIMENSIONS ARE IN mm DIMENSIONS W/O TOL ARE BAS			IC .	TYPE	SECONDARY		1
		THIRD ANGLE SHEET 2 OF 4				A			
					DWG (CONTROL	PSII		1
							1		
		THE		T HEREON LA PROV	IDED TO		RPILLAR INC. AN	0/08	
		ITS SUBSIDIARIES AND INCLUDES INFORMATION OWNED BY CATERFILLAR AND/OF OWNER PARTIES, Caterfillar from bits and coting, transmittal to others, or use for any furbose every for that which it is loaded unless expressly permitted in writing.							
		INSTL-ATTACHMENT							
		(AFTERTRE	ΕΑΤΜΕ	ΝT	MOE	DULES		
			559	- 2	4	3 <u>ver</u> -	CHG	Ε	
-									

METRIC

559-1243



A





DETAIL OF EXHAUST INLET SCALE 1:5




Generator set data sheet



Model:	DQKAF	
Frequency:	60 Hz	
Fuel type:	Diesel	
kW rating:	2250 Standby 1825 Prime	
		_

Emissions level:

EPA NSPS Stationary Emergency Tier 2

Exhaust emission data sheet:	EDS-1120
Exhaust emission compliance sheet:	EPA-1166
Sound performance data sheet:	MSP-1132
Cooling performance data sheet:	MCP-208
Prototype test summary data sheet:	PTS-308
Standard set-mounted radiator cooling outline:	A034T734
Optional set-mounted radiator cooling outline:	A034H896
Optional heat exchanger cooling outline:	A034H896
Optional remote radiator cooling outline:	A034U921

	Standby			Prime				Continuous	
Fuel consumption	kW (kVA)		kW (kVA)				kW (kVA)		
Ratings	2250 (2812)			1825 (2281)			
Load	1/4	1/2	3/4	Full	1/4	1/2	3/4	Full	Full
US gph	50.6	85.6	119.3	151.8	43.9	72.6	100.4	127.4	
L/hr	191.7	324.1	451.7	574.6	166.2	274.6	380.0	482.2	

Engine	Standby rating	Prime rating	Continuous rating
Engine manufacturer	Cummins Inc.		
Engine model	QSK60-G14 NR2		
Configuration	Cast iron, V 16 cy	linder	
Aspiration	Turbocharged and	d low temperature aft	er-cooled
Gross engine power output, kWm (bhp)	2446 (3280)	1980 (2655)	
BMEP at set rated load, kPa (psi)	2710 (393)	2193 (318)	
Bore, mm (in.)	159 (6.25)		
Stroke, mm (in.)	190 (7.48)		
Rated speed, rpm	1800		
Piston speed, m/s (ft/min)	11.4 (2243)		
Compression ratio	14.5:1		
Lube oil capacity, L (qt)	261 (276)	378 (400)	
Overspeed limit, rpm	2070		
Regenerative power, kW	277		

Fuel flow

Maximum fuel flow, L/hr (US gph)	1033 (273)	
Maximum fuel inlet restriction, kPa (in Hg)	16.9 (5)	
Maximum fuel inlet temperature, ℃ (°F)	71 (160)	

Air	Standby rating	Prime rating	Continuous rating
Combustion air, m ³ /min (scfm)	195 (6900)	167 (5910)	
Maximum air cleaner restriction, kPa (in H2O)	3.7 (15)		
Alternator cooling air, m ³ /min (cfm)	222 (7840)		

Exhaust

Exhaust flow at set rated load, m ³ /min (cfm)	473 (16700)	402 (14205)	
Exhaust temperature, °C (°F)	474 (885)	457 (855)	
Maximum back pressure, kPa (in H2O)	6.7 (27)		

Standard set-mounted radiator cooling

Ambient design, ℃ (°F)	40 (104)		
Fan Ioad, kWm (HP)	46 (61)		
Coolant capacity (with radiator), L (US gal)	537 (142)		
Cooling system air flow, m ³ /min (scfm)	2094 (73937)		
Total heat rejection, MJ/min (Btu/min)	121.3 (114968)	98.5 (93385)	
Maximum cooling air flow static restriction, kPa (in H2O)	0.12 (0.5)		
Maximum fuel return line restriction kPa (in Hg)	34 (10)		

Optional set-mounted radiator cooling

Ambient design, ℃ (°F)	50 (122)		
Fan Ioad, kWm (HP)	66 (88)		
Coolant capacity (with radiator), L (US gal)	606 (160)		
Cooling system air flow, m ³ /min (scfm)	2347 (82891)		
Total heat rejection, MJ/min (Btu/min)	121.3 (114968)	98.5 (93385)	
Maximum cooling air flow static restriction, kPa (in H2O)	0.12 (0.5)		
Maximum fuel return line restriction kPa (in Hg)			

Optional heat exchanger cooling

Set coolant capacity, L (US gal)	
Heat rejected, jacket water circuit, MJ/min (Btu/min)	
Heat rejected, aftercooler circuit, MJ/min (Btu/min)	
Heat rejected, fuel circuit, MJ/min (Btu/min)	
Total heat radiated to room, MJ/min (Btu/min)	
Maximum raw water pressure, jacket water circuit, kPa (psi)	
Maximum raw water pressure, aftercooler circuit, kPa (psi)	
Maximum raw water pressure, fuel circuit, kPa (psi)	
Maximum raw water flow, jacket water circuit, L/min (US gal/min)	
Maximum raw water flow, aftercooler circuit, L/min (US gal/min)	
Maximum raw water flow, fuel circuit, L/min (US gal/min)	
Minimum raw water flow at 27 $^{\circ}\!C$ (80 $^{\circ}\!F)$ inlet temp, jacket water circuit, L/min (US gal/min)	
Minimum raw water flow at 27 °C (80 °F) inlet temp, aftercooler circuit, L/min (US gal/min)	
Minimum raw water flow at 27 °C (80 °F) inlet temp, fuel circuit, L/min (US gal/min)	
Raw water delta P at min flow, jacket water circuit, kPa (psi)	
Raw water delta P at min flow, aftercooler circuit, kPa (psi)	
Raw water delta P at min flow, fuel circuit, kPa (psi)	
Maximum jacket water outlet temp, °C (°F)	
Maximum aftercooler inlet temp, °C (°F)	
Maximum aftercooler inlet temp at 25 °C (77 °F) ambient, °C (°F)	
Maximum fuel return line restriction, kPa (in Hg)	

Optional remote radiator cooling ¹	Standby rating	Prime rating	Continuous rating
Set coolant capacity, L (US gal)			
Max flow rate at max friction head, jacket water circuit, L/min (US gal/min)	1900 (502)		
Max flow rate at max friction head, aftercooler circuit, L/min (US gal/min)	606 (160)		
Heat rejected, jacket water circuit, MJ/min (Btu/min)	56.6 (53645)	50.2 (47575)	
Heat rejected, aftercooler circuit, MJ/min (Btu/min)	43.9 (41605)	31.5 (29820)	
Heat rejected, fuel circuit, MJ/min (Btu/min)			
Total heat radiated to room, MJ/min (Btu/min)	19.4 (18406)	16 (15183.1)	
Maximum friction head, jacket water circuit, kPa (psi)	69 (10)		
Maximum friction head, aftercooler circuit, kPa (psi)	48 (7)		
Maximum static head, jacket water circuit, m (ft)	18 (60)		
Maximum static head, aftercooler circuit, m (ft)	18 (60)		
Maximum jacket water outlet temp, °C (°F)	104 (220)	100 (212)	
Maximum aftercooler inlet temp at 25 °C (77 °F) ambient, °C (°F)	49 (120)		
Maximum aftercooler inlet temp, ℃ (°F)	71 (160)	66 (150)	
Maximum fuel flow, L/hr (US gph)			
Maximum fuel return line restriction, kPa (in Hg)			

Weights²

Unit dry weight kgs (lbs)	16182 (35675)
Unit wet weight kgs (lbs)	16882 (37218)

Notes:

¹ For non-standard remote installations contact your local Cummins representative.

² Weights represent a set with standard features. See outline drawing for weights of other configurations.

Derating factors

Standby	Standard cooling system: Full rated power available up to 578.6 m (1898 ft) elevation at ambient temperatures up to 40 °C (104 °F). Above these conditions derate by 6.4% per 305 m (1000 ft), and derate by an additional 8.5% per 10 °C (18 °F). Enhanced cooling system: Full rated power available up to 588.6 m (1930.5 ft) elevation at ambient temperatures up to 40 °C (104 °F). Above these conditions derate by 6.4% per 305 m (1000 ft). Full rated power available up to 32.9 m (107.8 ft) elevation at ambient temperatures up to 50 °C (122 °F). Above these conditions derate by 4% per 305 m (1000 ft). At higher ambient temperatures, derate by additional 12% per 10 °C (18 °F).
Prime	Full rated power available up to 64.1 m (210.3 ft) elevation at ambient temperature up to 40 $^{\circ}$ C (104 $^{\circ}$ F). Above these elevations, at 40 $^{\circ}$ C (104 $^{\circ}$ F), derate by 5.1% per 305 m (1000 ft). Derate by 17% at sea level at ambient temperatures up to 50 $^{\circ}$ C (122 $^{\circ}$ F). Above these elevations, at 50 $^{\circ}$ C (122 $^{\circ}$ F), derate by an additional 5.1% per 305 m (1000 ft). At higher ambient temperatures, derate by an additional 16% per 10 $^{\circ}$ C (18 $^{\circ}$ F).

Continuous

Ratings definitions

nutrigo deminiono			
Emergency Standby Power (ESP):	Limited-Time Running Power (LTP):	Prime Power (PRP):	Base Load (Continuous) Power (COP):
Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. Emergency Standby Power (ESP) is in accordance with ISO 8528. Fuel stop power in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.	Applicable for supplying power to a constant electrical load for limited hours. Limited-Time Running Power (LTP) is in accordance with ISO 8528.	Applicable for supplying power to varying electrical load for unlimited hours. Prime Power (PRP) is in accordance with ISO 8528. Ten percent overload capability is available in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.	Applicable for supplying power continuously to a constant electrical load for unlimited hours. Continuous Power (COP) is in accordance with ISO 8528, ISO 3046, AS 2789, DIN 6271 and BS 5514.

|--|

		Temp rise		Single phase	Max surge	Winding	Alternator	Frame	Feature
Voltage	Connection ¹	degrees C	Duty ²	factor ³	kVA ⁴	No.	data sheet	size	code
380	Wye, 3-phase	105/80	S/P		7994	13	ADS-516	LVSI804S	B599-2
380	Wye, 3-phase	125/105	S/P		7333	13	ADS-515	LVSI804R	B737-2
380	Wye, 3-phase	150/125	S/P		7333	13	ADS-515	LVSI804R	B799-2
416	Wye, 3-phase	105/80	S/P		9719	13	ADS-517	LVSI804T	B715-2
440	Wye, 3-phase	125	S		8412	12	ADS-516	LVSI804S	B535-2
440	Wye, 3-phase	105/80	S/P		8412	12	ADS-516	LVSI804S	B664-2
440	Wye, 3-phase	150	S		7267	12	ADS-515	LVSI804R	B701-2
480	Wye, 3-phase	105/80	S/P		8412	12	ADS-516	LVSI804S	B600-2
480	Wye, 3-phase	80	S		9719	12	ADS-517	LVSI804T	B601-2
480	Wye, 3-phase	125	S		7267	12	ADS-515	LVSI804R	B738-2
480	Wye, 3-phase	150	S		7267	12	ADS-515	LVSI804R	B816-2
600	Wye, 3-phase	125/105	S/P		7233	7	ADS-515	LVSI804R	B300-2
600	Wye, 3-phase	105/80	S/P		8189	7	ADS-516	LVSI804S	B603-2
600	Wye, 3-phase	80	S		12426	7	ADS-531	LVSI804W	B604-2
600	Wye, 3-phase	150	S		7695	7	ADS-335	P734G	B817-2
4160	Wye, 3-phase	105/80	S/P		6335	51	ADS-518	MVSI804R	B313-2
4160	Wye, 3-phase	80	S		7295	51	ADS-519	MVSI804S	B605-2
4160	Wye, 3-phase	80	S/P		7295	51	ADS-519	MVSI804S	B905-2
4160	Wye, 3-phase	125/105	S/P		6335	51	ADS-518	MVSI804R	B930-2
12470	Wye, 3-phase	105/80	S/P		7993	87	ADS-522	HVSI804S	B567-2
12470	Wye, 3-phase	125/105	S/P		6800	91	ADS-522	HVSI804S	B810-2
12470	Wye, 3-phase	105/80	S/P		7993	91	ADS-523	HVSI804T	B928-2
13200	Wye, 3-phase	105/80	S/P		6800	91	ADS-522	HVSI804S	B806-2
13200	Wye, 3-phase	125/105	S/P		6800	91	ADS-522	HVSI804S	B819-2
13200	Wye, 3-phase	105/80	S/P		6800	91	ADS-522	HVSI804S	B929-2
13800	Wye, 3-phase	125	S		5948	91	ADS-521	HVSI804R	B820-2
13800	Wye, 3-phase	105	S		6800	91	ADS-522	HVSI804S	B908-2
13800	Wye, 3-phase	80	S/P		7993	91	ADS-523	HVSI804T	B909-2

Notes:

¹ Limited single phase capability is available from some three phase rated configurations. To obtain single phase rating, multiply the three phase kW rating by the single phase factor³. All single phase ratings are at unity power factor.

² Standby (S), Prime (P) and Continuous ratings (C).

³ Factor for the *single phase output from three phase alternator* formula listed below.

⁴ Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

⁵ Derate may be applicable. Please consult the factory for details.

Formulas for calculating full load currents:

Derate may be applicable. Please consult the factory for details.

Three	phase	output	

Single phase output

kW x 1000

Voltage x 1.73 x 0.8

kW x SinglePhaseFactor x 1000 Voltage

Warning: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.

For more information contact your local Cummins distributor or visit power.cummins.com



Our energy working for you.™

©2018 Cummins Inc. All rights reserved. Cummins is a registered trademark of Cummins Inc. PowerCommand, AmpSentry, InPower and "Our energy working for you." are trademarks of Cummins Inc. Other company, product, or service names may be trademarks or service marks of others. Specifications are subject to change without notice. D-3511 (03/18)



Exhaust emission data sheet 2250DQKAF

60 Hz Diesel generator set EPA NSPS stationary emergency

Cummins Inc. QSK60-G14 NR2	Bore:	6.25 in. (159 mm)
4 Cycle, 60° V, 16 cylinder diesel	Stroke:	7.48 in. (190 mm)
Turbocharged and low temperature after-cooled (2 pump/2 loop)	Displacement:	3673 cu. in. (60.2 liters)
14.5:1		
Turbocharged with low temperature after-cooler		
1	Cummins Inc. QSK60-G14 NR2 4 Cycle, 60° V, 16 cylinder diesel Turbocharged and low temperature after-cooled (2 pump/2 loop) 14.5:1 Turbocharged with low temperature after-cooler	Cummins Inc. QSK60-G14 NR2Bore:4 Cycle, 60° V, 16 cylinder dieselStroke:Turbocharged and lowDisplacement:temperature after-cooled(2 pump/2 loop)14.5:1Turbocharged with lowtemperature after-cooler

	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>Full</u>	<u>Full</u>		
Performance data	<u>Standby</u>	Standby	<u>Standby</u>	<u>Standby</u>	Prime		
BHP @ 1800 RPM (60 Hz)	820	1640	2459	3280	2655		
Fuel consumption (Gal/Hr)	48	88	121	154	129		
Exhaust gas flow (CFM)	6594	11190	14174	16546	14760		
Exhaust gas temperature (°F)	727	821	855	895	864		
Exhaust emission data							
HC (Total unburned hydrocarbons)	0.15	0.07	0.02	0.04	0.02		
NOx (Oxides of nitrogen as NO2)	4.04	3.5	4.64	6.83	5.03		
CO (Carbon monoxide)	0.71	0.28	0.2	0.37	0.2		
PM (Particular matter)	0.16	0.07	0.03	0.04	0.03		
SO2 (Sulfur dioxide)	0.005	0.005	0.005	0.004	0.005		
Smoke (Bosch)	0.55	0.31	0.17	0.25	0.17		
				All values are Grams per HP-Hou			

Test conditions

Data is representative of steady-state engine speed (\pm 25 RPM) at designated genset loads. Pressures, temperatures, and emission rates were stabilized.

Fuel specification:	ASTM D975 No. 2-D diesel fuel with ULSD, and 40-48 cetane number.
Fuel temperature	99 \pm 9 °F (at fuel pump inlet)
Intake air temperature:	77 ± 9 °F
Barometric pressure:	29.6 ± 1 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb dry air
Reference standard:	ISO 8178

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.



2019 EPA Tier 2 Exhaust Emission Compliance Statement 2250DQKAF Stationary Emergency

60 Hz Diesel generator set

6.25 in. (159 mm)

7.48 in. (190 mm) 3673 cu. in. (60.2 liters)

14.5:1

Compliance Information:

 The engine used in this generator set complies with Tier 2 emissions limit of U.S. EPA New Source Performance

 Standards for stationary emergency engines under the provisions of 40 CFR 60 Subpart IIII when tested per ISO8178

 D2.

 Engine Manufacturer:
 Cummins Inc.

EPA Certificate Number:	KCEXL060.AAD-021
Effective Date:	10/01/2018
Date Issued:	10/01/2018
EPA Engine Family (Cummins Emissions Family):	KCEXL060.AAD

Engine information:

Model:	QSK60-G14 NR2	Bore:
Engine Nameplate HP:	3280	Stroke:
Туре:	4 cycle, 60°V, 16 Cylinder Diesel	Displacement:
Aspiration:	Turbocharged and Low Temperature Aftercooled	Compression Ratio:
Emission control device:	Electronic Control	

Diesel Fuel Emissions Limits

D2 Cycle Exhaust Emissions		Grams per BHP-hr			<u>Grams per kW_m-hr</u>		
	<u>NOx +</u> NMHC	<u>co</u>	<u>PM</u>	<u>NOx +</u> NMHC	<u>co</u>	<u>PM</u>	
Test Results	4.2	0.75	0.10	5.6	1.0	0.14	
EPA Emissions Limit	4.8	2.6	0.15	6.4	3.5	0.20	

Test methods: EPA nonroad emissions recorded per 40CFR89 (ref. ISO8178-1) and weighted at load points prescribed in Subpart E, Appendix A for constant speed engines (ref. ISO8178-4, D2)

Diesel fuel specifications: Cetane number: 40-48. Reference: ASTM D975 No. 2-D, 300-500 ppm Sulfur.

Reference conditions: Air inlet temperature: 25°C (77°F), Fuel inlet temperature: 40°C (104°F). Barometric pressure: 100 kPa (29.53 in Hg), Humidity: 10.7 g/kg (75 grains H2O/lb) of dry air; required for NOx correction, Restrictions: Intake restriction set to a maximum allowable limit for clean filter; Exhaust back pressure set to a maximum allowable limit.

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.



	T REL NO REVISION DATE	
	ECO-156406 A 1 PRODUCTION RELEASE SLOLDE A.BORROTO 22FEB	515
	NOTES:	
	2. PROVIDE FLEXIBLE CONDUIT TO CONTROL BOX.	D
	3. GENSET SHIPPED FILLED WITH ENGINE OIL.	
	4. SUPPLIED FUEL HOSE:	
	4.1. FUEL INLET HOSE: $\emptyset 22.2 \ [\emptyset 0.88] X 1270 \ [50.0] LONWITH I-II I/2 NPT EXTERNAL FITTING.$.6
	4.2. FUEL OUTLET HOSE: ∅16 [∅0.64] X 1270 [50.0] LONG WITH 3/4-14 NPT EXTERNAL FITTING.	
	5. IN-SKID ANTI VIBRATION MOUNTS ARE STANDARD ON THESE GENSETS.	
	6 GENSET LIFTING SHACKLES TO BE USED PER DIMENSIONS SHOWN. (SHEETS 2 AND 3)	
	<pre>MINIMUM AIR FILTER REMOVAL DISTANCE: HEAVY DUTY AIR FILTER = 700 [28] (SHEET 3) STANDARD DUTY AIR FILTER = 610 [24] (SHEET 2)</pre>	
	8. GENSET WEIGHTS ARE WITH STANDARD DUTY AIR CLEANERS. ADD 59 Kg (I30 LBS) WITH HEAVY DUTY AIR CLEANER.	С
	ISOLATOR LOCATION USED ONLY FOR ROOFTOP INSTALLATIONS. (SHEET 3)	
	IO. FOR SEISMIC ISOLATOR QUANTITY NEEDED, USE GENSET INSTALLATION DRAWING A046G655. RECOMMENDATION TO USE SAME QUANTITY FOR NON-SEISMIC ISOLATORS AS WELL CONTACT LOCAL SAE FOR ANY QUESTIONS.	
	II. FORCES ARE BASED ON NOMINAL VALUE.	\leftarrow
	12. ALL DIMENSIONS ARE REFERENCE, UNLESS SPECIFICALLY TOLERANCED.	
A	COMMON REFERENCE POINT ON GENSET SKID (
	14. LATERAL CENTER OF GRAVITY IS ON THE CRANK SHAFT CENTER LINE.	
	P7 TERMINAL HOUSING	В
	RTD AUXILIARY BOX OPTIONAL	
!	ALTERNATOR HEATER	
	GENSET CONTROL OPTIONAL LOCATION	A
DT S	CALE PRINT CKD L. ERNST APVD A. BORROTO CUMMINS POWER GENERATION OUTLINE, GENSET	
HEREO E DISC	DATE 13FEB16 N) IS CLOSED TO OTHERS ANY MEANS, OR DEFENSIONING AND TOLERANCING, SEE ANY MEANS, OR DEFENSION ING AND GFNSFT-QSK60 PGF DWG SIZE A054M306 LOFI	ет 3
NÎ OF]



Potential Site Variation Values

Generator Set Model	DQKAF
Engine Model	QSK60-G14
Fuel Rating	6816
Emissions Level	Tier 2

					SO Standb	Y	
Conorator	Sotlood	%	10	25	50	75	100
Generator	Set Loau	kWe	225	563	1125	1688	2250
Engine Loa	d	hp	328	820	1640	2459	3280
Fuel Consumption		gal/hr	26.8	48	88	121	154
	HC	g/bhp∙hr	0.39	0.15	0.07	0.02	0.04
Nominal	NOx	g/bhp∙hr	6.69	4.04	3.50	4.64	6.83
Nominal	СО	g/bhp∙hr	2.33	0.71	0.28	0.20	0.37
	PM	g/bhp∙hr	0.33	0.16	0.07	0.03	0.04

	HC	g/bhp∙hr	0.66	0.26	0.12	0.03	0.07
Potential	NOx	g/bhp∙hr	8.70	5.25	4.55	6.03	8.88
Variation	СО	g/bhp∙hr	4.66	1.42	0.56	0.40	0.74
	PM	g/bhp∙hr	0.83	0.40	0.18	0.08	0.10

Potential Site Variation Values

Generator Set Model	DQKAF
Engine Model	QSK60-G14
Fuel Rating	6816
Emissions Level	Tier 2

			I	SO Standb	y	
	%	10	25	50	75	100
Generator Set Load	kWe	225	563	1125	1688	2250
Engine Load	hp	328	820	1640	2459	3280
Fuel Consumption	gal/hr	26.8	48	88	121	154
				_		
	// /	0.20	0.45	0.07	0.00	0.04

Nominal	HC	g/bhp∙hr	0.39	0.15	0.07	0.02	0.04
	NOx	g/bhp∙hr	6.69	4.04	3.50	4.64	6.83
	СО	g/bhp∙hr	2.33	0.71	0.28	0.20	0.37
	PM	g/bhp∙hr	0.33	0.16	0.07	0.03	0.04

	HC	g/bhp∙hr	0.66	0.26	0.12	0.03	0.07
Potential	NOx	g/bhp∙hr	8.70	5.25	4.55	6.03	8.88
Variation	СО	g/bhp∙hr	4.66	1.42	0.56	0.40	0.74
	PM	g/bhp∙hr	0.83	0.40	0.18	0.08	0.10

18" exhaust outlet	
188" exhaust	
height	



Exhaust emission data sheet 2250DQKAF

60 Hz Diesel generator set EPA NSPS stationary emergency

Engine information:			
Model:	Cummins Inc. QSK60-G14 NR2	Bore:	6.25 in. (159 mm)
Туре:	4 Cycle, 60° V, 16 cylinder diesel	Stroke:	7.48 in. (190 mm)
Aspiration:	Turbocharged and low temperature after-cooled (2 pump/2 loop)	Displacement:	3673 cu. in. (60.2 liters)
Compression ratio:	14.5:1		
Emission control device:	Turbocharged with low temperature after-cooler		

	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>Full</u>	<u>Full</u>
Performance data	<u>Standby</u>	Standby	<u>Standby</u>	Standby	<u>Prime</u>
BHP @ 1800 RPM (60 Hz)	820	1640	2459	3280	2655
Fuel consumption (Gal/Hr)	48	88	121	154	129
Exhaust gas flow (CFM)	6594	11190	14174	16546	14760
Exhaust gas temperature (°F)	727	821	855	895	864
Exhaust emission data					
HC (Total unburned hydrocarbons)	0.15	0.07	0.02	0.04	0.02
NOx (Oxides of nitrogen as NO2)	4.04	3.5	4.64	6.83	5.03
CO (Carbon monoxide)	0.71	0.28	0.2	0.37	0.2
PM (Particular matter)	0.16	0.07	0.03	0.04	0.03
SO2 (Sulfur dioxide)	0.005	0.005	0.005	0.004	0.005
Smoke (Bosch)	0.55	0.31	0.17	0.25	0.17
				All values are Grams	per HP-Hour

Test conditions

Data is representative of steady-state engine speed (\pm 25 RPM) at designated genset loads. Pressures, temperatures, and emission rates were stabilized.

Fuel specification:	ASTM D975 No. 2-D diesel fuel with ULSD, and 40-48 cetane number.
Fuel temperature	99 \pm 9 °F (at fuel pump inlet)
Intake air temperature:	77 ± 9 °F
Barometric pressure:	29.6 ± 1 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb dry air
Reference standard:	ISO 8178

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.

Generator Set Data Sheet



Model:	DQKAN
Frequency:	60 Hz
Fuel Type:	Diesel
kW Rating:	2500 Standby
Emissions Level:	EPA NSPS Stationary Emergency Tier 2

Exhaust emission data sheet:	EDS-1153
Exhaust emission compliance sheet:	EPA-1223
Sound performance data sheet:	MSP-1189
Cooling performance data sheet:	MCP-269
Prototype test summary data sheet:	PTS-315
Standard set-mounted radiator cooling outline:	A054H274

Fuel Consumption	kW (kV	/A)		
Ratings	2500 (3	3125)		
Load	1/4	1/2	3/4	Full
US gph	50.6	91.1	133.6	173.1
L/hr	191.5	344.9	505.7	655.3

Engine

Engine modelQSK60-G19 NR2ConfigurationCast iron, V 16 cylinderAspirationTurbocharged and low temperature after-cooledGross engine power output, kWm (bhp)2715 (3640)BMEP at set rated load, kPa (psi)3007 (436)Bore, mm (in.)159 (6.25)Stroke, mm (in.)190 (7.48)Rated speed, rpm1800Piston speed, m/s (ft/min)11.4 (2243)Compression ratio14.5:1	Engine manufacturer	Cummins Inc.
ConfigurationCast iron, V 16 cylinderAspirationTurbocharged and low temperature after-cooledGross engine power output, kWm (bhp)2715 (3640)BMEP at set rated load, kPa (psi)3007 (436)Bore, mm (in.)159 (6.25)Stroke, mm (in.)190 (7.48)Rated speed, rpm1800Piston speed, m/s (ft/min)11.4 (2243)Compression ratio14.5:1	Engine model	QSK60-G19 NR2
AspirationTurbocharged and low temperature after-cooledGross engine power output, kWm (bhp)2715 (3640)BMEP at set rated load, kPa (psi)3007 (436)Bore, mm (in.)159 (6.25)Stroke, mm (in.)190 (7.48)Rated speed, rpm1800Piston speed, m/s (ft/min)11.4 (2243)Compression ratio14.5:1	Configuration	Cast iron, V 16 cylinder
Gross engine power output, kWm (bhp) 2715 (3640) BMEP at set rated load, kPa (psi) 3007 (436) Bore, mm (in.) 159 (6.25) Stroke, mm (in.) 190 (7.48) Rated speed, rpm 1800 Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	Aspiration	Turbocharged and low temperature after-cooled
BMEP at set rated load, kPa (psi) 3007 (436) Bore, mm (in.) 159 (6.25) Stroke, mm (in.) 190 (7.48) Rated speed, rpm 1800 Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	Gross engine power output, kWm (bhp)	2715 (3640)
Bore, mm (in.) 159 (6.25) Stroke, mm (in.) 190 (7.48) Rated speed, rpm 1800 Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	BMEP at set rated load, kPa (psi)	3007 (436)
Stroke, mm (in.) 190 (7.48) Rated speed, rpm 1800 Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	Bore, mm (in.)	159 (6.25)
Rated speed, rpm 1800 Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	Stroke, mm (in.)	190 (7.48)
Piston speed, m/s (ft/min) 11.4 (2243) Compression ratio 14.5:1	Rated speed, rpm	1800
Compression ratio 14.5:1	Piston speed, m/s (ft/min)	11.4 (2243)
	Compression ratio	14.5:1
Lube oil capacity, L (qt) 378 (400)	Lube oil capacity, L (qt)	378 (400)
Overspeed limit, rpm 2070	Overspeed limit, rpm	2070
Regenerative power, kW 207	Regenerative power, kW	207

Fuel Flow

Maximum fuel flow, L/hr (US gph)	1105 (292)
Maximum fuel inlet restriction, clean/dirty, kPa (in Hg)	16.9 (5) / 30 (9)
Maximum fuel inlet temperature, °C (°F)	71 (160)

Air

Combustion air, m ³ /min (scfm)	193 (6829)
Maximum air cleaner restriction, clean/dirty, kPa (in H_2O)	1.3 (7) / 5.3 (20.6)
Alternator cooling air, m ³ /min (cfm)	222 (7840)

Exhaust

Exhaust flow at set rated load, m3/min (cfm)	517 (18269)
Exhaust temperature, °C (°F)	551 (1022)
Maximum back pressure, kPa (in H ₂ O)	7.4 (30)

Standard Set-Mounted Radiator Cooling

Ambient design, °C (°F)	48 (118)
Fan load, kW _m (HP)	54 (72)
Coolant capacity (with radiator), L (US gal)	681.4 (180)
Cooling system air flow, m ³ /min (scfm)	2649 (93550)
Total heat rejection, MJ/min (Btu/min)	88.4 (83894)
Maximum cooling air flow static restriction, kPa (in H_2O)	0.12 (0.5)

Weights¹

	1
Unit dry weight kgs (lbs)	22887 (50457)
Unit wet weight kgs (lbs)	23299 (51366)

¹ Weights represent a set with standard features. See outline drawing for weights of other configurations.

Derating Factors

Full rated power available up to 300 m (1000 ft.) at ambient temperature up to 43 °C (110 °F). Above these elevations, derate at 5% per 300 m (1000 ft.) and 12% per 10 °C (18 °F).

Ratings Definitions

Emergency Standby Power (ESP): Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. Emergency Standby Power (ESP) is in accordance with ISO 8528. Fuel Stop power in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.

Alternator Da	ata
----------------------	-----

Voltage	Connection ¹	Temp rise degree C ²	Duty	Max surge kVA⁴	Winding No.	Alternator data sheet	Feature code
380	Wye, 3-phase	105	S	13024	13	ADS-531	B408-2
416	Wye, 3-phase	80	S	28176	12	ADS-532	B734-2
416	Wye, 3-phase	80	Р	13283	12	ADS-531	B715-2
416	Wye, 3-phase	105	S	13283	12	ADS-531	B715-2
440	Wye, 3-phase	80	S	14781	12	ADS-532	B688-2
440	Wye, 3-phase	80	Р	13204	12	ADS-531	B664-2
440	Wye, 3-phase	105	S	13204	12	ADS-531	B664-2
480	Wye, 3-phase	80	S	13204	12	ADS-531	B601-2
480	Wye, 3-phase	80	S/P	14781	12	ADS-532	B903-2
600	Wye, 3-phase	80	S	12426	7	ADS-531	B604-2
600	Wye, 3-phase	80	S/P	14781	7	ADS-532	B904-2
4160	Wye, 3-phase	80	S	11185	51	ADS-545	B605-2
4160	Wye, 3-phase	80	S/P	15662	51	ADS-587	B905-2
12470	Wye, 3-phase	80	S	13438	91	ADS-534	B607-2
12470	Wye, 3-phase	105	S	11213	91	ADS-533	B568-2
13200	Wye, 3-phase	80	S	13438	91	ADS-534	B807-2
13200	Wye, 3-phase	105	S	11213	91	ADS-533	B501-2
13800	Wye, 3-phase	80	S	11213	91	ADS-533	B610-2
13800	Wye, 3-phase	80	S/P	13438	91	ADS-534	B909-2

Notes:

¹ Limited single phase capability is available from some three phase rated configurations. To obtain single phase rating, multiply the three phase kW rating by the Single Phase Factor². All single phase ratings are at unity power factor.

² Also capable of 105/125/150 °C temp rise.

³ Factor for the Single Phase Output from Three Phase Alternator formula listed below.

⁴ Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

Formulas for Calculating Full Load Currents:

Three phase output	Single phase output
kW x 1000	kW x SinglePhaseFactor x 1000
Voltage x 1.73 x 0.8	Voltage

Warning: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.

For more information contact your local Cummins distributor or visit power.cummins.com



Our energy working for you."

©2019 Cummins Inc. All rights reserved. Cummins is a registered trademark of Cummins Inc. PowerCommand, AmpSentry, InPower and "Our energy working for you." are trademarks of Cummins Inc. Other company, product, or service names may be trademarks or service marks of others. Specifications are subject to change without notice. NAD-5919-EN PD00000134 (8/19)



Exhaust emission data sheet 2500DQKAN

60 Hz Diesel generator set EPA NSPS stationary emergency

Engine information:			
Model:	Cummins Inc. QSK60-G19 NR2	Bore:	6.25 in. (159 mm)
Туре:	4 Cycle, 60° V, 16 cylinder diesel	Stroke:	7.48 in. (189 mm)
Aspiration:	Turbocharged and low temperature after-cooled (2 pump/2 loop)	Displacement:	3673 cu. in. (60.1 liters)
Compression ratio:	14:5:1		
Emission control device:	Turbocharged with low temperature after-cooler		

	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>Full</u>			
Performance data	Standby	<u>Standby</u>	<u>Standby</u>	<u>Standby</u>			
BHP @ 1800 RPM (60 Hz)	910	1820	2730	3640			
Fuel consumption (Gal/Hr)	50.6	91.1	133.6	173.1			
Exhaust gas flow (CFM)	6482.0	10902.0	15122.0	18269.0			
Exhaust gas temperature (°F)	849.0	939.0	981.0	1022.0			
Exhaust emission data							
HC (Total unburned hydrocarbons)	0.15	0.08	0.05	0.04			
NOx (Oxides of nitrogen as NO2)	3.76	3.90	4.43	6.12			
CO (Carbon monoxide)	0.81	0.52	0.63	0.75			
PM (Particular matter)	0.17	0.09	0.10	0.10			
SO2 (Sulfur dioxide)	0.005	0.005	0.005	0.004			
Smoke (Bosch)	0.70	0.50	0.57	0.60			
All values are Grams per HP-Hou							

Test conditions

Data is representative of steady-state engine speed (\pm 25 RPM) at designated genset loads. Pressures, temperatures, and emission rates were stabilized.

Fuel specification:	ASTM D975 No. 2-D diesel fuel with ULSD, and 40-48 cetane number.
Fuel temperature	99 \pm 9 °F (at fuel pump inlet)
Intake air temperature:	77 ± 9 °F
Barometric pressure:	29.6 ± 1 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb dry air
Reference standard:	ISO 8178

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.



2019 EPA Tier 2 Exhaust Emission Compliance Statement 2500DQKAN Stationary Emergency

60 Hz Diesel generator set

Compliance Information:

 The engine used in this generator set complies with Tier 2 emissions limit of U.S. EPA New Source Performance

 Standards for stationary emergency engines under the provisions of 40 CFR 60 Subpart IIII when tested per ISO8178

 D2.

 Engine Manufacturer:
 Cummins Inc.

EPA Certificate Number:	KCEXL060.AAD-021
Effective Date:	10/01/2018
Date Issued:	10/01/2018
EPA Engine Family (Cummins Emissions Family):	KCEXL060.AAD

Engine information:

Model:	QSK60-G19 NR2
Engine Nameplate HP:	3640
Туре:	4 cycle, 60°V, 16 Cylinder Diesel
Aspiration:	Turbocharged and Low Temperature Aftercooled (2P/2L)
Emission control device:	Electronic Control

6.25 in. (159 mm) 7.48 in. (190 mm) 3673 cu. in. (60.2 liters) 14.5:1

Diesel Fuel Emissions Limits

D2 Cycle Exhaust Emissions	Gram	ns per BH	<u>IP-hr</u>	<u>Grams per kW_m-hr</u>			
	<u>NO_X +</u> NMHC	<u>co</u>	<u>PM</u>	<u>NO_X +</u> <u>NMHC</u>	<u>co</u>	<u>PM</u>	
Test Results	4.2	0.75	0.10	5.6	1.0	0.14	
EPA Emissions Limit	4.8	2.6	0.15	6.4	3.5	0.20	

Test methods: EPA nonroad emissions recorded per 40CFR89 (ref. ISO8178-1) and weighted at load points prescribed in Subpart E, Appendix A for constant speed engines (ref. ISO8178-4, D2)

Diesel fuel specifications: Cetane number: 40-48. Reference: ASTM D975 No. 2-D, 300-500 ppm Sulfur.

Reference conditions: Air inlet temperature: 25°C (77°F), Fuel inlet temperature: 40°C (104°F). Barometric pressure: 100 kPa (29.53 in Hg), Humidity: 10.7 g/kg (75 grains H2O/lb) of dry air; required for NOx correction, Restrictions: Intake restriction set to a maximum allowable limit for clean filter; Exhaust back pressure set to a maximum allowable limit.

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.



	1	2					1				
		ĒC	REL NO	REV	NO	REVISION PRODUCTION RELEASE		DWN Slo	ckd DEM	APVD D.MALONE	DATE
			NUTES:					- 0			
			I. DIM	1 E N 3		IS SHOWN IN []	ARE IN INCH	-5.		N 4 T 4	
			2. ALL	. D		ISIONS ARE REFEI	RENCE BASED (ON C	AD	DAIA.	
			3. PR() ()e f	LEXIBLE CONDUI	TO CONTROL	ВОХ	•		
			4. GEN	ISE	T SF	IIPPED FILLED W	ITH OIL.				
			5. SUF	PL	IED	FUEL HOSE:					
			5.1	.F V	FUEL VITH	INLET HOSE 24	5 [I] X I27 EXTERNAL FIT) [5 TING	0]	LONG	
			5.2	2. F V	FUEL VITH	OUTLET HOSE 3/4-14 NPT EX	16 [.6] X 1 [ERNAL FITTI	270 NG.	[50] LONG	
			6. CON	IMON	N RE	FERENCE POINT (ON GENSET SK	ID ()	
			POI	NTS	s T(ANCHORING HOL	ON SKID. (3	SHEE	3)	
			7. FOF	8 C	OF	G VALUE SEE SHI	ET 2.				
			-E X H A U S	ΤO	UTL	ΕT					
							ATOR HEATER	CON		τιων	
		\square					TERMINAL BO)X			
		N 9		$\left[\right]$	<u>; </u>		A	•			
									1		
				(0)				1. 2	\downarrow	—RTD INTER	FACE
								م. ا			
								0			
					F				/		
				\geq	J 116					3	
										2	
	OIL DRAIN-									2	
	OIL DRAIN						GENSET CON	TROI		2	
	OIL DRAIN COOLANT HEATER ERFACE OUTLINE FOR DETAILS						GENSET CON	TROL		2	
	OIL DRAIN COOLANT HEATER RFACE OUTLINE FOR DETAILS						-GENSET CON	TROL		2	
R NAL (INTE	OIL DRAIN OIL DRAIN COOLANT HEATER ERFACE OUTLINE FOR DETAILS LEFT S	SIDE					-GENSET CON	TROL		2	
	OIL DRAIN OIL DRAIN COOLANT HEATER ERFACE OUTLINE FOR DETAILS LEEST OTHERWISE SPECIFIED, ALL						GENSET CON	TROL	RG	ENERATION	
ER NAL (INTE X ± .X ±	OIL DRAIN OIL DRAIN COOLANT HEATER ERFACE OUTLINE FOR DETAILS LESS OTHERWISE SPECIFIED, ALL IMENSIONS ARE IN MILLIMETERS - U.O.O. 4.99 + 0.15/-0.08 5.00 - 9.99 + 0.20/-0.10 - U.O. 17.49 + 0.25/-0.13	SIDE		6. C 0. M 0. M	SVO ALO ALO		GENSET CON	TROL	R G		<u> </u>
ER NAL (NAL (NTE NTE X ± XX± ANG TOL	OIL DRAIN OIL DRAIN OIL DRAIN COOLANT HEATER ERFACE OUTLINE FOR DETAILS LESS OTHERWISE SPECIFIED, ALL IMMENSIONS ARE IN MILLIMETERS - 0.00-4.99 +0.15/-0.08 5.00-9.99 +0.20/-0.10 10.00-17.49 +0.25/-0.13 17.50-24.99 +0.30/-0.13 SCALE THIS DOCUMENT (AND THE INFORMATION	SIDE	DWN C CKD CKD C DATE (DATE (DATE (S. C D. M D. M D. M D. M D. M D. M D. M D. M	SVO ALO ALO CI5	D NE NE SITE CODE SITE CODE	GENSET CON	TROL Powe	R G	ENERATION	CAD SHEET



RNATOR DIM_A DIM_B GENSET WEIGHT SIZE C.G. DIM_B DRY KGS DRY LBS WET KGS WET LBS 30X 3239 937.25 22887 50457 23299 51366 ANG TOL SCALE THIS DOCUMENT (AND THE INFORMATION S UNAPPERTANA DAD PROPENTION OF ELECTRONIC FOR ANY PURPOSE WITHOUT WRITTEN	SIM TO	ISE SPECIFIED, ALL RE IN MILLIMETERS	ESS OTHERWI	UNL	TABULATION						
SIZE C.G. DRY KGS DRY LBS WET KGS WET LBS 30X 3239 937.25 22887 50457 23299 51366 + - 1:20 Instruction of the second of the seco	8 DO).00- 4.99 +0.15/-0.0	. <u>0</u>	X ± -		WEIGHT	GENSET		DIM_B	DIM_A	NATOR
30X 3239 937.25 22887 50457 23299 51366 ANG TOL SCALE THIS DOCUMENT (AND PROPERTARY AND SHORTARY AN	3).00-17.49 +0.25/-0.1	· · · · · · · · · · · · · · · · · · ·		WET LBS	WET KGS	DRY LBS	DRY KGS	C.G.	C.G.	SIZE
\pm - I:20 IN HARD COPY OR ELECTRONIC FORM, REP USED FOR ANY PURPOSE WITHOUT WRITTEN	TION SHO	THIS DOCUMENT (AND THE INFORMA CONFIDENTIAL AND PROPRIETARY AND	SCALE	ANG TOL	51366	23299	50457	22887	937.25	3239	3 O X
	N, REPRO	IN HARD COPY OR ELECTRONIC FOR USED FOR ANY PURPOSE WITHOUT W	I:20	± -							



Drawing Name: A054H275 Revision: A Part Name: A054H274 Revision: A

Potential Site Variation Values

Generator Set Model	DQKAN
Engine Model	QSK60-G19
Fuel Rating	FR60448
Emissions Level	Tier 2

					SO Standby	y	
Generator Set Load		%	10	25	50	75	100
		kWe	250	625	1250	1875	2500
Engine Load		hp	364	910	1820	2730	3640
Fuel Consumption		gal/hr	26.8	50.6	91.1	133.6	173.1
	HC	g/bhp∙hr	0.35	0.15	0.08	0.05	0.04
Nominal	NOx	g/bhp∙hr	4.64	3.76	3.90	4.43	6.12
Nominal	СО	g/bhp∙hr	1.63	0.81	0.52	0.63	0.75
	PM	g/bhp·hr	0.28	0.17	0.09	0.10	0.10

	HC	g/bhp∙hr	0.60	0.26	0.14	0.09	0.07
Potential	NOx	g/bhp∙hr	6.03	4.89	5.07	5.76	7.96
Variation	СО	g/bhp∙hr	3.26	1.62	1.04	1.26	1.50
	PM	g/bhp∙hr	0.70	0.43	0.23	0.25	0.25

Potential Site Variation Values

Generator Set Model	DQKAN
Engine Model	QSK60-G19
Fuel Rating	FR60448
Emissions Level	Tier 2

					SO Standb	y	
Conceptor Cat Load		%	10	25	50	75	100
Generator	Set Loau	kWe	250	625	1250	1875	2500
Engine Load		hp	364	910	1820	2730	3640
Fuel Consumption		gal/hr	26.8	50.6	91.1	133.6	173.1
	HC	g/bhp∙hr	0.35	0.15	0.08	0.05	0.04
Nominal	NOx	g/bhp∙hr	4.64	3.76	3.90	4.43	6.12
	СО	g/bhp∙hr	1.63	0.81	0.52	0.63	0.75
	PM	g/bhp∙hr	0.28	0.17	0.09	0.10	0.10

	HC	g/bhp∙hr	0.60	0.26	0.14	0.09	0.07
Potential	NOx	g/bhp∙hr	6.03	4.89	5.07	5.76	7.96
Variation	СО	g/bhp∙hr	3.26	1.62	1.04	1.26	1.50
	PM	g/bhp∙hr	0.70	0.43	0.23	0.25	0.25

Exhaust height 188"
18" outlet



Exhaust emission data sheet 2500DQKAN

60 Hz Diesel generator set EPA NSPS stationary emergency

Engine information:			
Model:	Cummins Inc. QSK60-G19 NR2	Bore:	6.25 in. (159 mm)
Туре:	4 Cycle, 60° V, 16 cylinder diesel	Stroke:	7.48 in. (189 mm)
Aspiration:	Turbocharged and low temperature after-cooled (2 pump/2 loop)	Displacement:	3673 cu. in. (60.1 liters)
Compression ratio:	14:5:1		
Emission control device:	Turbocharged with low temperature after-cooler		

	<u>1/4</u>	<u>1/2</u>	<u>3/4</u>	<u>Full</u>
Performance data	<u>Standby</u>	<u>Standby</u>	<u>Standby</u>	<u>Standby</u>
BHP @ 1800 RPM (60 Hz)	910	1820	2730	3640
Fuel consumption (Gal/Hr)	50.6	91.1	133.6	173.1
Exhaust gas flow (CFM)	6482.0	10902.0	15122.0	18269.0
Exhaust gas temperature (°F)	849.0	939.0	981.0	1022.0
Exhaust emission data				
HC (Total unburned hydrocarbons)	0.15	0.08	0.05	0.04
NOx (Oxides of nitrogen as NO2)	3.76	3.90	4.43	6.12
CO (Carbon monoxide)	0.81	0.52	0.63	0.75
PM (Particular matter)	0.17	0.09	0.10	0.10
SO2 (Sulfur dioxide)	0.005	0.005	0.005	0.004
Smoke (Bosch)	0.70	0.50	0.57	0.60
			All values are Grams	per HP-Hour

Test conditions

Data is representative of steady-state engine speed (\pm 25 RPM) at designated genset loads. Pressures, temperatures, and emission rates were stabilized.

Fuel specification:	ASTM D975 No. 2-D diesel fuel with ULSD, and 40-48 cetane number.
Fuel temperature	99 \pm 9 °F (at fuel pump inlet)
Intake air temperature:	77 ± 9 °F
Barometric pressure:	29.6 ± 1 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb dry air
Reference standard:	ISO 8178

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.





Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
- The generator set and its components are prototype-tested, factory-built, and production-tested.
- The 60 Hz generator set offers a UL 2200 listing.
- The generator set accepts rated load in one step.
- The 60 Hz generator set meets NFPA 110, Level 1, when equipped with the necessary accessories and installed per NFPA standards.
- A standard three-year or 1000-hour limited warranty for standby applications. Five-year basic, five-year comprehensive, and ten-year extended limited warranties are also available.
- A standard two-year or 8700-hour limited warranty for prime power applications.
- Other features:
 - Kohler designed controllers for one-source system integration and remote communication. See Controller on page 4.
 - The low coolant level shutdown prevents overheating (standard on radiator models only).

KDxxxx designates a generator set with a Tier 2 EPA-Certified engine. KDxxxx-F designates a 60 Hz generator set with a fuel optimized engine.

Ratings Range

		00112
Standby:	kW	2210-2250
-	kVA	2762-2812
Prime:	kW	1980-2040
	kVA	2475-2550

General Specifications

Orderable Generator Model Number	GMKD2250
Manufacturer	Kohler
Engine: model	KD62V12
Alternator Choices	KH05790TO4D KH06220TO4D KH06930TO4D KH07000TO4D KH07630TO4D KH07770TO4D KH08100TO4D KH08430TO4D KH08270TO4D
Performance Class	Per ISO 8528-5
One Step Load Acceptance	100%
Voltage	Wye, 600 V., 4160 V, or 6600- 13800 V
Controller	APM802
Fuel Tank Capacity, L (gal.)	8577-16383 (2266-4328)
Fuel Consumption, L/hr (gal./hr) 100% at Standby	632 (167.1)
Fuel Consumption, L/hr (gal./hr) 100% at Prime Power	592 (156.5)
Emission Level Compliance (KDxxxx)	Tier 2
Open Unit Noise Level @ 7 m dB(A) at Rated Load	_
Data Center Continuous (DCC) Rating (Refer to TIB-101 for definitions)	Same as the Prime Rating below

Generator Set Ratings

				150°C Standby	Rise Rating	130°C Standby	Rise Rating	125°C Prime F	Rise lating	105°C Prime F	Rise Rating
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps	kW/kVA	Amps	kW/kVA	Amps
KH05790TO4D	277/480	3	60	2250/2812	3383	2250/2812	3383	2040/2550	3068	2040/2550	3068
KH06930TO4D	277/480	3	60	2250/2812	3383	2250/2812	3383	2040/2550	3068	2040/2550	3068
	220/380	3	60	2250/2812	4273	2210/2762	4197	2040/2550	3875	1980/2475	3761
KH07770TO4D	240/416	3	60	2250/2812	3903	2250/2812	3903	2040/2550	3540	2040/2550	3540
	347/600	3	60	2250/2812	2706	2250/2812	2706	2040/2550	2454	2040/2550	2454
	220/380	3	60	2250/2812	4273	2250/2812	4273	2040/2550	3874	2040/2550	3874
	240/416	3	60	2250/2812	3903	2250/2812	3903	2040/2550	3540	2040/2550	3540
KH08430TO4D	277/480	3	60	2250/2812	3383	2250/2812	3383	2040/2550	3068	2040/2550	3068
	347/600	3	60	2250/2812	2706	2250/2812	2706	2040/2550	2454	2040/2550	2454
	2400/4160	3	60	2250/2812	391	2250/2812	391	2040/2550	354	2040/2550	354
KH07000TO4D	347/600	3	60	2250/2812	2706	2250/2812	2706	2040/2550	2454	2040/2550	2454
	2400/4160	3	60	2250/2812	391	2250/2812	391	2040/2550	354	2040/2550	354
KH06220TO4D	2400/4160	3	60	2250/2812	391	2250/2812	391	2040/2550	354	2000/2500	347

RATINGS: All three-phase units are rated at 0.8 power factor. *Standby Ratings:* The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. *Prime Power Ratings:* At varying load, the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-8528-1 and ISO-3046-1. For limited running time and continuous ratings, consult the factory. Obtain technical information bulletin (TIB-101) for ratings guidelines, complete ratings definitions, and iside condition derates. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever.



				130°C Standby	Rise Rating	105°C Prime I	Rise Rating
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps
	3810/6600	3	60	2250/2812	246	2040/2550	224
	7200/12470	3	60	2250/2812	131	2040/2550	119
KH07630104D	7620/13200	3	60	2250/2812	123	2040/2550	112
	7970/13800	3	60	2250/2812	118	2040/2550	107
	3810/6600	3	60	2250/2812	246	2040/2550	224
	7200/12470	3	60	2250/2812	131	2040/2550	119
KH08100104D	7620/13200	3	60	2250/2812	123	2040/2550	112
	7970/13800	3	60	2250/2812	118	2040/2550	107
1/1 1000 70 TO 4 D	3810/6600	3	60	2250/2812	246	2040/2550	224
	7200/12470	3	60	2250/2812	131	2040/2550	119
KHU92/0104D	7620/13200	3	60	2250/2812	123	2040/2550	112
	7970/13800	3	60	2250/2812	118	2040/2550	107

Engine Specifications	60 Hz	Fuel Consumption	60 Hz	
Manufacturer	Kohler	Diesel, Lph (gph) at % load	Standby Rating	
Engine: model	KD62V12	100%	632 (167.1)	
Engine: type	4-Cycle, Turbocharged,	75%	518 (136.9)	
	Intercooled	50%	360 (95.2)	
Cylinder arrangement	12-V	25%	210 (55.4)	
Displacement, L (cu. in.)	62 (3783)	Diesel, Lph (qph) at % load	Prime Rating	
Bore and stroke, mm (in.)	175 x 215 (6.89 x 8.46)	100%	592 (156.5)	
Compression ratio	16.0:1	75%	463 (122.2)	
Piston speed, m/min. (ft./min.)	774 (2539)	50%	333 (87.9)	
Main bearings: quantity, type	7, Precision Half Shells	05%	000 (67.9) 000 (67.7)	
Rated rpm	1800	25%	203 (33.7)	
Max. power at rated rpm, kWm (BHP)	2500 (3352)	Radiator System	60 Hz	
Cylinder head material	Cast Iron	Ambient temperature, °C (°F)*	50 (122)	
Crankshaft material	Steel	Engine jacket water capacity, L (gal.)	356 (94)	
Valve (exhaust) material	Steel	Radiator system capacity, including	0.40 (170)	
Governor: type, make/model	KODEC Electronic Control	engine, L (gal.)	643 (170)	
Frequency regulation, no-load to-full load	Isochronous	Engine jacket water now, Lpm (gpm)	2082 (550)	
Frequency regulation, steady state	±0.25%	kW, dry exhaust, kW (Btu/min.)	820 (46632)	
Frequency	Fixed	Charge cooler water flow, Lpm (gpm)	662 (174)	
Air cleaner type, all models	Dry	Heat rejected to charge cooling water at		
Lubricating System	60 Hz	rated kw, dry exnaust, kw (Btu/min.) Water pump type	730 (41514) Centrifugal	
Туре	Full Pressure	Fan diameter, including blades, mm (in.)	2434 (96)	
Oil pan capacity with filter (initial fill),		Fan, kWm (HP)	90 (120.7)	
L (qt.) §	335 (354)	Max. restriction of cooling air, intake and		
Oil filter: quantity, type §	6, Cartridge	discharge side of radiator, kPa (in. H ₂ O)	0.125 (0.5)	
Oil cooler	Water-Cooled	* Enclosure with enclosed silencer reduce	s ambient temperature	
§ Kohler recommends the use of Kohler	Genuine oil and filters.	capability by 5°C (9°F).		
Fuel System	60 Hz	Remote Radiator System [†]	60 Hz	
Fuel supply line, min, ID, mm (in.)	25 (1.0)	Exhaust manifold type	Dry	
Fuel return line, min, ID, mm (in,)	19 (0.75)	Connection sizes:	Class 150 ANSI Flange	
Max, fuel flow, I ph (aph)	848 (224 0)	Water inlet/outlet, mm (in.)	216 (8.5) Bolt Circle	
Min./max. fuel pressure at engine supply	070 (227.0)	Intercooler inlet/outlet, mm (in.)	178 (7.0) Bolt Circle	
connection, kPa (in. Hg)	- 30/30 (- 8.8/8.8)	Static nead allowable above engine, kPa (ft. H ₂ O)	70 (23.5)	
Max. return line restriction, kPa (in. Hg)	30 (8.9)	Contact your local distributor for cooling	system options and	
Fuel filter: quantity, type	2, Primary Engine Filter 2, Fuel/Water Separator	specifications based on your specific requirements.		

Recommended fuel

G5-586 (KD2250) 5/19e Page 2

#2 Diesel ULSD



Exhaust System	60 Hz
Exhaust flow at rated kW, m ³ /min. (cfm)	536 (18928)
Exhaust temperature at rated kW at 25°C (77°F) ambient, dry exhaust, °C (°F)	510 (950)
Maximum allowable back pressure, kPa (in. Hg)	8.5 (2.5)
Exh. outlet size at eng. hookup, mm (in.)	See ADV drawing
Electrical System	60 Hz
Battery charging alternator:	
Ground (negative/positive)	Negative
Volts (DC)	24
Ampere rating	140
Starter motor qty. at starter motor power rating, rated voltage (DC)	Standard: 2 @ 9 kW, 24
Battery, recommended cold cranking amps (CCA):	
Quantity, CCA rating each, type (with standard starters)	4, 1110, AGM
Battery voltage (DC)	12
Air Requirements	60 Hz
Radiator-cooled cooling air, m³/min. (scfm)‡	2549 (90000)
Cooling air required for generator set when equipped with city water cooling or remote radiator, based on 14°C (25°E)	
rise. $m^3/min.$ (scfm)‡	1002 (35385)
Combustion air, m ³ /min. (cfm)	191 (6745)
Heat rejected to ambient air:	
Engine, kW (Btu/min.)	120 (6824)
Alternator, kW (Btu/min.)	160 (9099)
, , , ,	× /

‡ Air density = 1.20 kg/m³ (0.075 lbm/ft³)

Alternator	· Specifications	60 Hz		
Туре		4-Pole, Rotating-Field		
Exciter typ	e	Brushless, Permanent- Magnet Pilot Exciter		
Voltage reg	gulator	Solid-State, Volts/Hz		
Insulation:		NEMA MG1, UL 1446, Vacuum Pressure Impregnated (VPI)		
Mater	rial	Class H, Synthetic, Nonhygroscopic		
Temp	erature rise	130°C, 150°C Standby		
Bearing: q	uantity, type	1 or 2, Sealed		
Coupling ty	уре	Flexible Disc or Coupling		
Amortisseu	ur windings	Full		
Alternator	winding type (up to 600 V)	Random Wound		
Alternator	winding type (above 600 V)	Form Wound		
Rotor bala	ncing	125%		
Voltage reg	gulation, no-load to full-load	±0.25%		
Unbalance	d load capability	100% of Rated Standby Current		
Peak moto	r starting kVA:	(35% dip for voltages below)		
480 V	KH05790TO4D	5225		
480 V	KH06930TO4D	5990		
480 V	KH08430TO4D	9908		

Alternator Standard Features

- The pilot-excited, permanent magnet (PM) alternator provides superior short-circuit capability.
- All models are brushless, rotating-field alternators.
- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Superior voltage waveform from two-thirds pitch windings and skewed stator.
- Brushless alternator with brushless pilot exciter for excellent load response.

NOTE: See TIB- 102 Alternator Data Sheets for alternator application data and ratings, efficiency curves, voltage dip with motor starting curves, and short circuit decrement curves.



Controller



APM802 Controller

Provides advanced control, system monitoring, and system diagnostics for optimum performance and compatibility.

- Graphic display with touch screen and menu control provide easy local data access
- Measurements are selectable in metric or English units
- User language is selectable
- Two USB ports allow connection of a flash drive, mouse, or keypad
- Electrical data, mechanical data, and system settings can be saved to a flash drive
- Ethernet port allows connection to a PC type computer or Ethernet switch
- The controller supports Modbus® RTU and TCP protocols
- NFPA 110 Level 1 capability

Refer to G6-152 for additional controller features and accessories.

Modbus® is a registered trademark of Schneider Electric.

Codes and Standards

- Engine-generator set is designed and manufactured in facilities certified to ISO 9001.
- Generator set meets NEMA MG1, BS5000, ISO, DIN EN, and IEC standards, NFPA 110.
- Engine generator set is tested to ISO 8528-5 for transient response.
- The generator set and its components are prototype-tested, factory-built, and production-tested.

Third-Party Compliance

• Tier 2 EPA-Certified for Stationary Emergency Applications

Available Approvals and Listings

- California OSHPD Approval
- CSA Certified
- IBC Seismic Certification
- UL 2200 Listing
- CUL Listing (fuel tanks only)
- Florida Dept. of Environmental Protection (FDEP) Compliance (fuel tanks only)

Warranty Information

- A standard three-year or 1000-hour limited warranty for standby applications. Five-year basic, five-year comprehensive, and ten-year extended limited warranties are also available.
- A standard two-year or 8700-hour limited warranty for prime power applications.

Available Warranties for Standby Applications

- 5-Year Basic Limited Warranty
- 5-Year Comprehensive Limited Warranty
- 10-Year Major Components Limited Warranty



Standard Features	Eucl Sustem
 Closed Crankcase Ventilation (CCV) Filters 	
Customer Connection	Restriction Gauge (for fuel/water separator)
Fan Bearing Grease Extension	
Fuel/Water Separator	Literature
Generator Heater	General Maintenance
 Local Emergency Stop Switch 	NFPA 110
 Oil Drain and Coolant Drain Extension 	Overhaul
Operation and Installation Literature	Production
Spring Isolation Under the Skid	Miscellaneous
Available Options	Air Cleaner, Heavy Duty
Engine Type	Air Cleaner Restriction Indicator
KDxxxx Tier 2 EPA-Certified Engine	Engine Eluids (oil and coolant) Added
KDxxxx-F Fuel Optimized Engine	
Approvals and Listings	
	Electrical Package (Requires Enclosure selection)
CSA Certified	Basic Electrical Package (select 1 Ph or 3 Ph)
	Wire Battery Charger (1 Ph)
	Wire Block Heater (select 1 Ph or 3 Ph)
old 2200 Listing fuel tanks only)	Wire Controller Heater (1 Ph)
Elorida Dept. of Environmental Protection (EDEP) Compliance	Wire Generator Heater (1 Ph)
(fuel tanks only)	Warranty (Standby Applications only)
Enclosed Unit	5-Year Basic Limited Warranty
Sound Level 1 Enclosure/Fuel Tank Package	5-Year Comprehensive Limited Warranty
Sound Level 2 Enclosure/Fuel Tank Package	10-Year Major Components Limited Warranty
	Other
Exhaust Silencer, Critical (kits: PA-354880 qty. 3)	
Exhaust Silencer, Hospital (kits: PA-354900 qty. 3)	_
Flexible Exhaust Connector, Stainless Steel	
Controller	
Input/Output, Analog	
Input/Output, Digital	
Input/Output, Harness	
Input/Output, Thermocouple (standard on 4160 V and above)	
Load Shed	
Manual Key Switch	
Remote Emergency Stop	
Remote Serial Annunciator Panel	
Cooling System	
Block Heater; 9000 W. 208 V. (Select 1 Ph or 3 Ph) *	Dimensions and Weights
Block Heater; 9000 W, 240 V. (Select 1 Ph or 3 Ph) *	Overall Size max 1 x W x H mm (in): 6057 x 2852 x 2307
Block Heater: 9000 W. 380 V. 3 Ph *	(273.9 x 112.3 x 130.2)
Block Heater: 9000 W. 480 V. (Select 1 Ph or 3 Ph) *	Weight, radiator model, max. wet, kg (lb.): 27033 (59598)
* Required for Ambient Temperatures Below 10°C (50°F) and	
DIOCK neater kit includes air intake manifold grid heater	
Electrical System	
Battery, AGM (kit with qty. 4)	
Battery Charger	
Battery Heater; 100 W, 120 V, 1Ph	
Battery Rack and Cables	
Bus Bar	
Line Circuit Breaker (select right or left side mounting)	
Line Circuit Breaker with Shunt Trip (select right or left side mtg	g) L

NOTE: This drawing is provided for reference only and should not be used for planning installation. Contact your local distributor for more detailed information. G5-586 (KD250) 5/19e Page 5



KOHLER CO., Kohler, Wisconsin 53044 USA Phone 920-457-4441, Fax 920-459-1646 For the nearest sales and service outlet in the US and Canada, phone 1-800-544-2444 KOHLERPower.com

Sound Enclosures and Subbase Fuel Tank

Sound Level 1 Enclosure Standard Features

- Lift base or tank-mounted, aluminum construction enclosure with internal-mounted, exhaust silencers.
- Every enclosure has a sloped roof to reduce the buildup of moisture and debris.
- Sound attenuated enclosure that offers noise reduction using acoustic insulation, acoustic-lined air inlets and an acoustic-lined air discharge.
- Fade-, scratch-, and corrosion-resistant Kohler[®]
 Power Armor[™] automotive-grade textured finish.
- Acoustic insulation that meets UL 94 HF1 flammability classification.
- Enclosure has large access doors that are hinged and removable which allow for easy maintenance.
- Lockable, flush-mounted door latches.
- Air inlet louvers reduce rain and snow entry.
- High wind bracing, 241 kph (150 mph).

Sound Level 2 Enclosure Standard Features

- Includes all of the sound level 1 enclosure features with the addition of up to 51 mm (2 in.) acoustic insulation material, intake sound baffles, vertical air discharge, and secondary silencers.
- Louvered air inlet and vertical outlet hood with 90 degree angles to redirect air and reduce noise.

Subbase Fuel Tank Features

- The fuel tank has a Power Armor Plus[™] textured epoxy-based rubberized coating.
- The above-ground rectangular secondary containment tank mounts directly to the generator set, below the generator set skid (subbase).
- Both the inner and outer tanks have UL-listed emergency relief vents.
- Flexible fuel lines are provided with subbase fuel tank selection.
- The containment tank's construction protects against fuel leaks or ruptures. The inner (primary) tank is sealed inside the outer (secondary) tank. The outer tank contains the fuel if the inner tank leaks or ruptures.
- The above ground secondary containment subbase fuel tank meets UL 142 requirements.
- Features include:
 - $\,\circ\,$ Additional fittings for optional accessories (qty. 3)
 - $\circ~$ Electrical stub-up area open to bottom
 - $\circ~$ Emergency inner and outer tank relief vents
 - $\,\circ\,$ Fuel fill with lockable cap and 51 mm (2 in.) riser
 - Fuel leak detection switch
 - $\,\circ\,$ Fuel level mechanical gauge
 - Fuel level sender
 - Normal vent
 - Removable engine supply and return diptubes



Sound Level 1 Enclosure (Shown with available spill containment)



(Shown with available spill containment)



Subbase Fuel Tank (Top View)

۵	DISTRIBU	JTED B	SY:	 	

© 2016, 2017, 2019 by Kohler Co. All rights reserved.



KD2250

60 Hz. Diesel Generator Set Tier 2 EPA Certified for Stationary Emergency Applications EMISSION OPTIMIZED DATA SHEET

ENGINE INFORMATION								
Model:	KD62V12	Bore:	175 mm (6.89 in.)					
Туре:	4-Cycle, 12-V Cylinder	Stroke:	215 mm (8.46 in.)					
Aspiration:	Turbocharged, Intercooled	Displacement:	62 L (3783 cu. in.)					
Compression ratio:	16:0:1							
Emission Control Device: Direct Diesel Injection, Engine Control Module, Turbocharger, Charge Air Cooler								

NOMINAL EMISSION DATA								
Cycle point	100% ESP	75% ESP	50% ESP	25% ESP	10% ESP			
Power [kW]	2500	1875	1250	625	250			
Speed [rpm]	1800	1800	1800	1800	1800			
Exhaust Gas Flow [kg/h]	15017	14404	9978	5904	4042			
Exhaust Gas Temperature [C]	451	447	450	453	390			
NO _x [g/kWh]	7.6	4.7	4.9	5.1	8.2			
CO [g/kWh]	0.4	0.8	0.7	2.5	5.3			
HC [g/kWh]	0.12	0.13	0.19	0.30	0.70			
PM [g/kWh]	0.05	0.12	0.09	0.32	0.19			

NOLI	O EXCEED	EMISSION DATA	
	T		

Cycle point	100% ESP	75% ESP	50% ESP	25% ESP	10% ESP
NO _x [g/kWh]	9.0	5.6	5.8	6.1	9.7
CO [g/kWh]	1.3	2.6	2.2	8.1	10.9
HC [g/kWh]	0.14	0.15	0.22	0.35	0.89
PM [g/kWh]	0.07	0.18	0.13	0.47	0.28

TEST METHODS AND CONDITIONS

Test Methods:

Steady-State emissions recorded per EPA CFR 40 Part 89, and ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rated stabilized.

Fuel Specification:

40-48 Cetane Number, 0.05 Wt. % max. Sulfur; Reference ISO8178-5, 40CFR86.1313-98 Type 2-D and ASTM D975 No. 2-D.

Reference Conditions:

25 °C (77 °F) Air Inlet Temperature, 40 °C (104 °F) Fuel Inlet Temperature, 100 kPa (29.53 in Hg) Barometric Pressure; 10.7 g/kg (75 grains H2O/lb.) of dry air Humidity (required for NOx correction); Intake Restriction set to maximum allowable limit for clean filter; Exhaust Back pressure set to maximum allowable limit.

Data was taken from a single engine test according to the test methods, fuel specification and reference conditions stated above and is subjected to instrumentation and engine-to-engine variability. Tests conducted with alternate test methods, instrumentation, fuel or reference conditions can yield different results.

Data and specifications subject to change without notice.





Standard Features

- Kohler Co. provides one-source responsibility for the generating system and accessories.
- The generator set and its components are prototype-tested, factory-built, and production-tested.
- The 60 Hz generator set offers a UL 2200 listing.
- The generator set accepts rated load in one step.
- The 60 Hz generator set meets NFPA 110, Level 1, when equipped with the necessary accessories and installed per NFPA standards.
- A standard three-year or 1000-hour limited warranty for standby applications. Five-year basic, five-year comprehensive, and ten-year extended limited warranties are also available.
- A standard two-year or 8700-hour limited warranty for prime power applications.
- Other features:
 - Kohler designed controllers for one-source system integration and remote communication. See Controller on page 4.
 - The low coolant level shutdown prevents overheating (standard on radiator models only).

KDxxxx designates a generator set with a Tier 2 EPA-Certified engine. KDxxxx-F designates a 60 Hz generator set with a fuel optimized engine.

Ratings Range

U		60 Hz
Standby:	kW kVA	2250-2500 2812-3125
Prime:	kW kVA	2050-2270 2562-2838

General Specifications

Orderable Generator Model Number	GMKD2500
Manufacturer	Kohler
Engine: model	KD62V12
Alternator Choices	KH06930TO4D KH07000TO4D KH07770TO4D KH08100TO4D KH08430TO4D KH09270TO4D
Performance Class	Per ISO 8528-5
One Step Load Acceptance	100%
Voltage	Wye, 600 V., 4160 V, or 6600- 13800 V
Controller	APM802
Fuel Tank Capacity, L (gal.)	8577-16383 (2266-4328)
100% at Standby	651 (172.0)
Fuel Consumption, L/hr (gal./hr) 100% at Prime Power	626 (165.3)
Emission Level Compliance (KDxxxx)	Tier 2
Open Unit Noise Level @ 7 m dB(A) at Rated Load	_
Data Center Continuous (DCC) Rating (Refer to TIB-101 for definitions)	Same as the Prime Rating below

Generator Set Ratings

				150°C Rise Standby Rating		130°C Rise Standby Rating		125°C Rise Prime Rating		105°C Rise Prime Rating	
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps	kW/kVA	Amps	kW/kVA	Amps
KH06930TO4D	277/480	3	60	2500/3125	3759	2500/3125	3759	2270/2838	3414	2190/2738	3294
KH07000TO4D	347/600	3	60	2500/3125	3008	2500/3125	3008	2270/2838	2731	2250/2812	2706
	2400/4160	3	60	2500/3125	434	2500/3125	434	2270/2838	394	2250/2812	391
	277/480	3	60	2500/3125	3759	2500/3125	3759	2270/2838	3414	2270/2838	3414
KH07770TO4D	347/600	3	60	2500/3125	3008	2500/3125	3008	2270/2838	2731	2270/2838	2731
	2400/4160	3	60	2500/3125	434	2500/3125	434	2270/2838	394	2270/2838	394
	240/416	3	60	2500/3125	4338	2500/3125	4338	2270/2838	3939	2270/2838	3939
KH08430TO4D	277/480	3	60	2500/3125	3759	2500/3125	3759	2270/2838	3414	2270/2838	3414
	347/600	3	60	2500/3125	3008	2500/3125	3008	2270/2838	2731	2270/2838	2731
	2400/4160	3	60	2500/3125	434	2500/3125	434	2270/2838	394	2270/2838	394

RATINGS: All three-phase units are rated at 0.8 power factor. Standby Ratings: The standby rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. *Prime Power Ratings:* At varying load, the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve. Ratings are in accordance with ISO-8528-1 and ISO-3046-1. For limited running time and continuous ratings, consult the factory. Obtain technical information bulletin (TIB-101) for ratings guidelines, complete ratings definitions, and site condition derates. The generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever.

KOHLER

Industrial Diesel Generator Set - KD2500 Tier 2 EPA-Certified for Stationary Emergency Applications

				130°C Rise Standby Rating		105°C Rise Prime Rating		
Alternator	Voltage	Ph	Hz	kW/kVA	Amps	kW/kVA	Amps	
KH08100TO4D	3810/6600	3	60	2500/3125	274	2270/2838	249	
	7200/12470	3	60	2250/2812	131	2050/2562	119	
	7620/13200	3	60	2380/2975	131	2180/2725	120	
	7970/13800	3	60	2500/3125	131	2270/2838	119	
KH09270TO4D	3810/6600	3	60	2500/3125	274	2270/2838	249	
	7200/12470	3	60	2500/3125	145	2270/2838	132	
	7620/13200	3	60	2500/3125	137	2270/2838	125	
	7970/13800	3	60	2500/3125	131	2270/2838	119	

Engine Specifications	60 Hz	Fuel Consumption	60 Hz		
Manufacturer	Kohler	Diesel, Lph (gph) at % load	Standby Rating		
Engine: model	KD62V12	100%	651 (172.0)		
Engine: type	4-Cycle, Turbocharged,	75%	572 (151.0)		
Cylinder arrangement	Intercooled 12-V	50% 25%	389 (102.8) 222 (58.7)		
Displacement, L (cu. in.)	62 (3783)	Diesel, Lph (gph) at % load	Prime Rating		
Bore and stroke, mm (in.)	175 x 215 (6.89 x 8.46)	100%	626 (165.3)		
Compression ratio	16.0:1	75%	492 (130.0)		
Piston speed, m/min. (ft./min.)	774 (2539)	50%	359 (04.7)		
Main bearings: quantity, type	7, Precision Half Shells	50 /6 0E9/	338 (94.7) 004 (52.0)		
Rated rpm	1800	25%	204 (53.8)		
Max. power at rated rpm, kWm (BHP)	2700 (3621)	Radiator System	60 Hz		
Cylinder head material	Cast Iron	Ambient temperature, °C (°F)*	50 (122)		
Crankshaft material	Steel	Engine jacket water capacity, L (gal.)	356 (94)		
Valve (exhaust) material	Steel	Radiator system capacity, including			
Governor: type, make/model	KODEC Electronic Control	engine, L (gal.)	643 (170)		
Frequency regulation, no-load to-full load	Isochronous	Engine jacket water flow, Lpm (gpm)	2082 (550)		
Frequency regulation, steady state	±0.25%	kW. drv exhaust, kW (Btu/min.)	870 (49476)		
Frequency	Fixed	Charge cooler water flow, Lpm (gpm)	662 (174)		
Air cleaner type, all models	Dry	Heat rejected to charge cooling water at			
Lubricating System	60 H-	rated kW, dry exhaust, kW (Btu/min.)	760 (43220)		
		Water pump type	Centrifugal		
Туре	Full Pressure	Fan diameter, including blades, mm (in.)	2434 (96)		
Oil pan capacity with filter (initial fill), L (qt.) \S	335 (354)	Fan, kWm (HP) Max, restriction of cooling air, intake and	90 (120.7)		
Oil filter: quantity, type § 6, Cartridge		discharge side of radiator, kPa (in. H_2O)	0.125 (0.5)		
Oil cooler § Kohler recommends the use of Kohler	Water-Cooled r Genuine oil and filters.	* Enclosure with enclosed silencer reduces capability by 5°C (9°F).	ambient temperature		
First Overteen		Remote Radiator Svstem⁺	60 Hz		

Fuel System	60 Hz
Fuel supply line, min. ID, mm (in.)	25 (1.0)
Fuel return line, min. ID, mm (in.)	19 (0.75)
Max. fuel flow, Lph (gph)	881 (232.7)
Min./max. fuel pressure at engine su connection, kPa (in. Hg)	upply - 30/30 (- 8.8/8.8)
Max. return line restriction, kPa (in.	Hg) 30 (8.9)
Fuel filter: quantity, type	2, Primary Engine Filter 2, Fuel/Water Separator
Recommended fuel	#2 Diesel ULSD

75%	492 (130.0)
50%	358 (94.7)
25%	204 (53.8)
Radiator System	60 Hz
Ambient temperature, °C (°F)*	50 (122)
Engine jacket water capacity, L (gal.)	356 (94)
Radiator system capacity, including engine, L (gal.)	643 (170)
Engine jacket water flow, Lpm (gpm)	2082 (550)
Heat rejected to cooling water at rated kW, dry exhaust, kW (Btu/min.)	870 (49476)
Charge cooler water flow, Lpm (gpm)	662 (174)
Heat rejected to charge cooling water at rated kW, dry exhaust, kW (Btu/min.)	760 (43220)
Water pump type	Centrifugal
Fan diameter, including blades, mm (in.)	2434 (96)
Fan, kWm (HP)	90 (120.7)
Max. restriction of cooling air, intake and discharge side of radiator, kPa (in. H_2O)	0.125 (0.5)
* Enclosure with enclosed silencer reduce capability by 5°C (9°F).	es ambient temperature
Remote Radiator System [‡]	60 Hz
Exhaust manifold type	Dry
Connection sizes:	Class 150 ANSI Flange

	Diy
Connection sizes:	Class 150 ANSI Flange
Water inlet/outlet, mm (in.)	216 (8.5) Bolt Circle
Intercooler inlet/outlet, mm (in.)	178 (7.0) Bolt Circle
Static head allowable above engine, kPa (ft. H ₂ O)	70 (23.5)

 $\ensuremath{^\dagger}$ Contact your local distributor for cooling system options and specifications based on your specific requirements.



Exhaust System	60 Hz
Exhaust flow at rated kW, m ³ /min. (cfm)	579 (20447)
Exhaust temperature at rated kW at 25°C (77°F) ambient, dry exhaust, °C (°F)	500 (932)
Maximum allowable back pressure, kPa (in. Hg)	8.5 (2.5)
Exh. outlet size at eng. hookup, mm (in.)	See ADV drawing
Electrical System	60 Hz
Battery charging alternator:	
Ground (negative/positive)	Negative
Volts (DC)	24
Ampere rating	140
Starter motor qty. at starter motor power rating, rated voltage (DC)	Standard: 2 @ 9 kW, 24
Battery, recommended cold cranking amps (CCA):	
Quantity, CCA rating each, type (with standard starters)	4, 1110, AGM
Battery voltage (DC)	12
Air Requirements	60 Hz
Radiator-cooled cooling air, m ³ /min. (scfm)‡	2549 (90000)
Cooling air required for generator set when equipped with city water cooling or remote radiator, based on 14°C (25°E)	
rise. $m^3/min.$ (scfm)‡	1116 (39398)
Combustion air, m ³ /min. (cfm)	208 (7345)
Heat rejected to ambient air:	()
Engine, kW (Btu/min.)	150 (8530)
Alternator, kW (Btu/min.)	160 (9099)
, , , ,	

‡ Air density = 1.20 kg/m³ (0.075 lbm/ft³)

Alternator	Specifications	60 Hz			
Туре		4-Pole, Rotating-Field			
Exciter type	9	Brushless, Permanent- Magnet Pilot Exciter			
Voltage reg	ulator	Solid-State, Volts/Hz			
Insulation:		NEMA MG1, UL 1446, Vacuum Pressure Impregnated (VPI)			
Materi	al	Class H, Synthetic, Nonhygroscopic			
Tempe	erature rise	130°C, 150°C Standby			
Bearing: qu	antity, type	1 or 2, Sealed			
Coupling ty	ре	Flexible Disc or Coupling			
Amortisseu	r windings	Full			
Alternator v	vinding type (up to 600 V)	Random Wound			
Alternator v	vinding type (above 600 V)	Form Wound			
Rotor balar	icing	125%			
Voltage reg	ulation, no-load to full-load	±0.25%			
Unbalanced	d load capability	100% of Rated Standby Current			
Peak motor starting kVA:		(35% dip for voltages below)			
480 V	KH06930TO4D	5990			
480 V	KH07770TO4D	7170			
480 V	KH08430TO4D	9908			

Alternator Standard Features

- The pilot-excited, permanent magnet (PM) alternator provides superior short-circuit capability.
- All models are brushless, rotating-field alternators.
- NEMA MG1, IEEE, and ANSI standards compliance for temperature rise and motor starting.
- Sustained short-circuit current of up to 300% of the rated current for up to 10 seconds.
- Sustained short-circuit current enabling downstream circuit breakers to trip without collapsing the alternator field.
- Self-ventilated and dripproof construction.
- Superior voltage waveform from two-thirds pitch windings and skewed stator.
- Brushless alternator with brushless pilot exciter for excellent load response.

NOTE: See TIB- 102 Alternator Data Sheets for alternator application data and ratings, efficiency curves, voltage dip with motor starting curves, and short circuit decrement curves.



Controller



APM802 Controller

Provides advanced control, system monitoring, and system diagnostics for optimum performance and compatibility.

- Graphic display with touch screen and menu control provide easy local data access
- Measurements are selectable in metric or English units
- User language is selectable
- Two USB ports allow connection of a flash drive, mouse, or keypad
- Electrical data, mechanical data, and system settings can be saved to a flash drive
- Ethernet port allows connection to a PC type computer or Ethernet switch
- The controller supports Modbus® RTU and TCP protocols
- NFPA 110 Level 1 capability

Refer to G6-152 for additional controller features and accessories.

Modbus® is a registered trademark of Schneider Electric.

Codes and Standards

- Engine- generator set is designed and manufactured in facilities certified to ISO 9001.
- Generator set meets NEMA MG1, BS5000, ISO, DIN EN, and IEC standards, NFPA 110.
- Engine generator set is tested to ISO 8528-5 for transient response.
- The generator set and its components are prototype-tested, factory-built, and production-tested.

Third-Party Compliance

• Tier 2 EPA-Certified for Stationary Emergency Applications

Available Approvals and Listings

- California OSHPD Approval
- CSA Certified
- IBC Seismic Certification
- UL 2200 Listing
- CUL Listing (fuel tanks only)
- Florida Dept. of Environmental Protection (FDEP) Compliance (fuel tanks only)

Warranty Information

- A standard three-year or 1000-hour limited warranty for standby applications. Five-year basic, five-year comprehensive, and ten-year extended limited warranties are also available.
- A standard two-year or 8700-hour limited warranty for prime power applications.

Available Warranties for Standby Applications

- 5-Year Basic Limited Warranty
- 5-Year Comprehensive Limited Warranty
- 10-Year Major Components Limited Warranty



Standard Features	Eucl Sustem
 Closed Crankcase Ventilation (CCV) Filters 	
Customer Connection	Restriction Gauge (for fuel/water separator)
Fan Bearing Grease Extension	
Fuel/Water Separator	Literature
Generator Heater	General Maintenance
 Local Emergency Stop Switch 	NFPA 110
 Oil Drain and Coolant Drain Extension 	Overhaul
Operation and Installation Literature	Production
Spring Isolation Under the Skid	Miscellaneous
Available Options	Air Cleaner, Heavy Duty
Engine Type	Air Cleaner Restriction Indicator
KDxxxx Tier 2 EPA-Certified Engine	Engine Eluids (oil and coolant) Added
KDxxxx-F Fuel Optimized Engine	
Approvals and Listings	
	Electrical Package (Requires Enclosure selection)
CSA Certified	Basic Electrical Package (select 1 Ph or 3 Ph)
	Wire Battery Charger (1 Ph)
	Wire Block Heater (select 1 Ph or 3 Ph)
old 2200 Listing fuel tanks only)	Wire Controller Heater (1 Ph)
Elorida Dept. of Environmental Protection (EDEP) Compliance	Wire Generator Heater (1 Ph)
(fuel tanks only)	Warranty (Standby Applications only)
Enclosed Unit	5-Year Basic Limited Warranty
Sound Level 1 Enclosure/Fuel Tank Package	5-Year Comprehensive Limited Warranty
Sound Level 2 Enclosure/Fuel Tank Package	10-Year Major Components Limited Warranty
	Other
Exhaust Silencer, Critical (kits: PA-354880 qty. 3)	
Exhaust Silencer, Hospital (kits: PA-354900 qty. 3)	_
Flexible Exhaust Connector, Stainless Steel	
Controller	
Input/Output, Analog	
Input/Output, Digital	
Input/Output, Harness	
Input/Output, Thermocouple (standard on 4160 V and above)	
Load Shed	
Manual Key Switch	
Remote Emergency Stop	
Remote Serial Annunciator Panel	
Cooling System	
Block Heater; 9000 W. 208 V. (Select 1 Ph or 3 Ph) *	Dimensions and Weights
Block Heater; 9000 W, 240 V. (Select 1 Ph or 3 Ph) *	Overall Size max 1 x W x H mm (in): 6057 x 2852 x 2307
Block Heater: 9000 W. 380 V. 3 Ph *	(273.9 x 112.3 x 130.2)
Block Heater: 9000 W. 480 V. (Select 1 Ph or 3 Ph) *	Weight, radiator model, max. wet, kg (lb.): 27033 (59598)
* Required for Ambient Temperatures Below 10°C (50°F) and	
DIOCK NEATER KIT INCIUDES AIR INTAKE MANIFOLD GRID heater	
Electrical System	
Battery, AGM (kit with qty. 4)	
Battery Charger	
Battery Heater; 100 W, 120 V, 1Ph	
Battery Rack and Cables	
Bus Bar	
Line Circuit Breaker (select right or left side mounting)	
Line Circuit Breaker with Shunt Trip (select right or left side mtg	g) L

NOTE: This drawing is provided for reference only and should not be used for planning installation. Contact your local distributor for more detailed information. G5-587 (KD2500) 5/19d Page 5



KOHLER CO., Kohler, Wisconsin 53044 USA Phone 920-457-4441, Fax 920-459-1646 For the nearest sales and service outlet in the US and Canada, phone 1-800-544-2444 KOHLERPower.com

Sound Enclosures and Subbase Fuel Tank

Sound Level 1 Enclosure Standard Features

- Lift base or tank-mounted, aluminum construction enclosure with internal-mounted, exhaust silencers.
- Every enclosure has a sloped roof to reduce the buildup of moisture and debris.
- Sound attenuated enclosure that offers noise reduction using acoustic insulation, acoustic-lined air inlets and an acoustic-lined air discharge.
- Fade-, scratch-, and corrosion-resistant Kohler[®]
 Power Armor[™] automotive-grade textured finish.
- Acoustic insulation that meets UL 94 HF1 flammability classification.
- Enclosure has large access doors that are hinged and removable which allow for easy maintenance.
- Lockable, flush-mounted door latches.
- Air inlet louvers reduce rain and snow entry.
- High wind bracing, 241 kph (150 mph).

Sound Level 2 Enclosure Standard Features

- Includes all of the sound level 1 enclosure features with the addition of up to 51 mm (2 in.) acoustic insulation material, intake sound baffles, vertical air discharge, and secondary silencers.
- Louvered air inlet and vertical outlet hood with 90 degree angles to redirect air and reduce noise.

Subbase Fuel Tank Features

- The fuel tank has a Power Armor Plus[™] textured epoxy-based rubberized coating.
- The above-ground rectangular secondary containment tank mounts directly to the generator set, below the generator set skid (subbase).
- Both the inner and outer tanks have UL-listed emergency relief vents.
- Flexible fuel lines are provided with subbase fuel tank selection.
- The containment tank's construction protects against fuel leaks or ruptures. The inner (primary) tank is sealed inside the outer (secondary) tank. The outer tank contains the fuel if the inner tank leaks or ruptures.
- The above ground secondary containment subbase fuel tank meets UL 142 requirements.
- Features include:
 - $\,\circ\,$ Additional fittings for optional accessories (qty. 3)
 - $\circ~$ Electrical stub-up area open to bottom
 - $\circ~$ Emergency inner and outer tank relief vents
 - $\,\circ\,$ Fuel fill with lockable cap and 51 mm (2 in.) riser
 - Fuel leak detection switch
 - Fuel level mechanical gauge
 - Fuel level sender
 - Normal vent
 - Removable engine supply and return diptubes



Sound Level 1 Enclosure (Shown with available spill containment)



Sound Level 2 Enclosure (Shown with available spill containment)

0 0 0	 · · ·	•	•	 · ·
∎=*°, •, •, •, •, •, •, •, •, •, •, •, •, •, •	 		•	 •

Subbase Fuel Tank (Top View)

ſ	DISTRIBL	JTED B	Y:		

© 2016, 2017, 2019 by Kohler Co. All rights reserved.



KD2500

60 Hz. Diesel Generator Set Tier 2 EPA Certified for Stationary Emergency Applications EMISSION OPTIMIZED DATA SHEET

ENGINE INFORMATION						
Model:	KD62V12	Bore:	175 mm (6.89 in.)			
Туре:	4-Cycle, 12-V Cylinder	Stroke:	215 mm (8.46 in.)			
Aspiration:	Turbocharged, Intercooled	Displacement:	62 L (3783 cu. in.)			
Compression ratio: 16:0:1						
Emission Control Device:	Direct Diesel Injection, Engine Control Module, To	urbocharger, Char	ge Air Cooler			

Cycle point 100% ESP 75% ESP 50% ESP 25% ESP 10% ES							
Power [kW]	2700	2025	1350	675	270		
Speed [rpm]	1800	1800	1800	1800	1800		
Exhaust Gas Flow [kg/h]	15085	15390	10714	6183	4140		
Exhaust Gas Temperature [C]	456	464	447	464	404		
NO _X [g/kWh]	9.5	4.5	4.9	5.0	6.6		
CO [g/kWh]	0.3	1.2	0.7	2.6	4.1		
HC [g/kWh]	0.12	0.10	0.18	0.29	0.70		
PM [g/kWh]	0.06	0.16	0.12	0.34	0.38		

Cycle point	100% ESP	75% ESP	50% ESP	25% ESP	10% ESP	
NO _X [g/kWh]	11.2	5.3	5.7	5.9	7.8	
CO [g/kWh]	1.0	3.5	1.9	7.4	8.3	
HC [g/kWh]	0.14	0.12	0.21	0.34	0.84	
PM [g/kWh]	0.10	0.20	0.15	0.40	0.45	

TEST METHODS AND CONDITIONS

Test Methods:

Steady-State emissions recorded per EPA CFR 40 Part 89, and ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rated stabilized.

Fuel Specification:

40-48 Cetane Number, 0.05 Wt. % max. Sulfur; Reference ISO8178-5, 40CFR86.1313-98 Type 2-D and ASTM D975 No. 2-D.

Reference Conditions:

25 °C (77 °F) Air Inlet Temperature, 40 °C (104 °F) Fuel Inlet Temperature, 100 kPa (29.53 in Hg) Barometric Pressure; 10.7 g/kg (75 grains H2O/lb.) of dry air Humidity (required for NOx correction); Intake Restriction set to maximum allowable limit for clean filter; Exhaust Back pressure set to maximum allowable limit.

Data was taken from a single engine test according to the test methods, fuel specification and reference conditions stated above and is subjected to instrumentation and engine-to-engine variability. Tests conducted with alternate test methods, instrumentation, fuel or reference conditions can yield different results.

Data and specifications subject to change without notice.
PACKAGE DATA	[C09DE	[48]	OCTOBER 14, 201						
			For Help Desk Phone Numbers <u>Click her</u>						
Feature Code:	C09DE48	Rating Type:	STANDBY	Sales model Package:	PGS300				
Engine Sales Model:	C9	Engine Arrangement Number:	4529685	Hertz:	60				
EKW W/F:	300.0	Noise Reduction:	0 dBA	Back Pressure:	0.0 inH2O				
, Frankra Daalaana ka	f								
Engine Package in	itormatio	n							

igine Package

Engine Package Data

Package Cooling Information

SA Level 2 Canopy Cooling Data

% Load	Airflow Rate scfm	Ambient Capability Sea Level (Deg F)	Ambient Capability 300 m (Deg F)	Ambient Capability 600 m (Deg F)	Ambient Capability 900 m (Deg F)
100.0	12395	114	111	107	104
75.0	12395	132	129	125	122

Package Sound Information

Sound Comments :

https://tmiwebclassic.cat.com/tmi/servlet/TMIDirector?&Action=rdbutton&refkind=RNT... 10/14/2019

SA Level 2 Canopy Sound Data

EKW W/F	% LOAD	OVERALL SOUND DB(A)	OBCF 63HZ DB	OBCF 125HZ DB	OBCF 250HZ DB	OBCF 500HZ DB	OBCF 1000HZ DB	OBCF 2000HZ DB	OBCF 4000HZ DB	OBCF 8000HZ DB
300.0	100.0	83.0	88.9	90.5	85.6	78.4	76.1	73.4	70.3	66.4
225.0	75.0	82.8	87.7	90.2	85.6	78.3	75.9	73.1	69.6	65.7
150.0	50.0	82.7	86.6	89.9	85.6	78.4	75.9	73.0	68.8	64.4
75.0	25.0	82.7	85.5	89.7	85.6	78.4	76.1	73.1	68.1	62.5

Distance: 23.0 Feet

Distance: 3.3 Feet

EKW W/F	% LOAD	OVERALL SOUND DB(A)	OBCF 63HZ DB	OBCF 125HZ DB	OBCF 250HZ DB	OBCF 500HZ DB	OBCF 1000HZ DB	OBCF 2000HZ DB	OBCF 4000HZ DB	OBCF 8000HZ DB
300.0	100.0	71.3	82.0	81.2	74.8	66.7	60.3	59.9	57.8	54.9
225.0	75.0	71.2	80.9	80.9	75.1	66.5	59.9	60.1	57.3	54.6
150.0	50.0	71.1	80.0	80.5	75.2	66.4	59.9	60.2	56.6	53.4
75.0	25.0	70.9	79.1	80.2	75.0	66.6	60.2	60.1	55.7	51.2

Distance: 49.2 Feet

EKW W/F	% LOAD	OVERALL SOUND DB(A)	OBCF 63HZ DB	OBCF 125HZ DB	OBCF 250HZ DB	OBCF 500HZ DB	OBCF 1000HZ DB	OBCF 2000HZ DB	OBCF 4000HZ DB	OBCF 8000HZ DB
300.0	100.0	65.3	76.0	75.2	68.8	60.7	54.3	53.9	51.8	48.9
225.0	75.0	65.2	74.9	74.9	69.1	60.5	53.9	54.1	51.3	48.6
150.0	50.0	65.1	74.0	74.5	69.2	60.4	53.9	54.2	50.6	47.4
75.0	25.0	64.9	73.1	74.2	69.0	60.6	54.2	54.1	49.7	45.2

(This Page Intentionally Left Blank)

PERFORMANCE DATA[DM8168]

Performance Number: DM8168

SALES MODEL: BRAND:	C9 CAT	COMBUSTION: ENGINE SPEED (RPM):	DIRECT INJECTION 1,800
ENGINE POWER (BHP):	480	HERTZ:	60
GEN POWER W/O FAN (EKW):	319.0	FAN POWER (HP):	36.5
GEN POWER WITH FAN (EKW):	300.0	ASPIRATION:	ТА
COMPRESSION RATIO:	16.1	AFTERCOOLER TYPE:	ATAAC
RATING LEVEL:	STANDBY	AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
PUMP QUANTITY:	1	INLET MANIFOLD AIR TEMP (F):	120
FUEL TYPE:	DIESEL	JACKET WATER TEMP (F):	192.2
MANIFOLD TYPE:	DRY	TURBO CONFIGURATION:	SINGLE
GOVERNOR TYPE:	ELEC	TURBO QUANTITY:	1
CAMSHAFT TYPE:	STANDARD	TURBOCHARGER MODEL:	S310-1.25
IGNITION TYPE:	CI	CERTIFICATION YEAR:	2005
INJECTOR TYPE:	EUI	PISTON SPD @ RATED ENG SPD (FT/MIN):	1,759.8
REF EXH STACK DIAMETER (IN):	4		
MAX OPERATING ALTITUDE (FT):	3,281		

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
300.0	100	480	393	0.332	22.7	82.5	122.6	1,247.3	60.6	927.2
270.0	90	430	352	0.334	20.5	78.7	121.1	1,179.5	55.9	877.6
240.0	80	383	314	0.339	18.5	74.9	121.5	1,120.8	51.5	840.4
225.0	75	361	295	0.342	17.6	73.0	121.6	1,094.5	49.4	826.3
210.0	70	339	277	0.347	16.8	71.0	121.7	1,071.1	47.3	817.6
180.0	60	296	242	0.360	15.2	66.4	121.7	1,028.3	43.1	800.8
150.0	50	253	207	0.376	13.6	61.1	121.7	988.0	38.7	784.5
120.0	40	212	173	0.390	11.8	52.8	121.7	944.9	32.8	768.7
90.0	30	170	139	0.403	9.8	42.5	121.6	899.1	25.9	752.9
75.0	25	149	122	0.411	8.7	36.9	121.6	875.4	22.3	745.0
60.0	20	127	104	0.419	7.6	30.8	121.6	850.8	18.7	737.0
30.0	10	82.9	68	0.441	5.2	17.9	121.5	723.0	11.7	650.3

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
300.0	100	480	83	450.8	916.6	2,460.9	3,985.8	4,144.9	872.5	798.0
270.0	90	430	80	428.0	893.4	2,306.9	3,884.5	4,028.0	848.2	780.6
240.0	80	383	76	406.4	870.9	2,173.0	3,772.3	3,902.1	821.8	760.2
225.0	75	361	74	396.1	859.8	2,109.4	3,711.7	3,835.1	806.5	747.8
210.0	70	339	72	386.3	846.8	2,047.1	3,649.5	3,766.9	788.0	732.2
180.0	60	296	67	367.7	814.1	1,926.8	3,499.4	3,605.2	751.6	701.1
150.0	50	253	62	350.2	772.8	1,810.5	3,315.8	3,410.8	715.5	669.7
120.0	40	212	54	321.8	707.1	1,643.7	3,018.0	3,100.6	657.9	617.9
90.0	30	170	43	282.8	623.3	1,424.8	2,642.8	2,711.5	577.7	544.3
75.0	25	149	38	260.3	576.0	1,299.8	2,434.3	2,495.5	530.5	500.6
60.0	20	127	31	235.4	524.5	1,162.9	2,209.5	2,262.9	477.8	451.6
30.0	10	82.9	18	178.8	412.8	851.2	1,728.1	1,764.7	377.1	358.8

Heat Rejection Data

GENSET POWER WITH	PERCENT LOAD	ENGINE	REJECTION TO JACKET	REJECTION TO	REJECTION TO EXH	EXHUAST RECOVERY	FROM OIL COOLER	FROM AFTERCOOLER	WORK	LOW HEAT VALUE	HIGH HEAT VALUE
FAN			WATER	ATMOSPHERE		TO 350F				ENERGY	ENERGY

Change Level: 04

PERFORMANCE DATA[DM8168]

October 14, 2019

EKW	%	BHP	BTU/MIN								
300.0	100	480	6,838	1,312	18,223	10,196	2,598	5,239	20,357	48,785	51,968
270.0	90	430	6,227	1,100	16,530	8,999	2,344	4,774	18,249	44,009	46,881
240.0	80	383	5,718	954	15,163	8,062	2,120	4,304	16,263	39,804	42,402
225.0	75	361	5,492	885	14,576	7,680	2,017	4,080	15,306	37,868	40,339
210.0	70	339	5,288	827	14,082	7,393	1,922	3,868	14,366	36,078	38,432
180.0	60	296	4,912	823	13,054	6,800	1,739	3,448	12,536	32,644	34,774
150.0	50	253	4,565	786	11,966	6,184	1,555	3,034	10,749	29,195	31,100
120.0	40	212	4,219	770	10,567	5,402	1,348	2,419	8,983	25,307	26,959
90.0	30	170	3,811	699	8,973	4,534	1,120	1,706	7,210	21,028	22,400
75.0	25	149	3,554	623	8,129	4,085	999	1,352	6,312	18,747	19,970
60.0	20	127	3,271	492	7,247	3,625	871	1,008	5,399	16,350	17,417
30.0	10	82.9	2,624	519	4,878	2,172	597	397	3,514	11,200	11,931

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	300.0	225.0	150.0	75.0	30.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	480	361	253	149	82.9
TOTAL NOX (AS NO2)		G/HR	2,032	1,047	539	288	217
TOTAL CO		G/HR	214	166	242	203	191
TOTAL HC		G/HR	50	54	81	76	65
PART MATTER		G/HR	30.2	29.7	66.7	43.9	28.4
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,371.7	1,572.5	1,056.2	887.0	1,244.7
TOTAL CO	(CORR 5% O2)	MG/NM3	216.0	218.7	414.7	579.4	974.9
TOTAL HC	(CORR 5% O2)	MG/NM3	43.7	62.4	119.7	182.7	276.3
PART MATTER	(CORR 5% O2)	MG/NM3	24.8	34.3	101.8	98.2	126.1
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,155	766	514	432	606
TOTAL CO	(CORR 5% O2)	PPM	173	175	332	464	780
TOTAL HC	(CORR 5% O2)	PPM	82	116	223	341	516
TOTAL NOX (AS NO2)		G/HP-HR	4.27	2.92	2.13	1.94	2.61
TOTAL CO		G/HP-HR	0.45	0.46	0.96	1.36	2.30
TOTAL HC		G/HP-HR	0.11	0.15	0.32	0.51	0.79
PART MATTER		G/HP-HR	0.06	0.08	0.26	0.29	0.34
TOTAL NOX (AS NO2)		LB/HR	4.48	2.31	1.19	0.64	0.48
TOTAL CO		LB/HR	0.47	0.37	0.53	0.45	0.42
TOTAL HC		LB/HR	0.11	0.12	0.18	0.17	0.14
PART MATTER		LB/HR	0.07	0.07	0.15	0.10	0.06

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		FKW	300.0	225.0	150.0	75.0	30.0
PERCENTIOAD		%	100	75	50	25	10
ENGINE POWER		BHP	480	361	253	149	82.9
TOTAL NOX (AS NO2)		G/HR	1,881	970	499	267	201
TOTAL CO		G/HR	115	89	129	109	102
TOTAL HC		G/HR	26	29	43	40	35
TOTAL CO2		KG/HR	225	175	135	86	51
PART MATTER		G/HR	15.5	15.2	34.2	22.5	14.6
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,196.0	1,456.1	978.0	821.3	1,152.5
TOTAL CO	(CORR 5% O2)	MG/NM3	115.5	117.0	221.7	309.8	521.3
TOTAL HC	(CORR 5% O2)	MG/NM3	23.1	33.0	63.3	96.7	146.2
PART MATTER	(CORR 5% O2)	MG/NM3	12.7	17.6	52.2	50.4	64.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,070	709	476	400	561
TOTAL CO	(CORR 5% O2)	PPM	92	94	177	248	417
TOTAL HC	(CORR 5% O2)	PPM	43	62	118	180	273
TOTAL NOX (AS NO2)		G/HP-HR	3.95	2.70	1.98	1.79	2.42
TOTAL CO		G/HP-HR	0.24	0.25	0.51	0.73	1.23
TOTAL HC		G/HP-HR	0.06	0.08	0.17	0.27	0.42
PART MATTER		G/HP-HR	0.03	0.04	0.14	0.15	0.18
TOTAL NOX (AS NO2)		LB/HR	4.15	2.14	1.10	0.59	0.44
TOTAL CO		LB/HR	0.25	0.20	0.29	0.24	0.22
TOTAL HC		LB/HR	0.06	0.06	0.09	0.09	0.08
TOTAL CO2		LB/HR	496	387	297	189	112
PART MATTER		LB/HR	0.03	0.03	0.08	0.05	0.03
OXYGEN IN EXH		%	9.2	11.2	12.6	13.6	15.0
DRY SMOKE OPACITY		%	0.3	0.4	1.0	0.8	0.8
BOSCH SMOKE NUMBER			0.07	0.20	0.90	0.76	0.68

Regulatory Information

EPA TIER 3	PA TIER 3 2005 - 2010							
GASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 89 SUBPART D AND ISO 8178 FOR MEASURING HC,								
CO, PM, AND NOX. THE "MA	CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE NON-ROAD REGULATIONS.							
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR				
U.S. (INCL CALIF)	EPA	NON-ROAD	TIER 3	CO: 3.5 NOx + HC: 4.0 PM: 0.20				
EPA EMERGENCY STATION	NARY	2011						
GASEOUS EMISSIONS DAT	A MEASUREMENTS PROVIDED	TO THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 SUI	BPART IIII AND ISO 8178 FOR MEASURING HC,				
CO, PM, AND NOX. THE "MA	AX LIMITS" SHOWN BELOW ARE	WEIGHTED CYCLE AVERAGES AND ARE I	N COMPLIANCE WITH THE EMERGENCY ST	ATIONARY REGULATIONS.				
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR				
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 4.0 PM: 0.20				

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL	
ALTITUDE (FT)														
0	480	480	480	480	480	477	474	465	452	433	412	395	478	
1,000	480	480	480	480	477	475	470	457	441	422	402	386	476	
2,000	480	480	479	477	474	470	463	446	427	410	392	376	473	
3,000	480	478	475	470	463	457	449	434	418	403	386	370	464	
4,000	475	469	463	456	450	444	436	422	407	391	374	358	453	
5,000	462	456	449	442	436	430	422	408	393	377	360	343	442	
6,000	449	442	435	428	422	416	408	394	379	362	346	329	430	
7,000	434	428	421	414	408	402	394	379	364	348	332	315	418	
8,000	420	413	406	400	394	387	380	365	350	334	318	302	406	
9,000	405	398	392	385	379	373	365	350	335	320	305	289	394	
10,000	390	384	377	371	365	359	352	337	322	307	293	278	382	
11,000	376	369	363	357	351	345	339	334	320	305	291	277	370	
12,000	361	355	348	342	337	331	326	320	315	303	288	270	357	
13,000	347	340	334	329	323	318	312	307	302	290	274	257	345	
14,000	332	326	321	315	310	304	299	294	289	276	261	246	333	
15,000	319	313	307	302	297	291	286	282	276	263	249	235	322	

Cross Reference

Test Spec	Setting	Engine Arrangement	Engineering Model	Engineering Model Version	Start Effective Serial Number	End Effective Serial Number
0K6616	NAP	2531644	GS279	-	S9L00001	
4150068	PP5547	3950369	GS279	-	S9P00001	
4150068	PP5547	4529865	GS857	LS	S9P00001	
4150068	PP5547	5664658	PG350	G	RG300001	
4150068	PP5547	5664658	PG375	G	RE300001	

Performance Parameter Reference

Parameters Reference:DM9600-11 PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600 APPLICATION: Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar

PERFORMANCE DATA[DM8168]

maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted. PERFORMANCE PARAMETER TOLERANCE FACTORS: Power +/- 3% Torque +/- 3% Exhaust stack temperature +/- 8% Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10% Exhaust flow +/- 6% Specific fuel consumption +/- 3% Fuel rate +/- 5% Specific DEF consumption +/- 3% DEF rate +/- 5% Heat rejection +/- 5% Heat rejection exhaust only +/- 10% Heat rejection CEM only +/- 10% Heat Rejection values based on using treated water. Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications. On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed These values do not apply to C280/3600. For these models, see the tolerances listed below C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5% TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque +/- 0.5% Speed +/- 0.2% Fuel flow +/- 1.0% Temperature +/- 2.0 C degrees Intake manifold pressure +/- 0.1 kPa OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS. REFERENCE ATMOSPHERIC INLET AIR FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp. FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature. MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions. REFERENCE EXHAUST STACK DIAMETER The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available. REFERENCE FUEL DIESEL Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 deg C (84.2 deg F), where the density is 838.9 G/Liter (7.001 Lbs/Gal). GAS Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas. ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust

PERFORMANCE DATA[DM8168]

Restrictions

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values

defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude

defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings. REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer. EMISSION CYCLE LIMITS:

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS 1. For constant-speed marine engines for ship main propulsion,

including,diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets

test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied.

4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied. HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500 HIGH DISPLACEMENT (HD) DEFINITIONS: 3500: EM1500 RATING DEFINITIONS: Agriculture : TM6008 Fire Pump : TM6009 Generator Set : TM6035 Generator (Gas) : TM6041 Industrial Diesel : TM6010 Industrial (Gas) : TM6040 Irrigation : TM5749 Locomotive : TM6037 Marine Auxiliary : TM6036 Marine Prop (Except 3600) : TM5747 Marine Prop (3600 only) : TM5748 MSHA : TM6042 Oil Field (Petroleum) : TM6011 Off-Highway Truck : TM6039 On-Highway Truck : TM6038 SOUND DEFINITIONS: Sound Power : DM8702

(This Page Intentionally Left Blank)

Systems Data Reference Number: DM8168

CATERPILLAR®

October 14, 2019 For Help Desk Phone Numbers <u>Click Here</u>

THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL EN TO ASSURE REGULATORY COMPLIANCE.	IISSIONS CER	TIFIED ENGINES
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH CLEAN ELEMENT		IN-H20
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH DIRTY ELEMENT		IN-H20
MAXIMUM PRESSURE DROP FROM COMPRESSOR OUTLET TO MANIFOLD INLET (OR MIXER INLET FOR EGR)	4.4	IN-HG
MAXIMUM TURBO INI FT AIR TEMPERATURE		DEG F
MAXIMUM AIR FILTER INLET AIR TEMPERATURE		DEG F
CHARGE AIR FLOW AT RATED SPEED	62.8	LB/MIN
TURBO COMPRESSOR OUTLET PRESSURE AT RATED SPEED (ABSOLUTE)	108.8	IN-HG
COOLING SYSTEM		
ENGINE ONLY COOLANT CAPACITY		GAL
MAXIMUM ALLOWABLE JACKET WATER OUTLET TEMPERATURE		DEG F
REGULATOR LOCATION FOR JW (HT) CIRCUIT		
MAXIMUM UNINTERRUPTED FILL RATE	5.0	G/MIN
MINIMUM COOLANT LOSS WITHOUT IMPACTING RADIATOR		
PERFORMANCE (PERCENT OF TOTAL)		PERCENT
COOLANT LOSS-MAXIMUM PERCENTAGE OF PUMP PRESSURE RISE		PERCENT
AIR VENT CAPABILITY AT 35% PUMP PRESSURE RISE LOSS		PT/MIN
ENGINE SPEC SYSTEM	-	
CYLINDER ARRANGEMENT	INLINE	
NUMBER OF CYLINDERS	6	
CYLINDER BORE DIAMETER		IN
PISTON STROKE		IN
TOTAL CYLINDER DISPLACEMENT		CU IN
STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END	ccw	
STANDARD CYLINDER FIRING ORDER		
NUMBER 1 CYLINDER LOCATION	FRONT	
STROKES/COMBUSTION CYCLE	4	
EXHAUST SYSTEM	1	
THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL EN TO ASSURE REGULATORY COMPLIANCE.	IISSIONS CER	TIFIED ENGINE
MAXIMUM ALLOWABLE SYSTEM BACK PRESSURE		IN-H20
MANIFOLD TIPE		
FUEL SYSTEM		
FUEL SYSTEM MAXIMUM FUEL FLOW FROM TRANSFER PUMP TO ENGINE	46.5	G/HR
FUEL SYSTEM MAXIMUM FUEL FLOW FROM TRANSFER PUMP TO ENGINE MAXIMUM ALLOWABLE FUEL SUPPLY LINE RESTRICTION	46.5	G/HR IN-HG

MAXIMUM FUEL FLOW TO RETURN LINE FROM ENGINE	29.9	G/HR
MAXIMUM ALLOWABLE FUEL RETURN LINE RESTRICTION		IN-HG
NORMAL FUEL PRESSURE IN A CLEAN SYSTEM		PSI
FUEL SYSTEM TYPE		
LUBE SYSTEM		
LUBE SYSTEM OIL COOLER TYPE	PLATE	
CRANKCASE VENTILATION TYPE		
MOUNTING SYSTEM		
CENTER OF GRAVITY LOCATION - X DIMENSION - FROM REAR FACE OF BLOCK - (REFERENCE TM7077)		IN
CENTER OF GRAVITY LOCATION - Y DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)		IN
CENTER OF GRAVITY LOCATION - Z DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)		IN
STARTING SYSTEM		
LOWEST AMBIENT START TEMPERATURE WITHOUT AIDS		DEG F

TEST SPEC [C09DE48]

OCTOBER 14, 2019

For Help Desk Phone Numbers Click here

Reference Number: 4150068

Model: C9 DI TA AAAC

Make from Spec:

Effective Serial Number: S9P02089 V

Test Spec Data							
Description	Measure	Nominal	Ceiling	Floor			
Corr Full Load Power 🥝	hp	480	485	475			
Full Load Speed 🞯	RPM	1800	1810	1790			
High Idle Speed 🞯	RPM	1945	1955	1935			
Low Idle Speed 🧐	RPM	1369	1379	1359			
FL Static Fuel Setting 🧐	in	1.007					
FT Static Fuel Setting 🞯	in	1.037					
ELS (Intercent)		-27					
		-1					
	GAL/HR	23.2	24.4	22.0			
		0.242	0.262	0.222			
CSFC 🧶		0.342	0.363	0.323			
Adjusted Boost 🧐	IN_HG	78.5	89.2	65.9			
Torque Check Speed 🥨	RPM	1650	1660	1640			
Corr Torq Rise at TC RPM 🧐	%	7.0					
Corr Torque at TC RPM 🧐	LB.FT	1,499	1,604	1,393			
C Fuel Rate at TC RPM 🧐	GAL/HR	22.2	23.3	21.1			
CSFC at TC RPM 🞯	LB/HP.H	0.334	0.356	0.313			
ADJ Boost at TC RPM 🞯	IN_HG	81.1	91.3	67.5			
Power Loss/Cvl @	% C FL PWR	21.0	27.0	10.0			
Specific Blowby @	CU FT/HP.H						
Temp Jacket Water Pump Inlet @	F	192	197	186			
Delta T lacket Water (out-in)	F	10	19	1			
	F	122	131	113			
	F	125	131	120			
		12	10	120			
Scac Water Flow		10	10	26			
Oil Pressure 🧐	PS1	49	87	26			
Oil Pressure Low Idle 🧐	PSI	50	70	32			
Fuel Pressure	PSI	84	102	59			
	PSI		4				
		86	95	26			
			1 10	20			
	F		1.10	50			
Fuel Density	DEG API		36.0	34.0			
Boost Constant		1.0	50.0				
Governor Setting Constant							
Governor Setting Torque	% RTD TRQ						
High Idle Stability	RPM						
Low Idle Stability	RPM						
Set Point RPM	RPM	1820	1830	1810			
Adjusted Boost (Gas Blending)	HG						
Corrected Fuel Rate - Diesel (Gas Blending) 🞯	GAL/HR						
Corrected Fuel Rate - Gas (Gas Blending @	BTU/MIN						
Full Load Fueling (Gas Blending) 🞯	MM3/ST						
Gas Substitution Ratio (Gas Blending) 🗐	%						
(1	1	1	1			

Corr Full Load Power (Gas Blending) ወ	НР		
Full Load Speed (Gas Blending) 🞯	RPM		
Exhaust Back Pressure	PSI		
TQ CK Exhaust Back Pressure	PSI		
Ataac Delta Pressure	PSI		

Engine Reference Information						
Description	Measure	Data				
FL Static/FT Static Fuel Settings	in	1.007 / 1.037				
Fuel Valve Part Number						
Unit Injector Part Number		5734231				
Timing Dimension Field Service	in					
Timing Dimension Factory						
Torque Control Group Number		Change Level:				
Fuel Pump/Gov Grp Part Number		3282580				
Fuel Pump Type		HUI				
Flyweight Part Number/Attitude						
		2550051 / S310-1.25VTF				
Turbo Part No and Model		2550051 / S310-1.25VTF				
Advertised Power / Governor Speed		480hp 1,800 RPM				
Compression Ratio		16.1				
Torque Rise Cam Part Number						
Manifold Type		DRY				
Engine Flash File Part Number		5781990				
Rating Number		2				
Flash File Change Number						
ASM Flash File Part Number						
ISM Flash File Part Number						
Advisor Flash File Part Number						
Secondary Module Flash File Part Number						
Messenger Flash File Part Number						
Tandem Software Flash File Part Number						
Governor Type		ELEC				

Torque Control Group Spring Data						
Part No	Thickness	Quantity				
No data found						

Torque Control Group Spacer Data						
Part No	Thickness	Quantity				
No data found						

Timing Data Mechanical Advance Part Number: Chg. Level: Advance: 0.0 DEG Dog Leg Differentials: RPM: KW:				
Description	Measure	Spec	Minimum	Maximum
Timing Static @ 0 RPM BTDC	DEG		-2.0	2.0

Application/Performance Data				
Description	Measure	Data		
Application Identification		224 GS STANDBY		
Engine Sales Model and Series		C9		
Combustion System type		DI		
Aspiration Type		ТА		
Engine Source Factory Ref Number		40		
Power Setting PL/PP Ref Number		PP5547		
Engine Perf Data Ref No and Change Level		DM8168		
Multi Engine Torq/Rating				
	1			

Emissions Family		
Generator Rating W/O Fan	EKW	319
Generator	HZ	60
Brakesaver test		
Certified Engine Rating	hp	
Engineering Model Ref		GS279 GS322
Low Idle In-Veh Speed	RPM	
Sales Model		
Machine Facility		
Usage		
Transmission		
Description		GS
Serial Number Prefixs		
Sales Model		
Machine Facility		
Usage		
Transmission		
Description		GS
Serial Number Prefixs		

Altitude Derating Information				
Description	Measure	Data		
Altitude - Maximum	FT	3,280		
Engine Power (ADV)	hp	480		
Engine Power (Test)	hp	480		
High Idle Speed	RPM	1945		
FL Static Fuel Setting	in	1.007		
FT Static Fuel Setting	in	1.037		
Corrected Fuel Rate	GAL/HR	23.2		
FL Boost Pressure	IN_HG	80.6		

Spec Number vs. Arrangement Number Cross Reference				
Arrangement	2531644	3950369	4529865	5664658

_

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 10/14/2019 9:26:08 AM © Caterpillar Inc. 2019 All Rights Reserved. <u>Data Privacy Statement</u>.

(This Page Intentionally Left Blank)

RADIATOR PERFORMANCE DATA [LS1849]

OCTOBER 14, 2019

For Help Desk Phone Numbers Click here

Component Performance Number: EM0499				
Radiator Data	Engine Data	Combination Data		
Radiator Part Number: 4490660	Performance Number: DM8168	Pully Ratio: 0.76		
Radiator Type: AS13.3CTS	Sales Model: C9	Fan Power: 22.79734 hp		
Front Area: 13.24 ft2	EKW: 300			
Radiator Dry Weight: 269.0 lbs	Rating: STANDBY			
Radiator Wet Weight: NA lbs	Speed: 1800			
Radiator Water Capacity High Temp Circuit: 6.0 gal Settings: NA				
Radiator Water Capacity Low Temp Circuit: NA gal IM ATAAC Temp Deg F: 120				
Center of Gravity (X): 0.00 in (Distance from front face of core)				
Center of Gravity (Y): 0.00 in (Distance from bottom of	f radiator support)			
Center of Gravity (Z): 0.00 in (Distance from center lin	ne of core)			

Restric	Ambient tions (1/2	inH2O)	Restric	Ambien tions (3/4	t inH2O)	Air Flow Restrictions (1/2 in H2	Air Flow (3/4 in H2O)
984 Feet	2460 Feet	4921 Feet	984 Feet	2460 Feet	4921 Feet	Restrictions (1/2 mi12	
	Max A	Ambient P	re-alarm	Deg F -			- scfm
138	132	125	134	129	122	13984	12289
						- 30,000	<u>^</u>
		CORE	COR	E		E 30,000	
		RESIS [®] inH2O	T AIRFL	OW n		Ø 25,000	
		0	0			20.000	
		0.4	6,179	.08		No. 10,000	
		0.8	9,880	.77		15,000	
		1.61	15,799	9.66			
		2.81	23,080).98		₹ 10,000	
		3.62	27,363	3.24		8 5 000 F	
		4.02	29,386	5.78		Ö 5,000 /	
		4.42	31,346	5.74			
						0 1	2 3 4
						CORE	KESIST INHZU
_							
Refei Num	rence ber: EM()499				No notes found	
Para Refei	meters rence:					No notes found	

https://tmiwebclassic.cat.com/tmi/servlet/TMIDirector?&Action=rdbutton&refkind=RNT... 10/14/2019

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 10/14/2019 9:30:45 AM © Caterpillar Inc. 2019 All Rights Reserved. <u>Data Privacy Statement</u>.

GENERATOR DATA	O CTOBER 14, 2019
	For Help Desk Phone Numbers <u>Click here</u>
Spec Info Mechanical Data Cooling Data	Motor Starting Curve Open Circuit
Zero Power Factor Curve Reactive Capa	bility Chart General Information
Selected Moo	lel
Engine: C9 Generator Frame: LC0114D Gen Fuel: Diesel Cenerator Arrangement: 4183863 Cen	set Rating (kW): 300.0 Line voltage: 460
Frequency: 60 Excitation Type: Self Excited Pwr	Factor: 0.8 Rated Current: 451.1
Duty: STANDBY Connection: SERIES STAR App	lication: EPG Status: Current
	Version:
Spec Informat	41704740470741800710392
Generator Specification	Concretor Efficiency
Frame: LC6114B Type: LC No. of Bearings: 1	Generator Efficiency
Winding Type: RANDOM WOUND Flywheel: 14.0	
Connection: SERIES STAR Housing: 1	0.5 150 92 7
Phases: 3 No. of Leads: 12	0.75 225.0 93.7
Poles: 4 Wires per Lead: 2	1.0 300.0 93.7
Sync Speed: 1800 Generator Pitch: 0.666	7
Reactances	Per Unit Ohms
SUBTRANSIENT - DIRECT AXIS X" _d	0.1156 0.0710
SUBTRANSIENT - QUADRATURE AXIS X"q	0.1567 0.0963
TRANSIENT - SATURATED X'd	0.1652 0.1015
SYNCHRONOUS - DIRECT AXIS X_d SYNCHRONOUS - OLADRATURE AXIS X	2.8/11 1.7640
NEGATIVE SEQUENCE X_2	0.1357 0.0834
ZERO SEQUENCE X_0	0.0081 0.0050
Time Constants	Seconds
OPEN CIRCUIT TRANSIENT - DIRECT AXIS	T' ₄₀ 1.7380
SHORT CIRCUIT TRANSIENT - DIRECT AXI	S T' _d 0.1000
OPEN CIRCUIT SUBSTRANSIENT - DIRECT	AXIS T" _{d0} 0.0130
SHORT CIRCUIT SUBSTRANSIENT - DIREC	Г AXIS T" _d 0.0100
OPEN CIRCUIT SUBSTRANSIENT - QUADRA	ATURE AXIS T" _{q0} 0.1100
SHORT CIRCUIT SUBSTRANSIENT - QUAD	RATURE AXIS T"q 0.0100
EXCITER TIME CONSTANT T _e	0.0300
ARMATURE SHORT CIRCUIT T _a	0.0150
Short Circuit Ratio: 0.44 Stator Resistance = 0.0163	Ohms Field Resistance = 0.768 Ohms
Voltage Regulation	Generator Excitation
Voltage level adjustment: +/- 5.0%	No Load Full Load, (rated) pf
Voltage regulation, steady state: +/- 0.5%	Series Parallel
Voltage regulation with 3% speed change: +/- 0.5% Excita	tion voltage: 10.2 Volts 41.75 Volts Volts
Waveform deviation line - line, no load: less than 2.0% Excita	ation current1.0 Amps3.37 AmpsAmps
Telephone influence factor: less than 50	

<u>Top...</u>

	Selected	Model	
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version: 41764 /40476 /41800 /10592





<u>Top...</u>

Selected Model

Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current

Version: 41764 /40476 /41800 /10592

Cooling Requirements:TemperatuHeat Dissipated:20.2 kWStator RiseAir Flow:66.0 m³/minRotor Rise			
Heat Dissipated: 20.2 kWStator RiseAir Flow:66.0 m³/minRotor Rise	re Data: (Ambient 40 ⁰ C)		
Air Flow: 66.0 m ³ /min Rotor Rise	e: 105.0 °C		
	: 105.0 ⁰ C		
Insulation Class: H			
Insulation Reg. as shipped: $100.0\ M\Omega$	minimum at 40 ⁰ C		
Thermal Limits of Generator Frequency: 60 Hz Line to Line Voltage: 480 Volts B BR 80/40 384.0 kVA F BR -105/40 436.8 kVA H BR - 125/40 480.0 kVA F PR - 130/40 480.0 kVA H PR - 150/40 508.8 kVA			

<u>Top...</u>

Selected Model			
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current
			Version: 41764 /40476 /41800 /10592

Starting Capability & Current Decrement



Motor Starting Capability (0.6 pf)

Instantaneous 3 Phase Fault Current: 3877 Amps Instantaneous Line - Line Fault Current: 3089 Amps Instantaneous Line - Neutral Fault Current: 5181 Amps

Top...

Selected Model				
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480	
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277	
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1	
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current	
			Version: 41764 /40476 /41800 /10592	

Generator Output Characteristic Curves



Open Circuit Curve

Short Circuit Curve



<u>Top...</u>

Selected Model									
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480						
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277						
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1						
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current						
			Version: 41764 /40476 /41800 /10592						

Generator Output Characteristic Curves

				2	er	0 0	ower	-
Field Surrent	Line - Line Volt	60	00			-	•	
44.3	0	1 50	00		1			
53.7	240	>			/			1
55.4	288	e 40	00 1	1				
57.3	336	·=		•				
9.9	384	7 30	00 1	•				
.0	432	U	.	*				
.9	480	. <u>5</u> 20	20 1	1				
9.4	528		. II					
0.6	576	T	⁰⁰ 1					
231.2	624			1				
			0.1	50		100	150	20
						Field	1 Curre	ont







<u>Top...</u>

Selected Model									
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480						
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277						
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1						
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current						
			Version: 41764 /40476 /41800 /10592						

Reactive Capability Curve



Operating Chart

<u>Top...</u>

Selected Model									
Engine: C9	Generator Frame: LC6114B	Genset Rating (kW): 300.0	Line Voltage: 480						
Fuel: Diesel	Generator Arrangement: 4183863	Genset Rating (kVA): 375.0	Phase Voltage: 277						
Frequency: 60	Excitation Type: Self Excited	Pwr. Factor: 0.8	Rated Current: 451.1						
Duty: STANDBY	Connection: SERIES STAR	Application: EPG	Status: Current						
			Version: 41764 /40476 /41800 /10592						

General Information

GENERATOR INFORMATION (DM7900)

1. Motor Starting

Motor starting curves are obtained in accordance with IEC60034, and are displayed at 0.6 power factor.

2. Voltage Dip

Prediction of the generator synchronous voltage dip can be made by consulting the plot for the voltage dip value that corresponds to the desired motor starting kVA value.

3. Definitions
A) Generator Keys
Frame: abbreviation of generator frame size
Freq: frequency in hertz.
PP/SB: prime/standby duty respectively
Volts: line - line terminal voltage
kW: rating in electrical kilo watts
Model: engine sales model

B) Generator Temperature Rise The indicated temperature rises are the IEC/NEMA limits for standby or prime power applications. The quoted rise figures are maximum limits only and are not necessarily indicative of the actual temperature rise of a given machine winding.

C) Centre of Gravity

The specified centre of gravity is for the generator only. For single bearing, and two bearing close coupled generators, the center of gravity is measured from the generator/engine flywheel-housing interface and from the centreline of the rotor Shaft.

For two bearing, standalone generators, the center of gravity is measured from the end of the rotor shaft and from the centerline of the rotor shaft.

D) Generator Current Decrement Curves The generator current decrement curve indicates the generator armature current arising from a symmetrical three-phase fault at the generator terminals. Generators equipped with AREP or PMG excitation systems will sustain 300% of rated armature current for 10 seconds.

E) Generator Efficiency Curves The efficiency curve is displayed for the generator only under the given conditions of rating, voltage, frequency and power factor. This is not the overall generating set efficiency curve.

Caterpillar Confidential: **Green** Content Owner: Commercial Processes Division Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: 10/14/2019 9:39:16 AM © Caterpillar Inc. 2019 All Rights Reserved. Data Privacy Statement.

(This Page Intentionally Left Blank)

DQDAC data is below.

Generator Set Model	DQDAC
Engine Model	QSL9-G7
Emissions Level	Tier 2

					SO Standby	y	
Concrator Sot L	ad	%	10	25	50	75	100
	Generator Set Load		30	75	150	225	300
Engine Load		hp	43.5	113.75	227.5	341.25	455
Fuel Consumption		gal/hr	3.34	6.82	12.23	17.65	23.07
Exhaust Gas							
Temperature		deg F	514	678	785	915	990
Exhaust Gas Flow	v	CFM	615	615 1099.6 1714.8 2118		2118.6	2279.4
	-						
	HC	g/bhp∙hr	1.72	0.25	0.129	0.052	0.046
Nominal	NOx	g/bhp∙hr	1.70	1.60	1.70	2.65	5.25
Nominal	со	g/bhp∙hr	3.13	3.20	3.17	0.73	0.30
	PM	g/bhp∙hr	0.30	0.20	0.14	0.04	0.03

Potential Site Variation	HC	g/bhp·hr	2.92	0.43	0.22	0.09	0.08
	NOx	g/bhp∙hr	2.21	2.08	2.21	3.45	6.83
	СО	g/bhp∙hr	6.26	6.40	6.34	1.46	0.60
	PM	g/bhp·hr	0.75	0.50	0.35	0.10	0.08

Engine outlet = 6"

Exhaust outlet height 114" above grade



3. ENGINE SPECIFICATIONS - AS-BUILT

Sabey Data Center Properties | Intergate Quincy Notice of Construction Trinity Consultants

PERFORMANCE DATA[DM9168]

Change Level: 02

Performance Number: DM9168

	25100	COMPLICATION	B I
SALES MODEL:	35160	COMBOSTION:	DI
BRAND:	CAT	ENGINE SPEED (RPM):	1,800
ENGINE POWER (BHP):	2,937	HERTZ:	60
GEN POWER WITH FAN (EKW):	2,000.0	FAN POWER (HP):	114.0
COMPRESSION RATIO:	14.7	ASPIRATION:	ТА
RATING LEVEL:	MISSION CRITICAL STANDBY	AFTERCOOLER TYPE:	ATAAC
PUMP QUANTITY:	1	AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
FUEL TYPE:	DIESEL	INLET MANIFOLD AIR TEMP (F):	122
MANIFOLD TYPE:	DRY	JACKET WATER TEMP (F):	210.2
GOVERNOR TYPE:	ADEM3	TURBO CONFIGURATION:	PARALLEL
ELECTRONICS TYPE:	ADEM3	TURBO QUANTITY:	4
CAMSHAFT TYPE:	STANDARD	TURBOCHARGER MODEL:	GTA5518BN-56T-1.12
IGNITION TYPE:	CI	CERTIFICATION YEAR:	2010
INJECTOR TYPE:	EUI	CRANKCASE BLOWBY RATE (FT3/HR):	2,937.9
FUEL INJECTOR:	3920220	FUEL RATE (RATED RPM) NO LOAD (GAL/HR):	13.7
UNIT INJECTOR TIMING (IN):	64.34	PISTON SPD @ RATED ENG SPD (FT/MIN):	2,244.1
REF EXH STACK DIAMETER (IN):	12		
MAX OPERATING ALTITUDE (FT):	3,117		

INDUSTRY	SUBINDUSTRY	APPLICATION
OIL AND GAS	LAND PRODUCTION	PACKAGED GENSET
ELECTRIC POWER	STANDARD	PACKAGED GENSET

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
2,000.0	100	2,937	307	0.329	138.0	78.3	121.2	1,118.5	71.5	752.1
1,800.0	90	2,641	276	0.331	124.9	73.1	119.6	1,067.5	65.7	716.0
1,600.0	80	2,353	246	0.337	113.1	68.0	118.2	1,027.0	60.0	693.3
1,500.0	75	2,212	231	0.340	107.5	65.2	117.5	1,008.1	57.2	684.6
1,400.0	70	2,071	216	0.344	101.8	62.3	116.8	989.4	54.4	676.9
1,200.0	60	1,795	188	0.352	90.1	55.5	115.4	952.0	48.0	662.8
1,000.0	50	1,521	159	0.357	77.5	46.5	113.7	913.4	40.1	654.0
800.0	40	1,250	131	0.357	63.8	34.8	111.8	863.8	30.3	655.0
600.0	30	977	102	0.365	50.9	24.2	110.6	803.8	22.0	650.0
500.0	25	839	88	0.374	44.8	19.7	110.2	767.0	18.7	641.7
400.0	20	699	73	0.388	38.8	15.7	109.8	724.6	15.7	629.0
200.0	10	411	43	0.450	26.4	9.0	109.1	596.9	10.9	552.8

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
2,000.0	100	2,937	83	454.3	6,548.9	15,292.8	28,512.8	29,478.4	6,205.0	5,738.7
1,800.0	90	2,641	77	428.8	6,318.7	14,243.0	27,390.5	28,264.7	5,956.5	5,533.7
1,600.0	80	2,353	72	404.5	6,073.3	13,331.0	26,220.6	27,012.9	5,685.0	5,301.6
1,500.0	75	2,212	69	392.7	5,932.2	12,897.9	25,568.0	26,319.7	5,542.0	5,176.6
1,400.0	70	2,071	66	380.9	5,777.2	12,448.0	24,862.1	25,573.8	5,384.8	5,037.5
1,200.0	60	1,795	59	353.9	5,397.2	11,422.5	23,141.0	23,771.1	5,003.4	4,694.0
1,000.0	50	1,521	50	318.8	4,857.3	10,138.7	20,731.5	21,274.5	4,476.2	4,208.4
800.0	40	1,250	38	271.1	4,090.0	8,488.8	17,357.1	17,803.6	3,744.5	3,524.2
600.0	30	977	27	225.0	3,394.1	6,989.6	14,328.5	14,684.4	3,097.0	2,920.6
500.0	25	839	22	204.1	3,103.5	6,328.1	13,075.2	13,388.4	2,825.1	2,668.8
400.0	20	699	18	184.1	2,840.4	5,696.0	11,947.2	12,218.4	2,572.5	2,435.7
200.0	10	411	11	148.5	2,409.4	4,478.2	10,105.7	10,290.7	2,174.6	2,076.8

Heat Rejection Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHUAST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLE	WORK R ENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
2,000.0	100	2,937	43,150	7,564	101,696	49,615	15,778	38,240	124,558	296,234	315,563
1,800.0	90	2,641	40,179	7,175	92,069	43,106	14,280	34,105	111,977	268,102	285,596
1,600.0	80	2,353	37,427	6,907	84,225	38,510	12,931	30,201	99,774	242,774	258,615
1,500.0	75	2,212	36,092	6,791	80,632	36,523	12,286	28,303	93,784	230,664	245,715
1,400.0	70	2,071	34,737	6,671	77,064	34,629	11,640	26,432	87,835	218,548	232,809
1,200.0	60	1,795	31,877	6,341	69,432	30,722	10,302	22,179	76,103	193,426	206,048
1,000.0	50	1,521	28,631	6,026	60,835	26,675	8,865	17,129	64,508	166,434	177,294
800.0	40	1,250	24,910	5,810	50,784	22,387	7,288	11,280	53,005	136,837	145,766
600.0	30	977	21,252	5,496	41,420	18,139	5,820	6,677	41,431	109,268	116,397
500.0	25	839	19,405	5,303	37,082	16,055	5,124	4,986	35,574	96,210	102,488
400.0	20	699	17,492	5,098	32,738	13,986	4,431	3,593	29,634	83,193	88,622
200.0	10	411	13,286	4,670	23,481	8,473	3,022	1,516	17,448	56,745	60,447

Sound Data

SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779.

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	2,937	2,212	1,521	839	411
TOTAL NOX (AS NO2)		G/HR	19,256	10,318	5,811	4,222	2,933
TOTAL CO		G/HR	1,581	854	894	1,773	1,794
TOTAL HC		G/HR	422	514	512	410	442
PART MATTER		G/HR	105.4	99.5	122.5	256.7	203.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	3,305.2	2,333.8	1,849.4	2,378.8	2,855.1
TOTAL CO	(CORR 5% O2)	MG/NM3	258.0	181.8	272.6	895.6	1,714.4
TOTAL HC	(CORR 5% O2)	MG/NM3	59.5	93.5	131.7	194.1	379.0
PART MATTER	(CORR 5% O2)	MG/NM3	14.6	18.4	34.4	119.9	161.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,610	1,137	901	1,159	1,391
TOTAL CO	(CORR 5% O2)	PPM	206	145	218	716	1,371
TOTAL HC	(CORR 5% O2)	PPM	111	175	246	362	708
TOTAL NOX (AS NO2)		G/HP-HR	6.56	4.67	3.82	5.03	7.13
TOTAL CO		G/HP-HR	0.54	0.39	0.59	2.11	4.36
TOTAL HC		G/HP-HR	0.14	0.23	0.34	0.49	1.08
PART MATTER		G/HP-HR	0.04	0.04	0.08	0.31	0.49
TOTAL NOX (AS NO2)		LB/HR	42.45	22.75	12.81	9.31	6.47
TOTAL CO		LB/HR	3.48	1.88	1.97	3.91	3.95
TOTAL HC		LB/HR	0.93	1.13	1.13	0.90	0.98
PART MATTER		LB/HR	0.23	0.22	0.27	0.57	0.45

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	2,937	2,212	1,521	839	411
TOTAL NOX (AS NO2)		G/HR	16,047	8,598	4,842	3,518	2,444
TOTAL CO		G/HR	878	474	497	985	996
TOTAL HC		G/HR	317	386	385	308	333
TOTAL CO2		KG/HR	1,393	1,073	765	430	250
PART MATTER		G/HR	75.3	71.0	87.5	183.4	145.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,754.3	1,944.8	1,541.2	1,982.3	2,379.2
TOTAL CO	(CORR 5% O2)	MG/NM3	143.3	101.0	151.4	497.5	952.4
TOTAL HC	(CORR 5% O2)	MG/NM3	44.7	70.3	99.0	145.9	285.0

PERFORMANCE DATA[DM9168]

PART MATTER	(CORR 5% O2)	MG/NM3	10.4	13.1	24.6	85.6	115.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,342	947	751	966	1,159
TOTAL CO	(CORR 5% O2)	PPM	115	81	121	398	762
TOTAL HC	(CORR 5% O2)	PPM	83	131	185	272	532
TOTAL NOX (AS NO2)		G/HP-HR	5.46	3.89	3.18	4.19	5.94
TOTAL CO		G/HP-HR	0.30	0.21	0.33	1.17	2.42
TOTAL HC		G/HP-HR	0.11	0.17	0.25	0.37	0.81
PART MATTER		G/HP-HR	0.03	0.03	0.06	0.22	0.35
TOTAL NOX (AS NO2)		LB/HR	35.38	18.96	10.68	7.76	5.39
TOTAL CO		LB/HR	1.94	1.05	1.09	2.17	2.20
TOTAL HC		LB/HR	0.70	0.85	0.85	0.68	0.73
TOTAL CO2		LB/HR	3,070	2,365	1,687	949	552
PART MATTER		LB/HR	0.17	0.16	0.19	0.40	0.32
OXYGEN IN EXH		%	10.8	12.3	13.3	14.2	15.8
DRY SMOKE OPACITY		%	0.3	0.5	1.2	3.7	3.0
BOSCH SMOKE NUMBER			0.15	0.21	0.42	1.25	1.12

Regulatory Information

EPA TIER 2	ER 2 2006 - 2010					
GASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 89 SUBPART D AND ISO 8178 FOR MEASURING HC,						
CO, PM, AND NOX. THE "MA	X LIMITS" SHOWN BELOW ARE V	VEIGHTED CYCLE AVERAGES AND ARE I	N COMPLIANCE WITH THE NON-ROAD REG	GULATIONS.		
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR		
U.S. (INCL CALIF)	EPA	NON-ROAD	TIER 2	CO: 3.5 NOx + HC: 6.4 PM: 0.20		
EPA EMERGENCY STATIONARY 2011						
GASEOUS EMISSIONS DAT	A MEASUREMENTS PROVIDED T	O THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 SU	BPART IIII AND ISO 8178 FOR MEASURING HC,		
CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE EMERGENCY STATIONARY REGULATIONS.						
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR		
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 6.4 PM: 0.20		

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL
ALTITUDE (FT)													
0	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,849	2,731	2,937
1,000	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,931	2,820	2,702	2,937
2,000	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,927	2,876	2,826	2,761	2,614	2,937
3,000	2,937	2,937	2,937	2,937	2,937	2,926	2,873	2,822	2,772	2,724	2,673	2,526	2,937
4,000	2,849	2,849	2,849	2,849	2,849	2,820	2,768	2,719	2,671	2,625	2,581	2,438	2,849
5,000	2,752	2,752	2,752	2,752	2,752	2,716	2,667	2,619	2,573	2,529	2,486	2,350	2,752
6,000	2,659	2,659	2,659	2,659	2,659	2,616	2,569	2,523	2,478	2,436	2,379	2,261	2,659
7,000	2,570	2,570	2,570	2,570	2,567	2,519	2,473	2,429	2,386	2,345	2,261	2,144	2,570
8,000	2,484	2,484	2,484	2,484	2,471	2,425	2,381	2,338	2,297	2,257	2,144	2,027	2,484
9,000	2,401	2,401	2,401	2,401	2,377	2,333	2,291	2,250	2,211	2,144	2,027	1,909	2,401
10,000	2,321	2,321	2,321	2,321	2,287	2,245	2,204	2,165	2,127	2,027	1,909	1,792	2,321
11,000	2,244	2,244	2,244	2,242	2,200	2,159	2,120	2,082	2,027	1,909	1,792	1,703	2,244
12,000	2,171	2,171	2,171	2,156	2,115	2,076	2,038	1,997	1,880	1,792	1,674	1,586	2,171
13,000	2,100	2,100	2,100	2,072	2,033	1,995	1,959	1,850	1,762	1,674	1,586	1,498	2,100
14,000	2,027	2,027	2,027	1,991	1,954	1,917	1,821	1,733	1,645	1,557	1,439	1,351	2,027
15,000	1,938	1,938	1,938	1,913	1,877	1,792	1,703	1,615	1,498	1,410	1,292	1,204	1,938

Cross Reference

Test Spec	Setting	Engine Arrangement	Engineering Model	Engineering Model Version	Start Effective Serial Number	End Effective Serial Number
3496500	LL6305	2666137	GS334	-	SBJ00001	
3704962	GG0605	3994236	GS717	-	DD600001	
3704962	GG0605	5063102	GS334	-	SBJ02000	

Supplementary Data

Туре	Classification	Performance Number
SOUND	SOUND PRESSURE	DM8779

Performance Parameter Reference

Parameters	Reference:DM9600-08
PERFORMANC	E DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

PERFORMANCE DATA[DM9168]

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER	TOLERANCE FACTORS
Power	+/- 3%
Torque	+/- 3%
Exhaust stack temperature	+/- 8%
Inlet airflow	+/- 5%
Intake manifold pressure-gage	+/- 10%
Exhaust flow	+/- 6%
Specific fuel consumption	+/- 3%
Fuel rate	+/- 5%
Specific DEF consumption	+/- 3%
DEF rate	+/- 5%
Heat rejection	+/- 5%
Heat rejection exhaust only	+/- 10%
Heat rejection CEM only	+/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

 C280/3600 HEAT REJECTION TOLERANCE FACTORS:

 Heat rejection
 +/- 10%

 Heat rejection to Atmosphere
 +/- 50%

 Heat rejection to Ather cooler
 +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque	+/- 0.5%
Speed	+/- 0.2%
Fuel flow	+/- 1.0%
Temperature	+/- 2.0 C degrees
Intake manifold pressure	+/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1

and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humdity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.
REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 (84.2), where the density is 838.9 G/Liter (7.001 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer,

common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSIONS DEFINITIONS: Emissions : DM1176

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS: 3500: EM1500

RATING DEFINITIONS: Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

SOUND DEFINITIONS: Sound Power : DM8702

Sound Pressure : TM7080

Date Released : 7/7/15

Performance Number: DM9168

SALES MODEL:
ENGINE POWER (BHP):
GEN POWER WITH FAN (EKW):
COMPRESSION RATIO:
APPLICATION:
RATING LEVEL:
SUB APPLICATION:
PUMP QUANTITY:
FUEL TYPE:
MANIFOLD TYPE:
GOVERNOR TYPE:
ELECTRONICS TYPE:
CAMSHAFT TYPE:
IGNITION TYPE:
INJECTOR TYPE:
FUEL INJECTOR:
REF EXH STACK DIAMETER (IN):
MAX OPERATING ALTITUDE (FT):

3516C 2,937 2,000.0 14.7 PACKAGED GENSET MISSION CRITICAL STANDBY STANDARD 2 DIESEL DRY ADEM3 ADEM3 STANDARD CI EUI 2664387 12 3,117

COMBUSTION:	DI
ENGINE SPEED (RPM):	1,800
FAN POWER (HP):	114.0
ASPIRATION: AFTERCOOLER TYPE:	ATAAC
AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
INLET MANIFOLD AIR TEMP (F):	122
JACKET WATER TEMP (F):	210.2
TURBO CONFIGURATION:	PARALLEL
TURBO QUANTITY:	4
TURBOCHARGER MODEL:	GTA5518BN-56T-1.12
CERTIFICATION YEAR:	2010
CRANKCASE BLOWBY RATE (FT3/HR):	2,937.9
FUEL RATE (RATED RPM) NO LOAD (GAL/HR):	13.7
PISTON SPD @ RATED ENG SPD (FT/MIN):	2,244.1

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
2,000.0	100	2,937	307	0.329	138.0	78.3	121.2	1,118.5	71.5	752.1
1,800.0	90	2,641	276	0.331	124.9	73.1	119.6	1,067.5	65.7	716.0
1,600.0	80	2,353	246	0.337	113.1	68.0	118.2	1,027.0	60.0	693.3
1,500.0	75	2,212	231	0.340	107.5	65.2	117.5	1,008.1	57.2	684.6
1,400.0	70	2,071	216	0.344	101.8	62.3	116.8	989.4	54.4	676.9
1,200.0	60	1,795	188	0.352	90.1	55.5	115.4	952.0	48.0	662.8
1,000.0	50	1,521	159	0.357	77.5	46.5	113.7	913.4	40.1	654.0
800.0	40	1,250	131	0.357	63.8	34.8	111.8	863.8	30.3	655.0
600.0	30	977	102	0.365	50.9	24.2	110.6	803.8	22.0	650.0
500.0	25	839	88	0.374	44.8	19.7	110.2	767.0	18.7	641.7
400.0	20	699	73	0.388	38.8	15.7	109.8	724.6	15.7	629.0
200.0	10	411	43	0.450	26.4	9.0	109.1	596.9	10.9	552.8

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND	DRY EXH VOL FLOW RATE (32 DEG F AND
						FLOW RATE			29.98 IN HG)	29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
2,000.0	100	2,937	83	454.3	6,548.9	15,292.8	28,512.8	29,478.4	6,205.0	5,738.7
1,800.0	90	2,641	77	428.8	6,318.7	14,243.0	27,390.5	28,264.7	5,956.5	5,533.7
1,600.0	80	2,353	72	404.5	6,073.3	13,331.0	26,220.6	27,012.9	5,685.0	5,301.6
1,500.0	75	2,212	69	392.7	5,932.2	12,897.9	25,568.0	26,319.7	5,542.0	5,176.6
1,400.0	70	2,071	66	380.9	5,777.2	12,448.0	24,862.1	25,573.8	5,384.8	5,037.5
1,200.0	60	1,795	59	353.9	5,397.2	11,422.5	23,141.0	23,771.1	5,003.4	4,694.0
1,000.0	50	1,521	50	318.8	4,857.3	10,138.7	20,731.5	21,274.5	4,476.2	4,208.4
800.0	40	1,250	38	271.1	4,090.0	8,488.8	17,357.1	17,803.6	3,744.5	3,524.2
600.0	30	977	27	225.0	3,394.1	6,989.6	14,328.5	14,684.4	3,097.0	2,920.6
500.0	25	839	22	204.1	3,103.5	6,328.1	13,075.2	13,388.4	2,825.1	2,668.8
400.0	20	699	18	184.1	2,840.4	5,696.0	11,947.2	12,218.4	2,572.5	2,435.7
200.0	10	411	11	148.5	2,409.4	4,478.2	10,105.7	10,290.7	2,174.6	2,076.8

Heat Rejection Data

GENSET	PERCENT	ENGINE	REJECTION	REJECTION	REJECTION	FXHUAST	FROM OII	FROM	WORK	LOW HEAT	HIGH HEAT
POWER WITH	LOAD	POWER	TO JACKET	то	TO EXH	RECOVERY	COOLER	AFTERCOO	LER ENERGY	VALUE	VALUE
FAN			WATER	ATMOSPHERI	E	TO 350F				ENERGY	ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
2,000.0	100	2,937	43,150	7,564	101,696	49,615	15,778	38,240	124,558	296,234	315,563
1,800.0	90	2,641	40,179	7,175	92,069	43,106	14,280	34,105	111,977	268,102	285,596
1,600.0	80	2,353	37,427	6,907	84,225	38,510	12,931	30,201	99,774	242,774	258,615
1,500.0	75	2,212	36,092	6,791	80,632	36,523	12,286	28,303	93,784	230,664	245,715
1,400.0	70	2,071	34,737	6,671	77,064	34,629	11,640	26,432	87,835	218,548	232,809
1,200.0	60	1,795	31,877	6,341	69,432	30,722	10,302	22,179	76,103	193,426	206,048
1,000.0	50	1,521	28,631	6,026	60,835	26,675	8,865	17,129	64,508	166,434	177,294
800.0	40	1,250	24,910	5,810	50,784	22,387	7,288	11,280	53,005	136,837	145,766
600.0	30	977	21,252	5,496	41,420	18,139	5,820	6,677	41,431	109,268	116,397
500.0	25	839	19,405	5,303	37,082	16,055	5,124	4,986	35,574	96,210	102,488
400.0	20	699	17,492	5,098	32,738	13,986	4,431	3,593	29,634	83,193	88,622
200.0	10	411	13.286	4.670	23.481	8.473	3.022	1.516	17.448	56,745	60.447

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	2,937	2,212	1,521	839	411
TOTAL NOX (AS NO2)		G/HR	19,098	10,213	5,798	4,218	2,932
TOTAL CO		G/HR	1,564	847	905	1,772	1,794
TOTAL HC		G/HR	423	513	512	409	443
PART MATTER		G/HR	103.2	99.5	123.9	256.7	203.1
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	3,299.4	2,320.1	1,852.8	2,379.4	2,855.8
TOTAL CO	(CORR 5% O2)	MG/NM3	257.0	181.1	277.5	896.4	1,715.8
TOTAL HC	(CORR 5% O2)	MG/NM3	60.1	93.7	132.1	194.2	379.5
PART MATTER	(CORR 5% O2)	MG/NM3	14.4	18.5	35.1	120.0	161.3
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,607	1,130	902	1,159	1,391
TOTAL CO	(CORR 5% O2)	PPM	206	145	222	717	1,373
TOTAL HC	(CORR 5% O2)	PPM	112	175	247	363	708
TOTAL NOX (AS NO2)		G/HP-HR	6.54	4.64	3.82	5.04	7.13
TOTAL CO		G/HP-HR	0.54	0.38	0.60	2.12	4.36
TOTAL HC		G/HP-HR	0.15	0.23	0.34	0.49	1.08
PART MATTER		G/HP-HR	0.04	0.05	0.08	0.31	0.49
TOTAL NOX (AS NO2)		LB/HR	42.10	22.52	12.78	9.30	6.46
TOTAL CO		LB/HR	3.45	1.87	2.00	3.91	3.95
TOTAL HC		LB/HR	0.93	1.13	1.13	0.90	0.98
PART MATTER		LB/HR	0.23	0.22	0.27	0.57	0.45

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	2,000.0	1,500.0	1,000.0	500.0	200.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	2,937	2,212	1,521	839	411
TOTAL NOX (AS NO2)		G/HR	15,915	8,511	4,832	3,515	2,443
TOTAL CO		G/HR	869	471	503	984	997
TOTAL HC		G/HR	318	385	385	308	333
TOTAL CO2		KG/HR	1,383	1,068	762	430	250
PART MATTER		G/HR	73.7	71.1	88.5	183.4	145.1
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,749.5	1,933.4	1,544.0	1,982.8	2,379.8
TOTAL CO	(CORR 5% O2)	MG/NM3	142.8	100.6	154.2	498.0	953.2
TOTAL HC	(CORR 5% O2)	MG/NM3	45.2	70.4	99.3	146.0	285.3
PART MATTER	(CORR 5% O2)	MG/NM3	10.3	13.2	25.1	85.7	115.2
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,339	942	752	966	1,159
TOTAL CO	(CORR 5% O2)	PPM	114	80	123	398	763
TOTAL HC	(CORR 5% O2)	PPM	84	131	185	273	533
TOTAL NOX (AS NO2)		G/HP-HR	5.45	3.87	3.19	4.20	5.94
TOTAL CO		G/HP-HR	0.30	0.21	0.33	1.18	2.42
TOTAL HC		G/HP-HR	0.11	0.18	0.25	0.37	0.81
PART MATTER		G/HP-HR	0.03	0.03	0.06	0.22	0.35
TOTAL NOX (AS NO2)		LB/HR	35.09	18.76	10.65	7.75	5.39
TOTAL CO		LB/HR	1.92	1.04	1.11	2.17	2.20
TOTAL HC		LB/HR	0.70	0.85	0.85	0.68	0.73
TOTAL CO2		LB/HR	3,049	2,356	1,681	947	551
PART MATTER		LB/HR	0.16	0.16	0.20	0.40	0.32
OXYGEN IN EXH		%	10.8	12.3	13.3	14.2	15.8
DRY SMOKE OPACITY		%	0.3	0.5	1.2	3.7	3.0
BOSCH SMOKE NUMBER			0.15	0.21	0.43	1.25	1.12

Regulatory Information

EPA TIER 2	A TIER 2 2006 - 2010								
3ASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 89 SUBPART D AND ISO 8178 FOR MEASURING HC,									
CO, PM, AND NOX. THE "M	IAX LIMITS" SHOWN BELOW ARE \	VEIGHTED CYCLE AVERAGES AND ARE	IN COMPLIANCE WITH THE NON-ROAD REC	GULATIONS.					
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR					
U.S. (INCL CALIF)	EPA	NON-ROAD	TIER 2	CO: 3.5 NOx + HC: 6.4 PM: 0.20					
EPA EMERGENCY STATIO	NARY	201	1						
GASEOUS EMISSIONS DA	TA MEASUREMENTS PROVIDED T	O THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 SU	BPART IIII AND ISO 8178 FOR MEASURING HC,					
CO, PM, AND NOX. THE "M	AX LIMITS" SHOWN BELOW ARE V	VEIGHTED CYCLE AVERAGES AND ARE	IN COMPLIANCE WITH THE EMERGENCY S	TATIONARY REGULATIONS.					
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR					
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 6.4 PM: 0.20					

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	50	60	70	80	90	100	110	120	130	NORMAL	
ALTITUDE (FT)											
0	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	
1,000	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	
2,000	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,937	
3,000	2,937	2,937	2,937	2,937	2,937	2,937	2,937	2,896	2,847	2,937	
4,000	2,937	2,937	2,937	2,937	2,937	2,886	2,835	2,786	2,739	2,937	
5,000	2,937	2,937	2,933	2,879	2,826	2,776	2,727	2,680	2,634	2,937	
6,000	2,930	2,874	2,820	2,767	2,717	2,669	2,622	2,576	2,533	2,890	
7,000	2,816	2,762	2,710	2,660	2,611	2,565	2,520	2,476	2,434	2,796	
8,000	2,706	2,654	2,604	2,555	2,509	2,464	2,421	2,379	2,339	2,705	
9,000	2,598	2,548	2,500	2,454	2,409	2,366	2,325	2,285	2,246	2,616	
10,000	2,495	2,447	2,400	2,356	2,313	2,272	2,232	2,193	2,156	2,530	
11,000	2,394	2,348	2,303	2,261	2,220	2,180	2,142	2,105	2,069	2,445	
12,000	2,296	2,252	2,210	2,169	2,129	2,091	2,054	2,019	1,985	2,362	
13,000	2,202	2,159	2,119	2,079	2,042	2,005	1,970	1,936	1,903	2,281	
14,000	2,110	2,070	2,031	1,993	1,957	1,922	1,888	1,855	1,824	2,202	
15,000	2,022	1,983	1,945	1,909	1,875	1,841	1,809	1,778	1,747	2,125	

Cross Reference

Engine Arrangement						
Arrangement Number	Effective Serial Number	Engineering Model	Engineering Model Version			
2666137	SBJ00001	GS334	-			
3994236	DD600001	GS717	-			

Test Specification Data								
Test Spec	Setting	Effective Serial Number	Engine Arrangement	Governor Type	Default Low Idle Speed	Default High Idle Speed		
3496500	LL6305	SBJ00001	2666137	ADEM3				
3704962	GG0605	DD600001	3994236	ADEM3				

Supplementary Data

Туре	Classification	Performance Number
SOUND	SOUND PRESSURE	DM8779

General Notes

General Notes DM9168 - 01
SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779

Performance Parameter Reference

Parameters Reference:DM9600-05 PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:

Power +/- 3% Torque +/- 3% +/- 8% Exhaust stack temperature Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10% Exhaust flow +/- 6% Specific fuel consumption +/- 3% Fuel rate +/- 5% Heat rejection +/- 5% Heat rejection exhaust only +/- 10%

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Affercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

 Torque
 +/- 0.5%

 Speed
 +/- 0.2%

 Fuel flow
 +/- 1.0%

 Temperature
 +/- 2.0 C degrees

 Intake manifold pressure
 +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER SAE J1228 reference atmospheric pressure is 100 KPA (29.61 in hg) and standard temperature is 25 (77) at 60% relative humidity.

FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JAN90 standard reference conditions of 25, 100 KPA 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 (84.2), where the density is 838.9 G/Liter (7.001 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/ CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive

standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set Standard temperature values versus altitude could be seen on TM2001.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative. Log on to the Technology and Solutions Divisions (T&SD) web page (https://pdgtcat.com/cda/layout") (https://pdgtcat.com/cda/layout" target="blank" >Technology and Solutions Divisions (T&SD) web page (https://pdgtcat.com/cda/layout") for information including federal regulation applicability and time lines for implementation. Information for labeling and tagging requirements is also provided.

NOTES:

Regulation watch covers regulations in effect and future regulation changes for world, federal, state and local. This page includes items on the watch list where a regulation change or product change might be pending and may need attention of the engine product group. For additional emissions information log on to the TMI web page.

Additional product information for specific market application is available.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500

EMISSIONS DEFINITIONS: Emissions : DM1176

SOUND DEFINITIONS: Sound Power : DM8702

Sound Pressure : TM7080

RATING DEFINITIONS: Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

Date Released : 11/23/11

PERFORMANCE DATA[DM8260]

February 11, 2011

Change Level: 02

Performance Number: DM8260

ç

SALES MODEL:
ENGINE POWER (BHP):
GEN POWER WITH FAN (EKW):
COMPRESSION RATIO:
APPLICATION:
RATING LEVEL:
PUMP QUANTITY:
FUEL TYPE:
MANIFOLD TYPE:
GOVERNOR TYPE:
ELECTRONICS TYPE:
CAMSHAFT TYPE:
IGNITION TYPE:
INJECTOR TYPE:
FUEL INJECTOR:
REF EXH STACK DIAMETER (IN):
MAX OPERATING ALTITUDE (FT):

3512C 2,206 1,500.0 14.7 PACKAGED GENSET STANDBY 2 DIESEL DRY ADEM3 ADEM3 STANDARD CI EUI 2664387 10 3,937

1
-
1
. 1
4
(
2
2
0: 9
2

DI 1,800 60 88.5 TA ATAAC JW+OC, ATAAC 122 210.2 PARALLEL 4 GTB4708BN-52T-0.96 2006 2,203.4 9.9 2,244.1

General Performance Data

GENSET POWER WITH FAN	PERCENT	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
1,500.0	100	2,206	307	0.332	104.6	77.5	120.9	1,145.6	74.6	759,0
1,350.0	90	1,983	276	0.336	95.2	72.2	116.1	1,102.7	68.8	726.8
1,200.0	80	1,768	246	0.343	86.6	66.9	113.2	1,069.1	63.1	708.7
1,125.0	75	1,662	232	0.346	82,0	63,4	111.5	1,052.3	59.5	700.6
1,050.0	70	1,556	217	0.348	77.4	59.7	109.8	1,035.3	55.8	693.6
900.0	60	1,349	188	0.352	67.9	51.1	107.1	1,000.5	47.6	682.5
750.0	50	1,144	159	0.355	58.1	40.6	107,5	963.7	38.4	686.4
600.0	40	940	131	0.359	48.2	30,0	108.4	921.9	29.4	686,0
450.0	30	736	103	0,368	38.6	20.9	107.1	856,1	21.9	667.6
375.0	25	632	88	0.376	33.9	16.9	106.2	809.6	18,8	648.1
300.0	20	527	73	0.388	29.2	13.3	105.2	754.6	16.0	621.1
150.0	10	312	43	0.443	19.7	7,3	103,2	609.7	11.4	526,2

GENSET POWER WITH FAN	PERCENT LOAD	POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
1,500.0	100	2,206	82	449.8	4,570.7	10,909.2	20,179.4	20,912.0	4,401.2	3,984.7
1,350,0	90	1,983	77	428.8 .	4,387.3	10,167.0	19,354.1	20,020.6	4,213.1	3,825.4
1,200,0	80	1,768	71	409.0	4,190.2	9,533,7	18,456.0	19,062.3	4,012.0	3,655,5
1,125.0	75	1,662	68	396,6	4,062.8	9,156.1	17,861.1	18,435.5	3,879.9	3,539,6
1,050.0	70	1,556	64	382.7	3,917.6	8,750.8	17,185.6	17,727.5	3,730.8	3,407.5
900,0	60	1,349	55	350.3	3,576.3	7,863.4	15,607.1	16,082,3	3,384,9	3,097.2
750.0	50	1,144	44	309.9	3,132.5	6,856.9	13,608,7	14,015.1	2,941.7	2,693.8
600.0	40	940	33	266.6	2,669.6	5,821.5	11,547,1	11,884.6	2,498.4	2,290,8
450.0	30	736	23	224,6	2,255.4	4,830.1	9,719.1	9,989,4	2,106.6	1,937.5
375.0	25	632	19	204.3	2,072.0	4,354.9	8,915.9	9,153.2	1,932.9	1,782.3
300.0	20	527	15	184.3	1,901.9	3,888,6	8,175.8	8,380.0	1,769.0	1,636,5
150.0	10	312	9	148.8	1,629.0	3,012,8	6,991,2	7,129.2	1,502.5	1,404.3

j

Heat Rejection Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHUAST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLEI	WORK RENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
1,500.0	100	2,206	35,045	7,072	75,190	35,916	11,958	27,337	93,547	224,502	239,151
1,350.0	90	1,983	32,811	6,707	68,272	31,548	10,884	24,908	84,110	204,338	217,671
1,200.0	80	1,768	30,708	6,394	62,804	28,510	9,899	22,371	74,958	185,849	197,976
1,125.0	75	1,662	29,571	6,250	59,771	26,919	9,378	20,805	70,466	176,063	187,551
1,050.0	70	1,556	28,384	6,110	56,659	25,337	8,847	19,142	66,004	166,092	176,930
900.0	60	1,349	25,881	5,841	50,233	22,204	7,761	15,544	57,205	145,705	155,213
750,0	50	1,144	23,184	5,565	43,580	19,571	6,637	11,412	48,509	124,605	132,736
600.0	40	940	20,363	5,287	36,864	16,564	5,513	7,503	39,882	103,503	110,257
450.0	30	736	17,435	4,840	29,997	13,124	4,417	4,600	31,201	82,927	88,339
375.0	25	632	15,907	4,570	26,510	11,255	3,877	3,492	26,809	72,781	77,530
300,0	20	527	14,318	4,299	22,979	9,339	3,336	2,570	22,353	62,636	66,723
150.0	10	312	10,869	3,818	15,812	5,101	2,253	1,253	13,214	42,305	45,066

Page 2 of 10

PERFORMANCE DATA[DM8260]

ł

Emissions Data

RATED SPEED NOT TO EXCEED DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	1,500.0	1,125.0	750.0	375.0	150.0
ENGINE POWER	MARGE AND	BHP	2,206	1,662	1,144	632	312
PERCENT LOAD		%	100	75	50	25	10
TOTAL NOX (AS NO2)		G/HR	13,311	6,733	4,486	3,351	2,583
TOTAL CO		G/HR	1,745	1,092	1,544	1,806	1,733
TOTAL HC		G/HR	326	354	333	263	302
PART MATTER		G/HR	90.5	92.4	140.5	169.6	102.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,631.0	1,672,1	1,552.2	2,038.1	2,711.4
TOTAL CO	(CORR 5% O2)	MG/NM3	394,6	312.6	662.4	1,129.4	2,176.8
TOTAL HC	(CORR 5% O2)	MG/NM3	63.8	89.0	114.9	162.2	330.4
PART MATTER	(CORR 5% O2)	MG/NM3	16.8	22.3	50.7	100.7	105.3
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,282	814	756	993	1,321
TOTAL CO	(CORR 5% O2)	PPM	316	250	530	903	1,741
TOTAL HC	(CORR 5% O2)	PPM	119	166	215	303	617
TOTAL NOX (AS NO2)		G/HP-HR	6.09	4.09	3.95	5.33	8.34
TOTAL CO		G/HP-HR	0.80	0,66	1.36	2.88	5,59
TOTAL HC		G/HP-HR	0.15	0,22	0.29	0.42	0.97
PART MATTER		G/HP-HR	0.04	0.06	0,12	0,27	0.33
TOTAL NOX (AS NO2)		LB/HR	29:35	14.84	9.89	7.39	5.70
TOTAL CO		LB/HR	3.85	2.41	3.40	3.98	3,82
TOTAL HC		LB/HR	0.72	0,78	0.73	0.58	0.66
PART MATTER		LB/HR	0,20	0.20	0,31	0,37	0.23

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	1,500.0	1,125.0	750.0	375,0	150,0
ENGINE POWER		BHP	2,206	1,662	1,144	632	312
PERCENTLOAD		%	100	75	50	25	10
TOTAL NOX (AS NO2)		G/HR	11,092	5,610	3,738	2,793	2,153
TOTAL CO		G/HR	969	607	858	1,003	963
TOTAL HC		G/HR	245	267	251	197	227
TOTAL CO2	2013-00	KG/HR	1,012	791	557	324	186
PART MATTER		G/HR	64.7	66.0	100.4	121.1	73.3
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,192.5	1,393.4	1,293.5	1,698.4	2,259.5
TOTAL CO	(CORR 5% O2)	MG/NM3	219.2	173.7	368.0	627.4	1,209.3
TOTAL HC	(CORR 5% O2)	MG/NM3	48.0	66.9	86.4	121.9	248.4
PART MATTER	(CORR 5% O2)	MG/NM3	12.0	15,9	36.2	72.0	75,2
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,068	679	630	827	1,101
TOTAL CO	(CORR 5% O2)	PPM	175	139	294	502	967
TOTAL HC	(CORR 5% O2)	PPM .	90	125	161	. 228	464
TOTAL NOX (AS NO2)		G/HP-HR	5.08	3.41	3.29	4.45	6,95
TOTAL CO	and the second se	G/HP-HR	0.44	0.37	0.76	1.60	3.11
TOTAL HC		G/HP-HR	0.11	0.16	0.22	0.31	0.73
PART MATTER	and) - 17	G/HP-HR	0.03	0.04	0.09	0,19	0.24
TOTAL NOX (AS NO2)		LB/HR	24.45	12,37	8.24	6.16	4,75
TOTAL CO		LB/HR	2,14	1.34	1.89	2.21	2.12
TOTAL HC		LB/HR	0.54	0.59	0.55	0,44	0.50
TOTAL CO2		LB/HR	2,230	1,743	1,228	714	409
PART MATTER		LB/HR	0.14	0,15	0.22	0.27	0,16
OXYGEN IN EXH		%	10.4	11.6	12.3	13.3	15.3
DRY SMOKE OPACITY		%	1.0	1.3	2.9	5,0	3.0
BOSCH SMOKE NUMBER			0.37	0.45	1.06	1.60	1.11

PERFORMANCE DATA[DM8260]

ł

Regulatory Information

 \mathcal{L}

(,

EPA TIER 2		207	06 - 2010	
SASEOUS EMISSIONS DAT	TA MEASUREMENTS ARE CONSIS	STENT WITH THOSE DESCRIBED IN EPA	40 CFR PART 89 SUBPART D AND ISO 8178 I	OR MEASURING HC. CO. PM. AND NOX.
BASEOUS EMISSIONS VAL	UES ARE WEIGHTED CYCLE AVE	ERAGES AND ARE IN COMPLIANCE WITH	THE NON-ROAD REGULATIONS.	
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR
J.S. (INCL CALIF)	EPA	NON-ROAD	TIER 2	CO: 3,5 NOx + HC: 6,4 PM: 0,20
PA EMERGENCY STATIO	NARY	201		
GASEOUS EMISSIONS DAT	TA MEASUREMENTS ARE CONSIS	STENT WITH THOSE DESCRIBED IN EPA	40 CFR PART 60 SUBPART IIII AND ISO 8178	FOR MEASURING HC, CO, PM, AND NOX.
SASEOUS EMISSIONS VAL	LUES ARE WEIGHTED CYCLE AVE	RAGES AND ARE IN COMPLIANCE WITH	THE NON-ROAD REGULATIONS.	
Locality	Адепсу	Regulation	Tier/Stage	Max Limits - G/BKW - HR
US (INCLOALE)	ET ET A	Contraction of the second		

February 11, 2011

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	50	60	70	80	90	100	110	120	130	NORMAL
ALTITUDE (FT)									
0	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206
1,000	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206
2,000	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,200	2,163	2,206
3,000	2,206	2,206	2,206	2,206	2,206	2,193	2,155	2,118	2,082	2,206
4,000	2,206	2,206	2,206	2,188	2,149	2,110	2,073	2,037	2,003	2,206
5,000	2,206	2,186	2,144	2,105	2,066	2,029	1,994	1,959	1,926	2,183
6,000	2,143 ~	2,101	2,062	2,023	1,987	1,951	1,917	1,884	1,852	2,113
7,000	2,059	2,020	1,981	1,945	1,909	1,875	1,842	1,811	1,780	2,045
8,000	1,978	1,940	1,904	1,868	1,834	1,802	1,770	1,739	1,710	1,978
9,000	1,900	1,863	1,828	1,794	1,762	1,730	1,700	1,670	1,642	1,913
10,000	1,824	1,789	1,755	1,723	1,691	1,661	1,632	1,604	1,576	1,850
11,000	1,750	1,717	1,684	1,653	1,623	1,594	1,566	1,539	1,513	1,788
12,000	1,679	1,647	1,616	1,586	1,557	1,529	1,502	1,476	1,451	1,727
13,000	1,610	1,579	1,549	1,520	1,493	1,466	1,440	1,415	1,391	1,668
14,000	1,543	1,513	1,485	1,457	1,431	1,405	1,380	1,357	1,334	1,610
15,000	1,478	1,450	1,422	1,396	1,371	1,346	1,322	1,300	1,278	1,554

Cross Reference

Arrangement Number	Ef	fective Serial Number	Engine Arrangement Engineering	Model	Engineering Model	Version
2673949	E	3G00001	GS335		-	
Test Spec	Setting	Effective Serial Number	Engine Arrangement	I Governor Type	Default Low Idle Speed	Default High Idle Speed
0K7015	GG0288	EBG00001	2673949	ADEM3		

General Notes

General Notes DM8260 - 02	
SOUND DEESSURE DATA FOR THIS RATING CAN BE FOUND IN DERFORMANCE NUMBER - DM0770	
SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779	

February 11, 2011

Performance Parameter Reference

Parameters Reference:DM9600-02

<h2><u>PERFORMANCE DEFINITIONS DM9600</u></h2>

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request(SERR)test data shall be noted,

PERFORMANCE PARAMETER TOLERANCE FACTORS: +/- 3% Power +/- 3% Torque* Exhaust stack temperature +/- 8% +/- 5% Inlet airflow Intake manifold pressure-gage +/- 10% +/- 6% Exhaust flow Specific fuel consumption +/- 3% +/- 5% Fuel rate Heat rejection +/- 5% Heat rejection exhaust only +/- 10%

C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5%

*Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications,

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque	+/- 0.5%
Speed	+/- 0.2%
Fuel flow	+/- 1.0%
Temperature	+/- 2.0 C degrees
Intake manifold press	ure +/-01kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

<I>FOR 3500 ENGINES AND SMALLER</I> SAE J1228 reference atmospheric pressure is 100 KPA (29.61 in hg) and standard temperature is 25°C (77°F) at 60% relative humidity.

⊲>FOR 3600 ENGINES</i>
Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JAN90 standard reference conditions of 25°C, 100 KPA 30% relative humidity and 150M altitude at the stated attercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURELocation for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETERThe Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

1500 KWC

PERFORMANCE DATA[DM8260]

REFERENCE FUEL

<i>DIESEL</i>

Reference fuel is #2 distillate diesel with a 35° API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29°C (84.2°F), where the density is 838.9 G/Liter (7.001 Lbs/Gal).

<i>GAS</i>

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/ CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS

EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, commor nail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standar d temperature and standard pressure at which the engine could develop full rated output power on the current performance data set. Standard temperature values versus altitude could be seen on TM2001.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCETMI Emissions information is presented at 'nominal' and 'not to exceed' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative. Log on to the Technology and Solutions Divisions (T&SD) web page (http://tsd.cat.com/etsd/index.cfm?tech_id=2635ICAL) for information including federal regulation applicability and time lines for implementation. Information for labeling and tagging requirements is

<i>NOTES:</i>

also provided.

Regulation watch covers regulations in effect and future regulation ch anges for world, federal, state and loca. This page includes items on the watch list where a regulation change or product change might be pending and may need attention of the engine product group. For additional emissions information log on to the TMI web page.

Additional product information for specific market application is available.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

<ht><u>HEAT REJECTION DEFINITIONS:</u>choisCircuit Type and HHV Balance : <a href="http://tmiweb.cat.com/l</td>mi/servlet/TMIDirector?Action=buildtab&tab=DDDefinitionsDisplay&log=genData&jsp=PertDetai&perfNo=DM9500">DM9500

<h5><u>SOUND DEFINITIONS:</u></h4>

Sound Power : DM8702

Sound Pressure : TM7080">TM7080

PERFORMANCE DATA[DM8260]

<hs><u>RATING DEFINITIONS:</u></hs> Agriculture TM6008

Fire Pump TM6009

Generator Set TM6035

Generator (Gas) TM6041

Industrial Diesel TM6010

Industrial (Gas) TM6040">TM6040">>

Irrigation TM5749

Locomotive TM6037

Marine Auxiliary TM6036

Marine Prop (Except 3600) TM5747

Marine Prop (3600 only) TM5748

MSHA TM6042

Oil Field (Petroleum) TM6011

Off-Highway Truck TM6039

On-Highway Truck TM6038

<h6 align="right">Date Released : 12/06/10</h6>

GEN SET PACKAGE PERFORMANCE DATA [CO9DEO2]

APRIL 19, 2011

For Help Desk Phone Numbers Click here

Performance Number: DM8501

Change Level: 02

Sales Mode	I: C9 DITA	Combustion: DI	Aspr: TA	
Engine Pow	ver:			
250 W/F EKW	265 W/O F EKW	Speed: 1,800 RPM	After Cooler: ATAAC	
398 HP				
Manifold T	ype: DRY	Governor Type: ELEC	After Cooler Temp(F): 120	
Turbo Qua	ntity: 1	Engine App: GP	Turbo Arrangement:	
Hertz: 60		Application Type: PACKAGE-DIE	Engine Rating: PGS	Strategy:
Rating Type: STANDBY		Certification: EPA TIER-3 2005 EPA STAT EMERC 2011		

General Performance Data 1

GEN W/F EKW	PERCENT LOAD	engine Power Bhp	engine Bmep PSi	FUEL BSFC LB/BHP- HR	FUEL RATE GPH	INTAKE MFLD TEMP DEG F	INTAKE MFLD P IN-HG	INTAKE AIR FLOW CFM	exh Mfld Temp Deg f	EXH STACK TEMP DEG F	EXH GAS FLOW CFM
250	100	398	326.05	0.34	19.36	122.36	77.94	882.87	1,145.48	853.88	2,242.48
225	90	359	294.14	0.35	17.73	121.64	74.33	858.15	1,096.88	824.9	2,129.48
200	80	321	262.96	0.35	16.25	122.18	70.86	833.43	1,052.06	801.32	2,023.53
187.5	75	302	247.58	0.36	15.53	122.54	69.15	819.3	1,031	791.42	1,974.09
175	70	284	232.21	0.36	14.77	122.36	66.75	801.64	1,012.1	784.22	1,914.06
150	60	247	202.04	0.37	13.18	122.18	60.77	752.2	974.84	770.18	1,776.33
125	50	211	172.45	0.38	11.57	121.82	53.36	692.17	938.48	756.5	1,613.88
100	40	177	144.6	0.39	9.93	121.28	43.5	610.94	902.66	743.18	1,412.59
75	30	142	116.03	0.4	8.16	120.92	32.6	519.13	861.08	728.78	1,190.11
62.5	25	124	101.38	0.41	7.26	120.56	27.04	473.22	837.86	720.86	1,077.1
50	20	106	86.44	0.42	6.31	120.38	21.38	427.31	813.02	712.76	957.03
25	10	69	56.13	0.45	4.36	120.38	11.99	346.08	669.2	610.52	716.89

General Performance Data 2

GEN W/F EKW	PERCENT LOAD	engine Power Bhp	Compress OUT PRESS IN- HG	Compress Out Temp Deg F
250	100	398	78.8	426.2
225	90	359	75.25	408.92
200	80	321	71.78	390.74
187.5	75	302	70.09	381.2
175	70	284	67.67	370.94
150	60	247	61.68	347.36
125	50	211	54.19	319.28
100	40	177	44.27	280.4
75	30	142	33.29	236.66

62.5	25	124	27.66	214.16
50	20	106	21.97	191.3
25	10	69	12.53	149.72

Engine Heat Rejection Data

PERCENT LOAD	rej to Jw Btu/mn	REJ TO ATMOS BTU/MN	rej to Exhaust Btu/mn	EXH RCOV TO 350F BTU/MN	From Oil Clr Btu/Mn	From Aft Clr Btu/Mn	Work Energy Btu/Mn	lhv Energy Btu/Mn	hhv Energy Btu/mn
100	5,971.3	1,188.6	15,753.0	10,293.5	2,223.6	4,731.6	16,890.4	41,799.4	44,529.1
90	5,516.4	1,057.8	14,615.6	9,383.5	2,035.9	4,344.9	15,241.1	38,273.4	40,775.7
80	5,175.2	1,006.6	13,591.9	8,587.3	1,865.3	3,941.1	13,591.9	35,031.9	37,363.5
75	5,004.5	955.4	13,136.9	8,189.3	1,780.0	3,736.4	12,795.7	33,439.5	35,657.4
70	4,833.9	881.5	12,625.1	7,848.0	1,694.7	3,508.9	12,056.4	31,790.3	33,894.4
60	4,492.7	767.7	11,544.6	7,108.7	1,512.7	2,985.7	10,464.1	28,434.9	30,254.8
50	4,151.5	682.4	10,350.3	6,255.7	1,325.1	2,411.3	8,928.6	24,909.0	26,558.2
40	3,867.1	796.2	8,871.7	5,288.9	1,137.4	1,711.8	7,506.8	21,383.1	22,747.9
30	3,412.2	847.4	7,393.1	4,322.1	932.7	1,057.8	6,028.2	17,572.8	18,710.2
25	3,184.7	779.1	6,596.9	3,867.1	830.3	779.1	5,232.0	15,582.3	16,606.0
20	2,900.4	648.3	5,857.6	3,355.3	722.2	534.6	4,492.7	13,535.0	14,445.0
10	2,388.5	563.0	3,924.0	1,933.6	500.5	176.3	2,900.4	9,383.5	9,952.2
	PERCENT LOAD 90 80 75 70 60 50 40 30 25 20 10	PERCENT LOAD REJ TO JW BTU/MN 100 5,971.3 90 5,516.4 80 5,175.2 75 5,004.5 70 4,833.9 60 4,492.7 50 4,151.5 40 3,867.1 30 3,412.2 25 3,184.7 20 2,900.4 10 2,388.5	PERCENTREJ TO JW BTU/MNREJ TO ATMOS BTU/MN1005,971.31,188.6905,516.41,057.8805,175.21,006.6755,004.5955.4704,833.9881.5604,492.7767.7504,151.5682.4403,867.1796.2303,412.2847.4253,184.7779.1202,900.4648.3102,388.5563.0	PERCENT LOADREJ TO JW BTU/MNREJ TO ATMOS BTU/MNREJ TO ATMOS BTU/MNREJ TO SHAUST1005,971.31,188.615,753.0905,516.41,057.814,615.6805,175.21,006.613,591.9755,004.5955.413,136.9704,833.9881.512,625.1604,492.7767.711,544.6504,151.5682.410,350.3403,867.1796.28,871.7303,412.2847.47,393.1253,184.7779.16,596.9202,900.4648.35,857.6102,388.5563.03,924.0	PERCENT LOADREJ TO JW JWREJ TO ATMOS ATMOS DU/MNREJ TO SHAUSDREN COV TO 350F BTU/MN1005,971.31,188.615,753.010,293.5905,516.41,057.814,615.69,383.5905,516.41,057.814,615.69,383.5805,175.21,006.613,591.98,587.3755,004.5955.413,136.98,189.3704,833.9881.512,625.17,848.0604,492.7767.711,544.67,108.7504,151.5682.410,350.36,255.7403,867.1796.28,871.75,288.9303,412.2847.47,393.14,322.1202,900.4648.35,857.63,355.3102,388.5563.03,924.01,933.6	PERCENTREJ TO JW BU/MNREJ TO ATMOS BU/MNREJ TO SUMAUSREJ TO SOF BU/MNRED TO SOF SOF BU/MNRED TO SOF SOF SOF BU/MNRED TO SOF SOF SOF SOF SOF SOF SOF SOF SOFRED TO SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF SOF 	PERCENT LOADREJ TO JW BTU/MNREJ TO ATMOS BTU/MNREJ TO SHAUSTREJ TO S50F BTU/MNFROM S0F BTU/MNFROM S10L CLRFROM AFT CLR1005,971.31,188.615,753.010,293.52,223.64,731.6905,516.41,057.814,615.69,383.52,035.94,344.9805,175.21,006.613,591.98,587.31,865.33,941.1755,004.5955.413,136.98,189.31,780.03,736.4704,833.9881.512,625.17,848.01,694.73,508.9604,492.7767.711,544.67,108.71,512.72,985.7504,151.5682.410,350.36,255.71,325.12,411.3403,867.1796.28,871.75,288.91,137.41,711.8303,412.2847.47,393.14,322.1932.71,057.8202,900.4648.35,857.63,355.3722.2534.6102,388.5563.03,924.01,933.6500.5176.3	PERCENT LOADREJ TO JW BTU/MNREJ TO ATMOS BTU/MNREJ TO SHU/MNREJ TO SLHAUSTREJ TO SOF BTU/MNFROM SU/MNFROM AFF CLRWORK SNU/MN1005,971.31,188.615,753.010,293.52,223.64,731.616,890.4905,516.41,057.814,615.69,383.52,035.94,344.915,241.1805,175.21,006.613,591.98,587.31,865.33,941.113,591.9755,004.5955.413,136.98,189.31,780.03,736.412,795.7704,833.9881.512,625.17,848.01,694.73,508.912,056.4604,492.7767.711,544.67,108.71,512.72,985.710,464.1504,151.5682.410,350.36,255.71,325.12,411.38,928.6403,867.1796.28,871.75,288.91,137.41,711.87,506.8303,412.2847.47,393.14,322.1932.71,057.86,028.2203,184.7779.16,596.93,867.1830.3779.15,232.0202,900.4648.35,857.63,355.3722.2534.64,492.7102,388.5563.03,924.01,933.6500.5176.32,900.4	PERCENT LOADREJ TO JW BUU/MNREJ TO EHAUST BUU/MNREJ TO SOF SOF BUU/MNREOM SOF SOF BUU/MNFROM SFUM SUMREOM SUM SUMREOM SUM SUMREOM SUM SUMREOM SUMREOM SUM SUMREOM SUM SUMREOM SUMReom SUM </td

		EM	ISSIONS DATA		
EPA TIER-3 Gaseous emissic in 40 CFR, EU 97 HC, CO, PM and	2005 **** ns data measure 7/68/EC, ECE Re NOx.	ment are gulation N	consistent with the	*********** nose describ 78 for meas	www.com bed in suring
Gaseous emissic with the followir	ns values are WE ng non-road regul	EIGHTED C lations:	YCLE AVERAGES a	and are in c	ompliance
LOCALITY	AGENCY/LEV	EL	MAX LIMITS - g/	/kw-hr	
U. S. (incl Calif) Europe	EPA/Tier 3 EU/Stage-IIIA	CO:3.5 CO:3.5	NOx + HC:4.0 NOx + HC:4.0	PM:0.2 PM:0.2	
EPA STAT EMER EPA	C 2011 * EMERGENCY STA	**************************************	*****		P4
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN CON LOCALITY	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR IPLIANCE WITH T AGENCY/LEVE	*********** TIONARY SUREMENT 60 SUBPA 7. X. E WEIGHT THE NON-F EL	S ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERAG ROAD REGULATION MAX LIMITS - g/	NT WITH TH 78 FOR GES NS. kW-hr	OSE
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN CON LOCALITY 	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR IPLIANCE WITH T AGENCY/LEVE	XTIONARY SUREMENT 60 SUBPA X. E WEIGHT THE NON-F EL 	S ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA ROAD REGULATION MAX LIMITS - g/ CO:3.5 NOx +	NT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM	OSE 1:0.20
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN CON LOCALITY U.S. (INCL CALIF REFERENCE	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR IPLIANCE WITH T AGENCY/LEVE 	x********** TIONARY SUREMENT 60 SUBPA X. E WEIGHT THE NON-F EL MERGENCY CK DIAMI	S ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA(ROAD REGULATION MAX LIMITS - g/ CO:3.5 NOx + ETER	NT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM	OSE 1:0.20
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN COM LOCALITY U.S. (INCL CALIF REFERENCE WET EXHAU	C 2011 * EMERGENCY STA IONS DATA MEAS 2A 40 CFR PART CO, PM, AND NO IONS VALUES AR APLIANCE WITH T AGENCY/LEVE 	********************** TIONARY SUREMENT 60 SUBPA X. E WEIGHT THE NON-F EL 	TS ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA(ROAD REGULATION MAX LIMITS - g/ CO:3.5 NOx + ETER	NT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM	OSE 1:0.20 4,012.4 LB/HR
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN CON LOCALITY 	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR IPLIANCE WITH T AGENCY/LEVE 	********** TIONARY SUREMENT 60 SUBPA X. E WEIGHT THE NON-F EL MERGENCY CK DIAMI	TS ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA(ROAD REGULATION MAX LIMITS - g/ (CO:3.5 NOx + ETER K TEMP)	NT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM	OSE 1:0.20 4,012.4 LB/HR 2,245.31 CFM
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN CON LOCALITY 	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR IPLIANCE WITH T AGENCY/LEVE 	********** TIONARY SUREMENT 60 SUBPA X. E WEIGHT THE NON-F EL 	TS ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA(ROAD REGULATION MAX LIMITS - g/I CO:3.5 NOx + ETER K TEMP) F AND 29.98 IN H	IT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM	OSE 1:0.20 4,012.4 LB/HR 2,245.31 CFM 841.00 STD CFM
EPA STAT EMER EPA GASEOUS EMISS DESCRIBED IN EF MEASURING HC, GASEOUS EMISS AND ARE IN COM LOCALITY U.S. (INCL CALIF REFERENCE WET EXHAU WET EXHAU WET EXHAU	C 2011 * EMERGENCY STA IONS DATA MEAS PA 40 CFR PART CO, PM, AND NO IONS VALUES AR APLIANCE WITH T AGENCY/LEVE 	**************************************	S ARE CONSISTEN RT IIII AND ISO 81 ED CYCLE AVERA ROAD REGULATION MAX LIMITS - g/ CO:3.5 NOx + ETER K TEMP) F AND 29.98 IN H F AND 29.98 IN H	NT WITH TH 78 FOR GES NS. kW-hr HC:4.0 PM IG) IG)	OSE 1:0.20 4,012.4 LB/HR 2,245.31 CFM 841.00 STD CFM 770.92 STD CFM

Г

		RATED SPEED "Not to exceed data"									
	GEN F EKV	PWR PERC N LO	ENT EN AD PO	ngine Ower Bhp	TOTAL NOX (AS NO2) LB/HR	TOT/ CO LB/H	AL TO IR LE	DTAL HC B/HR	PART MATTER LB/HR	OXYO IN EXHA PERCI	GEN UST ENT
		250	100	398	3.1500	.5	900	.1700	.1400	10.1	000
	18	37.5	75	302	1.7800	.6	000	.2200	.1400	11.4	000
		125	50	211	1.1100	.4′	700	.2300	.1100	12.6	000
	6	52.5	25	124	.7000	.6	100	.1900	.1000	13.8	000
I		25	10	69	.5500	.6	000	.1800	.0800	15.2	000
		DEDCENT	F		SPEED	"Nom TAL	inal Da TOTAL	ita" TOTA	AL PA	RT	OXYGEN
	EKW	LOAD	Power Bhp	NOX NO LB/	(AS C 2) LB HR LB	;o /hr	HC LB/HR	CO2 LB/H	2 mat Ir lb/	ter 'Hr	EXHAUST PERCENT
	250	100	39	8 2.6	5000 .	3200	.090	0 42	4.2 .0	0700	10.1000
	187.5	75	30	2 1.4	. 1700	3200	.120	0 33	9.6 .0	0700	11.4000
	125	50	21	1.9	. 200	2500	.120	0 25	2.9 .0	0600	12.6000
	62.5	25	12	4 .5	5800 .	3300	.100	0 15	7.9 .0	0500	13.8000
	25	10	6	i9 .4	. 4500	3200	.100	0 9	4.8 .0	0400	15.2000
I											

					······	
Ambient Operating Temp. A l t i t u d e	50 F	68 F	86 F	104 F	122 F	NORMAL
0 F	398.28 hp					
984.25 F	398.28 hp					
1,640.42 F	398.28 hp	398.28 hp	398.28 hp	398.28 hp	388.9 hp	398.28 hp
3,280.84 F	398.28 hp	398.28 hp	390.24 hp	378.17 hp	366.1 hp	398.28 hp
4,921.26 F	392.92 hp	379.51 hp	367.44 hp	355.37 hp	344.64 hp	379.51 hp
6,561.68 F	370.12 hp	356.71 hp	344.64 hp	333.91 hp	323.19 hp	360.73 hp
8,202.1 F	347.32 hp	335.26 hp	324.53 hp	313.8 hp	304.41 hp	341.96 hp
9,842.52 F	325.87 hp	315.14 hp	304.41 hp	295.02 hp	285.64 hp	324.53 hp
11,482.94 F	305.75 hp	295.02 hp	285.64 hp	276.25 hp	268.2 hp	308.43 hp
13,123.36 F	286.98 hp	276.25 hp	268.2 hp	258.82 hp	250.77 hp	292.34 hp
14,763.78 F	268.2 hp	258.82 hp	250.77 hp	242.72 hp	234.68 hp	277.59 hp

Altitude Capability Data(Corrected Power Altitude Capability)

The powers listed above and all the Powers displayed are Corrected Powers

Engine Arrangement:	2575707	Lube Oil Press @ Rated Spd(PSI):	49.5
Effective Serial No:	S9L00001	Piston Speed @ Rated Eng SPD (FT/Min):	1,752.0
Primary Engine Test Spec:	0K6612	Max Operating Altitude(FT):	3,280.8
Performance Parm Ref:	TM5739	PEEC Elect Control Module Ref	
Performance Data Ref:	DM8501	PEEC Personality Cont Mod Ref	
Aux Coolant Pump Perf Ref:			
Cooling System Perf Ref:		Turbocharger Model	S310-1.25 VTF
Certification Ref:	EPA TIER 3	Fuel Injector	
Certification Year:	2005	Timing-Static (DEG):	
Compression Ratio:	16.1	Timing-Static Advance (DEG):	
Combustion System:	DI	Timing-Static (MM):	
Aftercooler Temperature (F):	120	Unit Injector Timing (MM):	
Crankcase Blowby Rate(CFH):		Torque Rise (percent)	
Fuel Rate (Rated RPM) No Load (Gal/HR):		Peak Torque Speed RPM	
Lube Oil Press @ Low Idle Spd(PSI):	42.5	Peak Torque (LB/FT):	

Identification Reference and Notes

Reference Number: DM8501	EPA TIER-3 2005G5EPA STAT EMERC 2011P4
Parameters Reference: TM5739	GEN SET - PACKAGED - DIESEL TOLERANCES: AMBIENT AIR CONDITIONS AND FUEL USED WILL AFFECT THESE VALUES. EACH OF THE VALUES MAY VARY IN ACCORDANCE WITH THE FOLLOWING TOLERANCES.
	ENGINE POWER +/- 3% EXHAUST STACK TEMPERATURE +/- 8% GENERATOR POWER +/- 5% INLET AIR FLOW +/- 5% INTAKE MANIFOLD PRESSURE - GAGE +/- 10% EXHAUST FLOW +/- 6% SPECIFIC FUEL CONSUMPTION +/- 3% FUEL RATE +/- 5% HEAT REJECTION EXHAUST ONLY +/- 10%
	CONDITIONS: ENGINE PERFORMANCE IS CORRECTED TO INLET AIR STANDARD CONDITIONS OF 99 KPA (29.31 IN HG) AND 25 DEG C (77 DEG F).
	THESE VALUES CORRESPOND TO THE STANDARD ATMOSPHERIC PRESSURE AND TEMPERATURE IN ACCORDANCE WITH SAE J1349. ALSO INCLUDED IS A CORRECTION TO STANDARD FUEL GRAVITY OF 35 DEGREES API HAVING A LOWER HEATING VALUE OF 42,780 KJ/KG (18,390 BTU/LB) WHEN USED AT 29 DEG C (84.2 DEG F) WHERE THE DENSITY IS 838.9 G/L (7.002 LB/GAL).
	THE CORRECTED PERFORMANCE VALUES SHOWN FOR CATERPILLAR ENGINES WILL APPROXIMATE THE VALUES OBTAINED WHEN THE OBSERVED PERFORMANCE DATA IS CORRECTED TO SAE J1349, ISO 3046-2 & 8665 & 2288 & 9249 & 1585, EEC 80/1269 AND DIN70020 STANDARD REFERENCE CONDITIONS.
	ENGINES ARE EQUIPPED WITH STANDARD ACCESSORIES; LUBE OIL, FUEL PUMP AND JACKET WATER PUMP. THE POWER REQUIRED TO DRIVE AUXILIARIES MUST BE DEDUCTED FROM THE GROSS OUTPUT TO ARRIVE AT THE NET POWER AVAILABLE FOR THE EXTERNAL (FLYWHEEL) LOAD. TYPICAL AUXILIARIES INCLUDE COOLING FANS, AIR COMPRESSORS, AND CHARGING ALTERNATORS.
	RATINGS MUST BE REDUCED TO COMPENSATE FOR ALTITUDE AND/OR AMBIENT TEMPERATURE CONDITIONS ACCORDING TO THE APPLICABLE DATA SHOWN ON THE PERFORMANCE DATA SET.
	GEN SET - PACKAGED - DIESEL ALTITUDE: ALTITUDE CAPABILITY - THE RECOMMENDED REDUCED POWER VALUES FOR SUSTAINED ENGINE OPERATION AT SPECIFIC ALTITUDE LEVELS AND AMBIENT TEMPERATURES.
	COLUMN "N" DATA - THE FLYWHEEL POWER OUTPUT AT NORMAL AMBIENT TEMPERATURE.
	AMBIENT TEMPERATURE - TO BE MEASURED AT THE AIR CLEANER AIR INLET DURING NORMAL ENGINE OPERATION. NORMAL TEMPERATURE - THE NORMAL TEMPERATURE AT VARIOUS SPECIFIC ALTITUDE LEVELS IS FOUND ON TM2001.
	THE GENERATOR POWER CURVE TABULAR DATA REPRESENTS THE NET ELECTRICAL POWER OUTPUT OF THE GENERATOR.

GENERATOR SET RATINGS EMERGENCY STANDBY POWER (ESP)

OUTPUT AVAILABLE WITH VARYING LOAD FOR THE DURATION OF AN EMERGENCY OUTAGE. AVERAGE POWER OUTPUT IS 70% OF THE ESP RATING. TYPICAL OPERATION IS 50 HOURS PER YEAR, WITH MAXIMUM EXPECTED USAGE OF 200 HOURS PER YEAR.

STANDBY POWER RATING

OUTPUT AVAILABLE WITH VARYING LOAD FOR THE DURATION OF AN EMERGENCY OUTAGE. AVERAGE POWER OUTPUT IS 70% OF THE STANDBY POWER RATING. TYPICAL OPERATION IS 200 HOURS PER YEAR, WITH MAXIMUM EXPECTED USAGE OF 500 HOURS PER YEAR.

PRIME POWER RATING

OUTPUT AVAILABLE WITH VARYING LOAD FOR AN UNLIMITED TIME. AVERAGE POWER OUTPUT IS 70% OF THE PRIME POWER RATING. TYPICAL PEAK DEMAND IS 100% OF PRIME RATED EKW WITH 10% OVERLOAD CAPABILITY FOR EMERGENCY USE FOR A MAXIMUM OF 1 HOUR IN 12. OVERLOAD OPERATION CANNOT EXCEED 25 HOURS PER YEAR.

CONTINUOUS POWER RATING

OUTPUT AVAILABLE WITH NON-VARYING LOAD FOR AN UNLIMITED TIME. AVERAGE POWER OUTPUT IS 70-100% OF THE CONTINUOUS POWER RATING. TYPICAL PEAK DEMAND IS 100% OF CONTINUOUS RATED EKW FOR 100% OF OPERATING HOURS.

Caterpillar Confidential: **Green** Content Owner: Shane Gilles Web Master(s): <u>PSG Web Based Systems Support</u> Current Date: Tuesday, April 19, 2011 9:39:56 AM © Caterpillar Inc. 2011 All Rights Reserved. <u>Data Privacy Statement</u>.

PERFORMANCE DATA[DM8501]

Performance Number: DM8501

SALES MODEL:	C9	COMBUSTION:	DI
ENGINE POWER (BHP):	398	ENGINE SPEED (RPM):	1,800
GEN POWER W/O FAN (EKW):	265.0	HERTZ:	60
GEN POWER W/ITH FAN (EKW):	250.0	FAN POWER (HP):	30.2
COMPRESSION RATIO:	16.1	ASPIRATION:	TA
RATING LEVEL:	STANDBY	AFTERCOOLER TYPE:	ATAAC
PUMP QUANTITY:	1	AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
FUEL TYPE:	DIESEL	INLET MANIFOLD AIR TEMP (F):	122
MANIFOLD TYPE:	DRY	JACKET WATER TEMP (F):	192.2
GOVERNOR TYPE:	ELEC	TURBO CONFIGURATION:	SINGLE
CAMSHAFT TYPE:	STANDARD	TURBO CUNFIGURATION:	1
IGNITION TYPE:	CI	TURBO CHARGER MODEL:	\$310-1.25
INJECTOR TYPE:	EUI	CERTIFICATION YEAR:	2005
REF EXH STACK DIAMETER (IN): MAX OPERATING ALTITUDE (FT):	4 3,281	PISTON SPD @ RATED ENG SPD (FT/MIN):	1,759.8

INDUSTRY	SUBINDUSTRY	APPLICATION
OIL AND GAS	LAND PRODUCTION	PACKAGED GENSET
ELECTRIC POWER	STANDARD	PACKAGED GENSET

General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
250.0	100	398	326	0.341	19.4	77.7	122.3	1,142.4	55.4	852.0
225.0	90	359	294	0.346	17.7	74.1	121.6	1,094.4	51.6	823.5
200.0	80	321	263	0.355	16.3	70.7	122.1	1,050.1	48.2	800.5
187.5	75	302	247	0.360	15.5	69.0	122.5	1,029.4	46.4	790.7
175.0	70	284	232	0.364	14.8	66.6	122.4	1,010.3	44.2	782.4
150.0	60	247	202	0.374	13.2	60.6	122.2	973.8	39.4	768.3
125.0	50	211	172	0.385	11.6	53.2	121.8	937.9	33.9	755.8
100.0	40	176	144	0.394	9.9	43.3	121.2	899.4	27.4	742.4
75.0	30	141	116	0.404	8.1	32.2	120.7	857.9	20.5	727.9
62.5	25	124	101	0.410	7.3	26.7	120.5	835.9	17.2	720.5
50.0	20	106	87	0.418	6.3	21.3	120.3	812.9	14.1	712.7
25.0	10	68.9	56	0.445	4.4	12.1	120.5	671.3	9.1	612.1

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
250.0	100	398	79	425.2	889.8	2,245.6	3,863.5	3,999.1	841.8	776.8
225.0	90	359	75	407.9	866.1	2,131.2	3,753.5	3,877.8	816.6	756.7
200.0	80	321	72	390.0	845.5	2,029.1	3,641.7	3,755.4	791.7	736.4
187.5	75	302	70	380.5	833.2	1,976.5	3,583.9	3,692.5	777.2	724.2
175.0	70	284	67	370.2	815.6	1,915.7	3,500.2	3,603.4	758.3	707.7
150.0	60	247	61	346.6	770.3	1,777.1	3,290.5	3,382.8	711.5	666.0
125.0	50	211	54	318.8	711.6	1,616.1	3,025.9	3,107.0	653.7	613.6
100.0	40	176	44	280.7	631.2	1,409.7	2,668.7	2,738.1	576.6	542.5
75.0	30	141	33	236.6	539.6	1,189.0	2,266.0	2,323.1	492.3	464.1
62.5	25	124	27	214.1	493.0	1,076.6	2,063.6	2,114.4	448.5	423.3
50.0	20	106	22	191.5	447.1	961.4	1,865.3	1,909.6	403.2	380.9
25.0	10	68.9	13	150.2	365.7	720.7	1,521.7	1,552.4	330.6	314.7

February 23, 2015

Change Level: 03

Heat Rejection Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHER	REJECTION TO EXH E	EXHUAST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOO	WORK LER ENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
250.0	100	398	5,928	1,004	15,772	8,470	2,214	4,686	16,886	41,564	44,276
225.0	90	359	5,517	890	14,624	7,716	2,028	4,305	15,231	38,081	40,566
200.0	80	321	5,156	844	13,650	7,085	1,859	3,906	13,615	34,894	37,171
187.5	75	302	4,986	796	13,203	6,804	1,775	3,702	12,819	33,332	35,507
175.0	70	284	4,811	750	12,693	6,507	1,688	3,474	12,026	31,686	33,754
150.0	60	247	4,487	657	11,600	5,894	1,508	2,957	10,466	28,319	30,167
125.0	50	211	4,177	565	10,395	5,241	1,323	2,387	8,931	24,835	26,456
100.0	40	176	3,834	664	8,956	4,456	1,131	1,704	7,458	21,230	22,615
75.0	30	141	3,407	764	7,418	3,634	932	1,052	5,989	17,489	18,630
62.5	25	124	3,174	722	6,658	3,239	829	773	5,246	15,560	16,575
50.0	20	106	2,926	591	5,915	2,861	723	532	4,490	13,570	14,455
25.0	10	68.9	2.390	520	4.011	1.661	501	182	2.923	9.412	10.026

Emissions Data

RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	250.0	187.5	125.0	62.5	25.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	398	302	211	124	68.9
TOTAL NOX (AS NO2)		G/HR	1,242	714	452	281	222
TOTAL CO		G/HR	270	271	211	284	268
TOTAL HC		G/HR	69	88	92	70	71
PART MATTER		G/HR	62.6	66.0	49.0	49.0	34.1
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	1,637.5	1,170.5	991.8	1,015.1	1,417.8
TOTAL CO	(CORR 5% O2)	MG/NM3	323.2	403.0	429.8	928.3	1,469.7
TOTAL HC	(CORR 5% O2)	MG/NM3	71.2	113.1	157.9	211.5	370.0
PART MATTER	(CORR 5% O2)	MG/NM3	63.7	84.4	84.3	148.3	155.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	798	570	483	494	691
TOTAL CO	(CORR 5% O2)	PPM	259	322	344	743	1,176
TOTAL HC	(CORR 5% O2)	PPM	133	211	295	395	691
TOTAL NOX (AS NO2)		G/HP-HR	3.14	2.38	2.16	2.27	3.22
TOTAL CO		G/HP-HR	0.68	0.90	1.01	2.30	3.89
TOTAL HC		G/HP-HR	0.17	0.29	0.44	0.57	1.03
PART MATTER		G/HP-HR	0.16	0.22	0.23	0.40	0.49
TOTAL NOX (AS NO2)		LB/HR	2.74	1.57	1.00	0.62	0.49
TOTAL CO		LB/HR	0.59	0.60	0.47	0.63	0.59
TOTAL HC		LB/HR	0.15	0.19	0.20	0.15	0.16
PART MATTER		LB/HR	0.14	0.15	0.11	0.11	0.08

RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN		EKW	250.0	187.5	125.0	62.5	25.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	398	302	211	124	68.9
TOTAL NOX (AS NO2)		G/HR	1,150	661	419	260	205
TOTAL CO		G/HR	144	145	113	152	144
TOTAL HC		G/HR	36	47	48	37	38
TOTAL CO2		KG/HR	193	155	115	71	43
PART MATTER		G/HR	32.1	33.9	25.1	25.1	17.5
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	1,516.2	1,083.8	918.3	939.9	1,312.7
TOTAL CO	(CORR 5% O2)	MG/NM3	172.8	215.5	229.8	496.4	785.9
TOTAL HC	(CORR 5% O2)	MG/NM3	37.7	59.9	83.6	111.9	195.8
PART MATTER	(CORR 5% O2)	MG/NM3	32.6	43.3	43.2	76.0	79.5
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	739	528	447	458	639
TOTAL CO	(CORR 5% O2)	PPM	138	172	184	397	629
TOTAL HC	(CORR 5% O2)	PPM	70	112	156	209	365
TOTAL NOX (AS NO2)		G/HP-HR	2.91	2.20	2.00	2.11	2.98
TOTAL CO		G/HP-HR	0.36	0.48	0.54	1.23	2.08
TOTAL HC		G/HP-HR	0.09	0.15	0.23	0.30	0.55
PART MATTER		G/HP-HR	0.08	0.11	0.12	0.20	0.25
TOTAL NOX (AS NO2)		LB/HR	2.54	1.46	0.92	0.57	0.45
TOTAL CO		LB/HR	0.32	0.32	0.25	0.34	0.32
TOTAL HC		LB/HR	0.08	0.10	0.11	0.08	0.08
TOTAL CO2		LB/HR	425	342	255	156	94
PART MATTER		LB/HR	0.07	0.07	0.06	0.06	0.04
OXYGEN IN EXH		%	10.2	11.6	12.7	13.7	15.0
DRY SMOKE OPACITY		%	0.5	0.8	0.8	1.4	0.9
BOSCH SMOKE NUMBER			0.39	0.67	0.66	1.21	0.84

Regulatory Information

EPA TIER 3	A TIER 3 2005 - 2010									
3ASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 89 SUBPART D AND ISO 8178 FOR MEASURING HC,										
CO, PM, AND NOX. THE "M	AX LIMITS" SHOWN BELOW ARE V	VEIGHTED CYCLE AVERAGES AND ARE	IN COMPLIANCE WITH THE NON-ROAD REG	JULATIONS.						
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR						
U.S. (INCL CALIF)	EPA	NON-ROAD	TIER 3	CO: 3.5 NOx + HC: 4.0 PM: 0.20						
EPA EMERGENCY STATIO	NARY	201	1							
GASEOUS EMISSIONS DAT	TA MEASUREMENTS PROVIDED T	O THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 SU	BPART IIII AND ISO 8178 FOR MEASURING HC,						
CO, PM, AND NOX. THE "M	AX LIMITS" SHOWN BELOW ARE V	VEIGHTED CYCLE AVERAGES AND ARE	IN COMPLIANCE WITH THE EMERGENCY S	TATIONARY REGULATIONS.						
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR						
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 4.0 PM: 0.20						

Altitude Derate Data

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL	
ALTITUDE (FT	[)													
0	398	398	398	398	398	398	398	398	398	398	398	398	398	
1,000	398	398	398	398	398	398	398	398	398	398	395	389	398	
2,000	398	398	398	398	398	398	398	398	394	387	380	374	398	
3,000	398	398	398	398	398	398	393	386	379	372	366	360	398	
4,000	398	398	398	398	392	385	378	371	365	358	352	346	396	
5,000	398	398	392	384	377	370	363	357	351	345	339	333	384	
6,000	392	384	377	370	363	356	349	343	337	331	326	320	372	
7,000	377	369	362	355	349	342	336	330	324	318	313	308	360	
8,000	362	355	348	341	335	329	323	317	311	306	301	296	348	
9,000	348	341	334	328	322	316	310	304	299	294	289	284	337	
10,000	334	327	321	315	309	303	297	292	287	282	277	273	325	
11,000	320	314	308	302	296	291	285	280	275	271	266	262	314	
12,000	307	301	295	290	284	279	274	269	264	260	255	251	304	
13,000	295	289	283	278	272	267	263	258	253	249	245	241	293	
14,000	282	277	271	266	261	256	252	247	243	239	235	231	283	
15,000	271	265	260	255	250	246	241	237	233	229	225	221	273	

Cross Reference

Engine Arrangement								
Effective Serial Number	Engineering Model	Engineering Model Version						
S9L00001	GS279	-						
S9P00001	GS279	-						
S9P00001	GS857	LS						
1	Engine Arr Effective Serial Number S9L00001 S9P00001 S9P00001	Engine Arrangement Effective Serial Number Engineering Model S9L00001 GS279 S9P00001 GS279 S9P00001 GS857						

Test Specification Data						
Test Spec	Setting	Effective Serial Number	Engine Arrangement	Governor Type	Default Low Idle Speed	Default High Idle Speed
0K6612		S9L00001	2575707	ELEC		
0K6612		S9P00001	3950368	ELEC		
4150078	PP5548	S9P00001	3950368	ELEC		
4150078	PP5548	S9P00001	4529865	ELEC		
Performance Parameter Reference

Parameters Reference:DM9600-06 PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data

PERFORMANCE PARAMETER TOLERANCE FACTORS:

Power	+/- 3%
Torque	+/- 3%
Exhaust stack temperature	+/- 8%
Inlet airflow	+/- 5%
Intake manifold pressure-gage	+/- 10%
Exhaust flow	+/- 6%
Specific fuel consumption	+/- 3%
Fuel rate	+/- 5%
Specific DEF consumption	+/- 3%
DEF rate	+/- 5%
Heat rejection	+/- 5%
Heat rejection exhaust only	+/- 10%
Heat rejection CEM only	+/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

 C280/3600 HEAT REJECTION TOLERANCE FACTORS:

 Heat rejection
 +/- 10%

 Heat rejection to Atmosphere
 +/- 50%

 Heat rejection to Lube Oil
 +/- 20%

 Heat rejection to Affercooler
 +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque	+/- 0.5%
Speed	+/- 0.2%
Fuel flow	+/- 1.0%
Temperature	+/- 2.0 C degrees
Intake manifold pressure	+/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler

PERFORMANCE DATA[DM8501]

water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 (84.2), where the density is 838.9 G/Liter (7.001 Lbs/Gal).

GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/ CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set. Standard temperature values versus altitude could be seen on TM2001. When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative. Log on to the Technology and Solutions Divisions (T&SD) web page (https://pdgt.cat.com/cda/layout) for information including federal regulation applicability and time lines for implementation. Information for labeling and tagging requirements is also provided.

NOTES:

Regulation watch covers regulations in effect and future regulation changes for world, federal, state and local. This page includes

PERFORMANCE DATA[DM8501]

Additional product information for specific market application is available. Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500

EMISSIONS DEFINITIONS: Emissions : DM1176

SOUND DEFINITIONS: Sound Power : DM8702

Sound Pressure : TM7080

RATING DEFINITIONS: Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6036

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

Date Released : 5/12/14

4. COOLING UNIT SPECIFICATIONS



Completed By:	BP	[- Inputs -	● IP
Date:	8/12/2019]	- Outputs	● IP
Indiv	idual Unit Design Perfo	rmance (Based on N Uni	its)	

System Design Inputs			
Project location	Quin	cy, WA	
Project elevation	1,	229	ft
Total power consumed by servers	13	,704	kW
Target supply air temperature (Dry IEC)	72.0	72.0	Deg F
Max supply air temp (DX Target DX Peak)	72.0	76.0	Deg F
Design temperature rise through IT eqmt.	2	0.0	Deg F
Room air dew point	5	5.0	Deg F
Total Duct ESP (Process Scavenger)	0.50	0.00	IN-WC
Unit size	PV-W	60-PVT	
Number of units (N)	:	36	
Supply Air Isolation Damper	Include		
Return Air Isolation Damper	Include		
Scavenger Air Control Damper	√ In	clude	
Mechanical Cooling type	Direct Exp	ansion (DX)	
Condenser coil location	Scaveng	er Exhaust	
Cycles of Concentration		5.0	
	Critical	Operating	
Ambient DB	109.0	109.0	Deg F
Ambient WB	75.0	75.0	Deg F
% Design load		100.0%	13,704.0 kW
Rate performance for N+() units operating		8	
ESP Adjustment (Supply) Min	ax	80%	%

Estimated Unit Operating Performance (per unit)			
	Critical	Operating	
ITE load rejected	380.7	311.5	kW
Total heat rejected (ITE load + fan heat)	120	95	Refrigeration Tons
Heat rejected by IEC/HX	81.1	66.6	Refrigeration Tons
Mech. cooling required	39.0	28.9	Refrigeration Tons
Supply fan air volume	65,910	53,926	CFM
Supply fan calculated TSP	3.1	2.2	IN-WC
Scavenger fan air volume	43,450	35,484	CFM
Scavenger fan calculated TSP	1.3	0.9	IN-WC

Estimated Unit Electrical Performance (per unit)

	Critical	Operating	
Unit operating power (+/- 5%)	84	55	kW
Unit coefficient of performance	5.05	6.06	
Unit partial PUE	1.220	1.178	

Estimated Unit Water Performance (per unit)

	Critical	Operating	
Water evaporation rate	235.7	193.1	Gal/hr
Water bleed rate	58.9	48.3	Gal/hr
Total water consumption	294.6	241.4	Gal/hr
Unit WUE	2.93	2.93	L / kWh

*Estimated value. Accurate value to be determined from customer-supplied water analysis.



State Points at Critical Design Conditions (Water Sprays on)

	DB (°F)	WB (°F)	ACFM
1 (R/A)	96.0	68.9	65,910
2	98.2	69.6	66,171
3	83.2	65.0	64,393
4 (S/A)	76.0	62.6	63,063
5 (O/A)	109.0	75.0	43,859
6	81.0	78.5	42,448
7 (E/A)	93.7	81.5	43,450

State Points at Operating Rating Point Conditions (Water Sprays on)

	DB (°F)	WB (°F)	ACFM
1 (R/A)	96.0	68.9	53,926
2	97.6	69.4	54,077
3	82.5	64.8	52,618
4 (S/A)	76.0	62.6	51,597
5 (O/A)	109.0	75.0	35,885
6	81.0	78.5	34,732
7 (E/A)	92.7	81.2	35,484

Note: Performance values includes estimated supply fan heat



All Values are Preliminary

Data Center Cooling Analysis Program V1.601.16

Munters Data Center Cooling Systems

Bin Analysis

% Design load Redundancy Required, N+(_) Approximate percentage of units with filters

Number of Operating Units (N+8) Units With Filters Units Without Filters

100%	
44	
44	
0	

75.4%

8

ESP Adj (Supply) Min Supply ESP (all units operating) 80% IN-WC 0.21

%

Electricity Rate	\$0.000	\$/kWh
Water	\$0.000	\$/100 ft^3
Sewer	\$0.000	\$/100 ft^3

Max

Annual Performance Summary

Predicted Annual Power Use Predicted Annual Water Evaporated Predicted Annual Water Drained Predicted Annual Total Water Consumed

Total	Per Unit	
6,138,392	139,509	kWh
19,343.4	439.6	1,000 gal
5,273.0	119.8	1,000 gal
24,616.4	559.5	1,000 gal

10,328.0 kW

Predicted Annual Ton-Hours of Mechanical Cooling: Predicted Annual Ton-Hours of Dry HX Cooling: Predicted Annual Ton-Hours of IEC Cooling:

135,289	0.50%
10,452,021	38.58%
16,501,401	60.92%

Estimated system annualized COP Estimated System annualized partial PUE Estimated System annualized WUE



94.3%

Predicted Annual Hrs Mech. Cooling Active % Annual Hrs IASE Rejects 100% of load



O/A dry bulb temperature to enable IEC 44.6 Deg F 47.0 Deg F

O/A dry bulb temp where dry HX rejects total load

Predicted Cost of Electricity Used Predicted Cost of Water Evaporated Predicted Cost of Water Drained Predicted Cost of Water Predicted Total Annual Operating Cost

\$0
\$0
\$0
\$0
\$0



Ы	nned weather Da	ata	STSTEM TOTA	ALS (Based on	N+8 units oper	rating)										
				- /	SUPPLY	SCAVENGER		PUMP	COMPRESSOR	SUPPLY FAN	SCAVENGER	TOTAL SYSTEM	SYSTEM pPUE		SYSTEM COP	TOTAL SYSTEM
BIN	O/A MCDB	O/A WB	S/A Temp	R/A Temp	AIRFLOW PER	AIRFLOW PER	IASE COOLING	POWER	POWER	POWER	FAN POWER	POWER	(AT BIN	KW / TON	(AT BIN	ENERGY
HOURS	(°F)	(°F)	(°F)	(°F)	UNIT (ACFM)	UNIT (ACFM)	(% OF TOTAL)	(kW)	(kW)	(kW)	(kW)	(kW)	CONDITION)		CONDITION)	(kWh)
1	91.0	71.0	72.0	92.0	38,886	26.424	72%	96.8	492.1	545.5	139.4	1 317 0	1 128	0.4	83	1 318
39	93.7	69.0	72.0	92.0	38,886	26,219	78%	96.8	402.8	545.3	138.9	1 227 7	1 1 1 1 1 9	0.4	8.9	47 882
61	90.7	67.0	72.0	92.0	38.886	26.025	84%	96.8	324.0	545.1	136.5	1,146.4	1.111	0.4	9.5	69,930
154	86.4	65.0	72.0	92.0	38,886	25.838	90%	96.8	254.1	544.9	133.8	1 073 6	1 104	0.3	10 1	165.342
242	82.2	63.0	72.0	92.0	38,886	25.657	96%	96.8	191.9	544 7	131.2	1,008.7	1 098	0.3	10.8	244 095
384	78.5	61.0	72.0	92.0	38,886	23,450	100%	96.8	0.0	544.6	103.6	789.0	1.076	0.3	13.8	302,971
416	74.3	59.0	72.0	92.0	38.886	18,984	100%	96.8	0.0	544.6	59.3	744.7	1.072	0.2	14.6	309,797
431	70.8	57.0	72.0	92.0	38,886	16,531	100%	96.8	0.0	544.6	41.3	726.7	1.070	0.2	15.0	313,204
459	67.5	55.0	72.0	92.0	38,886	15,074	100%	96.8	0.0	544.6	32.5	717.9	1.070	0.2	15.1	329,516
473	64.7	53.0	72.0	92.0	38,886	15,230	100%	96.8	0.0	544.6	33.2	718.6	1.070	0.2	15.1	339,919
412	60.8	51.0	72.0	92.0	38,886	13,610	100%	96.8	0.0	544.6	24.7	710.1	1.069	0. <mark>2</mark>	15.3	292,573
340	59.2	49.0	72.0	92.0	38,886	12,308	100%	96.8	0.0	544.6	18.8	704.2	1.068	0.2	15.4	239,422
275	56.6	47.0	72.0	92.0	38,886	11,247	100%	96.8	0.0	544.6	14.2	699.6	1.068	0.2	15.5	192,378
394	53.8	45.0	72.0	92.0	38,886	10,371	100%	96.8	0.0	544.6	11.0	696.4	1.067	0.2	15.6	274,366
445	50.7	43.0	72.0	92.0	38,886	9,640	100%	96.8	0.0	544.6	8.7	694.1	1.067	0.2	15.7	308,867
447	47.7	41.0	72.0	92.0	38,886	9,023	100%	96.8	0.0	544.6	7.0	692.4	1.067	0.2	15.7	309,515
407	45.3	39.0	72.0	92.0	38,886	8,498	100%	96.8	0.0	544.6	5.8	691.2	1.067	0.2	15.7	281,320
409	41.8	37.0	72.0	92.0	38,886	20,756	100%	0.0	0.0	544.6	66.8	655.4	1.063	0.2	16.6	268,070
408	38.9	35.0	72.0	92.0	38,886	18,937	100%	0.0	0.0	544.6	52.3	640.9	1.062	0.2	17.0	261,486
503	35.7	33.0	72.0	92.0	38,886	17,302	100%	0.0	0.0	544.6	41.0	629.6	1.061	0.2	17.3	316,675
716	32.4	31.0	72.0	92.0	38,886	15,933	100%	0.0	0.0	544.6	33.0	621.6	1.060	0.2	17.5	445,056
498	30.5	29.0	72.0	92.0	38,886	15,241	100%	0.0	0.0	544.6	29.3	617.9	1.060	0.2	17.6	307,725
298	28.7	27.0	72.0	92.0	38,886	14,647	100%	0.0	0.0	544.6	26.4	615.0	1.060	0.2	17.7	183,257
245	26.1	25.0	72.0	92.0	38,886	13,884	100%	0.0	0.0	544.6	22.8	611.4	1.059	0.2	17.8	149,797
112	24.5	23.0	72.0	92.0	38,886	13,449	100%	0.0	0.0	544.6	20.9	609.5	1.059	0.2	17.8	68,268
92	22.3	21.0	72.0	92.0	38,886	12,907	100%	0.0	0.0	544.6	18.7	607.3	1.059	0.2	17.9	55,874
42	20.4	19.0	72.0	92.0	38,880	12,474	100%	0.0	0.0	544.0	10.9	605.5	1.059	0.2	18.0	25,432
29	18.1	17.0	72.0	92.0	38,880	11,993	100%	0.0	0.0	544.6	14.9	603.5	1.058	0.2	18.0	17,502
10	10.8	15.0	72.0	92.0	38,880	11,500	100%	0.0	0.0	544.0	13.2	600.5	1.058	0.2	18.1	9,629
1	13.7	13.0	72.0	92.0	38,886	10,000	100%	0.0	0.0	544.0	11.9	500.5	1.058	0.2	10.1	600
	12.0	11.0	12.0	32.0	30,000	10,303	100 /0	0.0	0.0	544.0	11.0	555.5	1.000	<u> </u>	10.1	000
																l
									-							
									-							
		<u> </u>		<u> </u>											<u> </u>	
		l		l		l									l	L
				1												
		1		1											1	
All Values are P	Preliminary				All Values are	Preliminary	1				1	1				

SYSTEM TOTALS (Based on N+8 units operating)								
H,O	H ₂ O	TOTAL H ₂ O	SYSTEM WUE	TOTAL H ₂ O				
	RIEED	LISAGE DATE		CONSUMED				
		USAGE RATE		(L CONSONIED				
(1,000 GAL/HR)	(1,000 GAL/HR)	(1,000 GAL/HR)	CONDITION)	(1,000 GAL)				
4.56	1.14	5.70	1.58	5.7				
5.31	1.33	6.63	1.83	258.7				
5.33	1.33	6.66	1.84	406.2				
5.18	1.29	6.47	1.79	996.9				
5.04	1.26	6.30	1.74	1,523.4				
4.74	1.18	5.92	1.64	2,274.1				
4.15	1.04	5.19	1.43	2,157.7				
3.83	0.96	4.79	1.32	2,065.0				
3.62	0.90	4.52	1.25	2,076.3				
3.52	0.88	4.41	1.22	2,083.6				
3.29	0.82	4.11	1.14	1,695.1				
3.24	0.81	4.05	1.12	1.377.2				
3.14	0.79	3.93	1.08	1.079.8				
3.05	0.76	3.81	1.05	1.500.4				
2.05	0.74	3.69	1.02	1,640.8				
2.33	0.77	3.59	0.99	1,040.0				
2.07	0.72	3.53	0.00	1 425 2				
2.02	0.00	3.03	0.97	1,430.5				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				
0.00	0.00	0.00	0.00	0.0				

Table D-1. General Cost Calculation Inputs

Number of Main Engines	30
Number of Support Engines	2
Bank Prime Rate (Dec. 2019) ¹	4.75%
Lifespan of SCR (yrs.) ²	25
Lifespan of DPF (yrs.) ²	25
Lifespan of DOC (yrs.) ²	25
Lifespan of Tier 4 Integrated Control System (yrs.)	25
CECPI 2016 (\$)	541.7
CECPI 2018 (\$)	603.1

¹ Capital recovery is calculated using a 4.75% annual interest rate, which is the bank prime rate as of December 2019.

² A 25-yr life span is conservatively assumed for the SCR system, consistent with the recent Vantage and CyrusOne applications and in accordance with Section 4, Chapter 2 of EPA APCCM, 7th Edition. A 25-year life span is conservatively assumed for the DPF, DOC, and Tier 4 Integrated Control System, consistent with the recent Vantage and CyrusOne applications.

Table D-2. Criteria Pollutant Emission Rates and Control Efficiencies¹

	Main	Support	SCR Removal	DPF Removal	DOC Removal	Tier 4 Removal
Pollutant	tpy	tpy	%	%	%	%
Particulate Matter (PM)	1.70	0.01	0%	90%	25%	88%
Carbon Monoxide (CO)	13.77	0.19	0%	80%	80%	80%
Volatile Organic Compounds (VOC)	1.02	0.02	0%	70%	70%	70%
Nitrogen Oxides (NO _X)	54.98	0.38	90%	0%	0%	90%

¹ Control technology removal efficiencies are consistent with calculations from recent Vantage and CyrusOne applications.

Table D-3. Toxic Air Pollutant Emission Rates and Control Efficiencies¹

	Main	Support	SCR Removal	DPF Removal	DOC Removal	Tier 4 Removal
Pollutant	tpy	tpy	%	%	%	%
Acrolein	1.55E-04	1.61E-05	0%	70%	70%	70%
Benzene	1.52E-02	1.62E-04	0%	70%	70%	70%
Benzo(a)pyrene	5.04E-06	3.27E-08	0%	70%	70%	70%
Dibenz(a,h)anthracene	6.79E-06	1.01E-07	0%	70%	70%	70%
Formaldehyde	1.55E-03	2.05E-04	0%	70%	70%	70%
Naphthalene	2.55E-03	1.47E-05	0%	70%	70%	70%
Xylenes	3.78E-03	4.95E-05	0%	70%	70%	70%
Diesel engine exhaust, particulate	1.70E+00	9.92E-03	0%	90%	25%	88%
Sulfur Dioxide (SO ₂)	3.64E-02	5.41E-02	0%	0%	0%	0%
Carbon Monoxide (CO)	1.38E+01	1.87E-01	0%	80%	80%	80%
Nitrogen Dioxide (NO ₂)	5.50E+00	3.77E-02	90%	0%	0%	90%

¹ Control technology removal efficiencies are consistent with calculations from recent Vantage and CyrusOne applications.

Table D-4. SCR Cost Calculation Inputs

MW of NH3 (g/mol)	17.03
MW of NOX (g/mol)	46.01
Ammonia Cost (\$/gal)	0.293
Operational Hours (hr/yr/engine)	55
Aqueous Ammonia Concentration (%w/w)	29%
Specific Gravity 29% ammonia ¹	0.9
Water density (lb/gal)	8.35
Size of main engines (MW)	2.25
NRF ²	1.125
$CC_{replace}$ (\$/ft ³) ³	227
Size of support engines (MW)	0.3

¹ The specific gravity of 29% ammonia is estimated as 0.9, per the aqua ammonia specific gravity chart from Inyo Process

 $(https://inyoprocess.com/images/chem_appl/aqua_ammonia_specific_gravity_chart.pdf)$

 2 NRF is the $NO_{\rm X}$ removal, as defined in the EPA Control Cost Manual, 7th Edition, Equation 2.41.

³ CC_{replace} is the cost of catalyst replacement. The value used is the catalyst replacement cost used in EPA Control Cost Manual, 7th Edition, Section 2.5, Example Problem #1.

BACT Cost Analysis for NO_{X} - SCR Option - Main and Support Gensets

Table D-5a. Capital Costs

Capital Cost	Description	C	alculated Cost	Reference
Direct Cost				
	Emission Control Package for 30 Main Engines	\$	5,082,765 ^a	А
	Emission Control Package for 2 Support Engines	\$	101,151 ⁱ	В
	Sales Tax	\$	336,955 ^b	C = WA State Tax of 6.5% x (A + B)
	Shipping	\$	259,196 ^b	D = 5% of package price x (A + B)
	Installation for 30 Main Engines	\$	390,000 ^c	Е
	Installation for 2 Support Engines	\$	26,000 ^c	F
Total Direct Cost		\$	6,196,067	TDC = A + B + C + D + E + F
Indirect Cost				
	Engineering	\$	96,000 ^d	G
	Construction and Field Expenses	\$	96,000 ^d	Н
	Contractor Fees	\$	421,333 ^d	I = 6.8% x (A + B + C + D + E + F)
	Startup	\$	96,000 ^d	J
	Performance Test	\$	61,960.67 ^d	K = 1% x (A + B + C + D + E + F)
	Contingencies	\$	185,882.00 ^d	L = 3% x (A + B + C + D + E + F)
Total Indirect Cost		\$	957,175	TIC = G + H + I + J + K + L
Total Capital Investment		\$	7,153,242	TCI = TDC + TIC

Table D-5b. Operating Costs

Operating Cost			Reference
Direct Annual Cost			
	Maintenance	\$ 35,766 ^e	M = 0.5% x TCI
	Catalyst Cost	\$ 264,214 ^e	N = {Cost of replacement catalyst}
	Reagent Consumption	\$ 5,222 ^f	O = {NO _X removal, cost of ammonia}
Total Direct Annual Costs		\$ 305,202	DAC = M + N + O
Indirect Annual Costs			
	Administrative Charges	\$ 3,597 ^b	P = 3% x ((Op. Labor Cost) + 40% x K)
	Property Tax	\$ 71,532.42 ^b	Q = 1% x TCI
	Insurance	\$ 71,532.42 ^b	R = 1% x TCI
		g	
	Capital Recovery	\$ 494,897.95	$CRC_S = TCI \times CRF$
Total Indirect Annual Costs		\$ 641,560	IDAC = P + Q + R + CRC
Total Annual Cost ^h		\$ 946,762	TAC = DAC + IDAC

^a Cost for SCR control package is the average unit price from Vantage (for the 3 MWe unit) and CyrusOne (for the 2250 kWe unit) multiplied by 30 engines.

^b Shipping costs are calculated in accordance to Table 2.4, Section 2.6.4, Chapter 2, Section 1 of EPA Air Pollution Control Cost Manual (APCCM), 7th Edition. Sales tax is calculated using the Washington state sales tax rate. Administrative charges calculated in accordance with Equation 2.69, Chapter 2, Section 4 of EPA Air Pollution Control Cost Manual. Operator labor cost used in the calculation of administrative charges is calculated assuming a maximum labor usage of 55 hr/yr/engine, which is the maximum number of operational hours for each engine. Operator labor cost is calculated using the labor rate in Section 4, Chapter 2, 2.5 of the EPA Air Pollution Control Cost Manual Example Problem #1. Administrative charges, property tax, and insurance are calculated according to Section 1, Chapter 2, 2.6.5.8 of the APCCM.

^c Cost for SCR instalation is the average price from Vantage (for the 3 MWe unit) and CyrusOne (for the 2250 unit) multiplied by 30 engines.

^d Each of the indirect capital costs are calculated following the most conservative approach between the Vantage and CyrusOne applications.

e Maintenance cost is calculated in accordance with Equation 2.57 of Chapter 2, Section 4 of EPA APCCM, 7th Edition. Catalyst cost is calculated per Equation 2.67, Chapter 2, Section 4 of EPA APCCM, 7th Edition.

^f Reagent consumption is calculated in accordance to Equation 2.35, Chapter 2, Section 4 of EPA APCCM. It is assumed that anhydrous ammonia is used for this BACT cost analysis, because "anhydrous ammonia typically has the lowest capital and operating costs" (page 2-12 of Chapter 2, Section 4 of EPA APCCM). It is assumed that the NQ removal efficiency is 90%, and the cost of ammonia is at the EPA default value of \$0.293/gal ammonia, as listed in Chapter 2, Section 4, 2.6 of the EPA APCCM. The control efficiency used in the Vantage and CyrusOne applications is 90%. Additionally, using anhydrous ammonia and other cost associated with demonstrating compliance with Risk Management Program, which are not included in this conservative cost calculation.

^g Capital recovery is calculated using a 4.75% annual interest rate, which is the bank prime rate as of December 2019, and a 25-yr life span for the SCR system, in accordance with Section 4, Chapter 2 of EPA APCCM, 7th Edition.

^h For annual operating cost, it is conservatively assumed that operating labor, supervisory labor, and electricity are negligible since the emission units will not be operated continuously.

ⁱ Costs for support genset control technology are scaled from main genset costs according to the 0.6 power rule.

Table D-5c. Criteria Pollutant Control Cost Effectiveness

Annual Control Cost for SCR		\$ 946,762	
		Total Removal	
	Ecology Acceptable Unit Cost (\$/ton)	(tpy)	Reasonable Annual Cost (\$/yr)
Removal efficiency of 90% for NOx	\$12,000	49.82 ^{a,c}	\$ 597,888.00
Total Reasonable Annual Cost for Com			\$ 597,888.00
	Is the control d	evice cost reasonable?	No

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

^c "Ecology Acceptable Unit Costs" are consistent with the cost thresholds used in CyrusOne and Vantage applications.

Table D-5d. Toxic Air Pollutant Control Cost Effectiveness

		ASIL Based Cost		Total Removal	Reasonable Annual	
Pollutant ^a	ASIL (µg/m ³)	Factor ^b	Ecology Acceptable Unit Cost (\$/ton) ^c	(tpy)	Cost (\$/yr) ^d	
Removal efficiency of 0% for Acrolein	3.50E-01	4.9	\$ 51,317	0.00E+00	\$-	
Removal efficiency of 0% for Benzene	1.30E-01	5.3	\$ 55,833	0.00E+00	\$-	
Removal efficiency of 0% for Benzo(a)pyrene	1.00E-03	7.4	\$ 78,029	0.00E+00	\$-	
Removal efficiency of 0% for Dibenz(a,h)anthracene	5.00E-04	7.7	\$ 81,190	0.00E+00	\$-	
Removal efficiency of 0% for Formaldehyde	1.70E-01	5.2	\$ 54,610	0.00E+00	\$-	
Removal efficiency of 0% for Naphthalene	2.90E-02	6.0	\$ 62,674	0.00E+00	\$-	
Removal efficiency of 0% for Xylenes	2.20E+02	2.1	\$ 21,934	0.00E+00	\$-	
Removal efficiency of 0% for Diesel engine exhaust, particulate	3.30E-03	6.9	\$ 72,585	0.00E+00	\$-	
Removal efficiency of 0% for Sulfur Dioxide (SO2)	6.60E+02	1.6	\$ 16,924	0.00E+00	\$-	
Removal efficiency of 0% for Carbon Monoxide (CO)	2.30E+04	0.1	\$ 731	0.00E+00	\$-	
Removal efficiency of 90% for Nitrogen Dioxide (NO2)	4.70E+02	1.8	\$ 18,472	4.98E+00	\$ 92,022.57	
Total Reasonable Annual Cost for Combined Pollutants						
Is the control device cost reasonable?						

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b ASIL Based Cost Factor derived from the Hanford Methodology. https://www.osti.gov/servlets/purl/991923 . Cost Factor = Log₀(27,000 / ASIL)

^c Assumes a maximum ceiling value of \$10,500/ton, as described in the Hanford Evaluation of Best Available Control Technology for Toxics (tBACT) Double Sheel Tank Farms Primary Ventilation Systems Supporting Waste Transfer Operations and consistent with other recent data center NOC applications.

d The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage application:

BACT Cost Analysis for CO, PM and VOC - Diesel Particulate Filter - Main and Support Gensets

Table D-6a. Capital Costs

Capital Cost	Description	Calc	ulated Cost	Reference
Direct Cost				
	Emission Control Package for 30 Main Engines	\$	3,023,685 ^a	А
	Emission Control Package for 2 Support Engine	\$	60,174 ^g	В
	Sales Tax	\$	200,451 ^b	C = WA State Tax of 6.5% x (A + B)
	Shipping	\$	154,192.95 ^b	D = 5% x (A + B)
	Instrumentation	\$	30,838.59 ^b	E = 1% x (A + B)
Total Direct Cost		\$	3,469,341	TDC = A + B + C + D + E
Indirect Cost				
	Engineering	\$	64,000 ^c	F
	Construction and Field Expenses	\$	_ c	G
	Contractor Fees	\$	235,915 °	H = 6.8% x (A + B + C + D + E)
	Startup	\$	48,000.00 ^c	Ι
	Performance Test	\$	34,693.41 ^c	J = 1% x (A + B + C + D + E)
	Contingencies	\$	104,080.24 ^c	K = 3% x (A + B + C + D + E)
Total Indirect Cost		\$	486,689	TIC = F + G + H + I + J + K
Total Capital Investment		\$	3,956,030	TCI = TDC + TIC

Table D-6b. Operating Costs

Operating Cost			Reference
Indirect Annual Costs ^e			
	Administrative Charges	\$ 79,121 ^b	$L = 2\% \times TCI$
	Property Tax	\$ 39,560 ^ь	$M = 1\% \times TCI$
	Insurance	\$ 39,560 ^ь	$N = 1\% \times TCI$
	Capital Recovery	\$ 273,698.45 ^d	$CRC_S = TCI \times CRF$
Total Indirect Annual Costs		\$ 431,940	IDAC = L + M + N + CRC
Total Annual Cost ^r		\$ 431,940 ^f	TAC = IDAC

^a Cost for diesel particulate filter control package is the average unit price from Vantage (for the 3 MWe unit) and CyrusOne (for the 2250 KWe unit) Data Centers.

^b Shipping costs and instrumentation costs are calculated in accordance to Table 2.4, Section 2.6.4, Chapter 2, Section 1 of EPA Air Pollution Control Cost Manual (APCCM), 7th Edition. Sales tax is calculated using the Washington state sales tax rate. Indirect annual costs are calculated per EPA APCCM Section 1, Chapter 2, 2.6.5.8.

^c Each of the indirect capital costs are calculated following the most conservative approach between the EPA Air Pollution Control Cost Manual - Sixth Edition, Section 6, Chapter 1, Vantage application and CyrusOne application.

^d Capital recovery is calculated using a 4.75% annual interest rate, which is the bank prime rate as of December 2019, and a 25-yr life span for the DPF, following the precedent of the Vantage and CyrusOne permit applications.

^e Indirect annual costs calculated in accordance with EPA Air Pollution Control Cost Manual - Sixth Edition, Section 6, Chapter 1.

^f For direct annual operating cost, it is conservatively assumed that operating labor, supervisory labor, and electricity are negligible since the emission units will not be operated continuously. The cost for maintenance is also conservatively assumed negligible, though the diesel particulate filter will require regular cleaning and maintenance.

^g Costs for support genset control technology are scaled from main genset costs according to the 0.6 power rule.

Table D-6c. Criteria Pollutant Control Cost Effectiveness

Annual Control Cost for Diesel Particulate Filter		\$ 431,940			
		Total Removal			
	Ecology Acceptable Unit Cost (\$/ton)	(tpy)		Cost Effectiveness (\$/ton)	
Removal efficiency of 90% for PM	\$12,000	1.54	a,c	5 18,467.14	
Removal efficiency of 80% for CO	\$5,000	11.17	a,c	5 55,840.00	
Removal efficiency of 70% for VOC	\$12,000	0.73	a,c	8,707.44	
	Total Reasonable Annual Cost for Combined Pollutants ^{a,b}				
	Is the control d	evice cost reasonable?		No	

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

^c "Ecology Acceptable Unit Costs" are consistent with the cost thresholds used in CyrusOne and Vantage applications.

Table D-6d. Toxic Air Pollutant Control Cost Effectiveness

					R	easonable	
		ASIL Based Cost		Total Removal	Ar	nual Cost	
Pollutant ^a	ASIL (µg/m ³)	Factor ^b	Ecology Acceptable Unit Cost (\$/ton) ^c	(tpy)		(\$/yr) ^d	
Removal efficiency of 70% for Acrolein	3.50E-01	4.9	\$ 51,317	1.19E-04	\$	6.13	
Removal efficiency of 70% for Benzene	1.30E-01	5.3	\$ 55,833	1.08E-02	\$	601.07	
Removal efficiency of 70% for Benzo(a)pyrene	1.00E-03	7.4	\$ 78,029	3.55E-06	\$	0.28	
Removal efficiency of 70% for Dibenz(a,h)anthracene	5.00E-04	7.7	\$ 81,190	4.82E-06	\$	0.39	
Removal efficiency of 70% for Formaldehyde	1.70E-01	5.2	\$ 54,610	1.23E-03	\$	66.99	
Removal efficiency of 70% for Naphthalene	2.90E-02	6.0	\$ 62,674	1.79E-03	\$	112.49	
Removal efficiency of 70% for Xylenes	2.20E+02	2.1	\$ 21,934	2.68E-03	\$	58.87	
Removal efficiency of 90% for Diesel engine exhaust, particulate	3.30E-03	6.9	\$ 72,585	1.54E+00	\$	111,768.18	
Removal efficiency of 0% for Sulfur Dioxide (SO2)	6.60E+02	1.6	\$ 16,924	0.00E+00	\$	-	
Removal efficiency of 80% for Carbon Monoxide (CO)	2.30E+04	0.1	\$ 731	1.12E+01	\$	8,162.00	
Removal efficiency of 0% for Nitrogen Dioxide (NO2)	4.70E+02	1.8	\$ 18,472	0.00E+00	\$	-	
Total Reasonable Annual Cost for Combined Pollutant							
			Is the control device	cost reasonable?		No	

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b ASIL Based Cost Factor derived from the Hanford Methodology. https://www.osti.gov/servlets/purl/991923. Cost Factor = Log₀(27,000 / ASIL) c Assumes a maximum ceiling value of \$10,500/ton, as described in the Hanford Evaluation of Best Available Control Technology for Toxics (tBACT) Double Sheel Tank Farms Primary Ventilation Systems Supporting Waste Transfer Operations and consisten with other recent data center NOC applications.

^d The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

DACI COSt Analysis for CO, r M and VOC - Dieser Oxidation Catalyst - Main and Support Gensel
--

Table D-7a. Capital Costs

Capital Cost	Description	Cal	culated Cost	Reference
Direct Cost				
	Emission Control Package for 30 Main Engines	\$	667,290 ^a	А
	Emission Control Package for 2 Support Engines	\$	13,280 ^g	В
	Sales Tax	\$	44,237 ^b	C = WA State Tax of 6.5% x (A + B)
	Shipping	\$	34,028.48 ^b	D = 5% x (A + B)
	Instrumentation	\$	6,805.70 ^b	E = 1% x (A + B)
Total Direct Cost		\$	765,641	TDC = A + B + C + D + E
Indirect Cost				
	Engineering	\$	19,141 ^c	F = 2.5% x (A + B + C + D + E)
	Construction and Field Expenses	\$	_ c	G
	Contractor Fees	\$	52,064 ^c	H = 6.8% x (A + B + C + D + E)
	Startup	\$	15,312.82 ^c	I = 2% x (A + B + C + D + E)
	Performance Test	\$	7,656.41 ^c	J = 1% x (A + B + C + D + E)
	Other instrumentation	\$	22,969.23 ^c	K = 3% x (A + B + C + D + E)
Total Indirect Cost		\$	117,143	TIC = F + G + H + I + J + K
Total Capital Investment		\$	882,784	TCI = TDC + TIC

Table D-7b. Operating Costs

Operating Cost			Reference
Indirect Annual Costs ^e			
	Administrative Charges	\$ 17,656 ^b	$L = 2\% \times TCI$
	Property Tax	\$ 8,828 ^b	$M = 1\% \times TCI$
	Insurance	\$ 8,828 ^b	$N = 1\% \times TCI$
	Capital Recovery	\$ 61,075.52 ^d	$CRC_S = TCI \times CRF$
Total Indirect Annual Costs		\$ 96,387	IDAC = L + M + N + CRC
Total Annual Cost ^f		\$ 96,387 ^f	TAC = DAC

^a Cost for diesel oxidation catalyst control package is the average unit price from Vantage (for the 3 MWe unit) and CyrusOne (for the 2250 kWe unit) data centers.

^b Shipping costs and instrumentation costs are calculated in accordance to Table 2.4, Section 2.6.4, Chapter 2, Section 1 of EPA Air Pollution Control Cost Manual (APCCM), 7th Edition. Sales tax is calculated using the Washington state sales tax rate. Indirect annual costs are calculated per EPA APCCM Section 1, Chapter 2, 2.6.5.8.

^c Each of the indirect capital costs are calculated following the most conservative approach between the Vantage and CyrusOne applications.

^d Capital recovery is calculated using a 4.75% annual interest rate, which is the bank prime rate as of December 2019, and a 25-yr life span for the DOC, following the precedence of the Vantage and CyrusOne permit applications.

^e Indirect annual costs calculated in accordance with EPA Air Pollution Control Cost Manual - Sixth Edition, Section 6, Chapter 1.

^f For direct annual operating cost, it is conservatively assumed that operating labor, supervisory labor, and electricity are negligible since the emission units will not be operated continuously. The cost for maintenance is also assumed negligible, since diesel oxidation catalyst requires minimal maintenance once properly installed. The cost for catalyst replacement is conservatively assumed to be zero.

^g Costs for support genset control technology are scaled from main genset costs according to the 0.6 power rule.

Table D-7c. Criteria Pollutant Control Cost Effectiveness

Annual Control Cost for Diesel Oxidation Catalyst		\$ 96,3	87		
	Ecology Acceptable Unit Cost (\$/ton)	Total Removal (1	tpy)	Re	easonable Annual Cost (\$/yr)
Removal efficiency of 25% for PM	\$12,000	0.43	a,c	\$	5,129.76
Removal efficiency of 80% for CO	\$5,000	11.17	a,c	\$	55,840.00
Removal efficiency of 70% for VOC	\$12,000	0.73	a,c	\$	8,707.44
Total Reasonable Annual Cost for Combined Pollutants ^{a,b}					69,677.20
	Is the control d	levice cost reasona	ble?		No

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

^c "Ecology Acceptable Unit Costs" are consistent with the cost thresholds used in CyrusOne and Vantage applications.

Table D-7d. Toxic Air Pollutant Control Cost Effectiveness

					R	leasonable	
		ASIL Based Cost		Total Removal	A	nnual Cost	
Pollutant ^a	ASIL (µg/m ³)	Factor ^b	Ecology Acceptable Unit Cost (\$/ton) ^c	(tpy)		(\$/yr) ^d	
Removal efficiency of 70% for Acrolein	3.50E-01	4.89	\$ 51,317	1.19E-04	\$	6.13	
Removal efficiency of 70% for Benzene	1.30E-01	5.32	\$ 55,833	1.08E-02	\$	601.07	
Removal efficiency of 70% for Benzo(a)pyrene	1.00E-03	7.43	\$ 78,029	3.55E-06	\$	0.28	
Removal efficiency of 70% for Dibenz(a,h)anthracene	5.00E-04	7.73	\$ 81,190	4.82E-06	\$	0.39	
Removal efficiency of 70% for Formaldehyde	1.70E-01	5.20	\$ 54,610	1.23E-03	\$	66.99	
Removal efficiency of 70% for Naphthalene	2.90E-02	5.97	\$ 62,674	1.79E-03	\$	112.49	
Removal efficiency of 70% for Xylenes	2.20E+02	2.09	\$ 21,934	2.68E-03	\$	58.87	
Removal efficiency of 25% for Diesel engine exhaust, particulate	3.30E-03	6.91	\$ 72,585	4.28E-01	\$	31,046.72	
Removal efficiency of 0% for Sulfur Dioxide (SO2)	6.60E+02	1.61	\$ 16,924	0.00E+00	\$	-	
Removal efficiency of 80% for Carbon Monoxide (CO)	2.30E+04	0.07	\$ 731	1.12E+01	\$	8,162.00	
Removal efficiency of 0% for Nitrogen Dioxide (NO2)	4.70E+02	1.76	\$ 18,472	0.00E+00	\$	-	
Total Reasonable Annual Cost for Combined Pollutants							
			Is the control device	cost reasonable?		No	

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b ASIL Based Cost Factor derived from the Hanford Methodology. https://www.osti.gov/servlets/purl/991923 . Cost Factor = Log₁₀(27,000 / ASIL) c Assumes a maximum ceiling value of \$10,500/ton, as described in the Hanford Evaluation of Best Available Control Technology for Toxics (tBACT) Double Sheel Tank Farms Primary Ventilation Systems Supporting Waste Transfer Operations and consistent with other recent data center NOC applications.

^d The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

Capital Cost	Description	Ca	lculated Cost	Reference
Direct Cost				
	Emission Control Package for 30 Main Engines	\$	7,701,450 ^a	А
	Emission Control Package for 2 Support Engin	\$	153,266 ^f	В
	Sales Tax	\$	510,557 ^b	C = WA State Tax of 6.5% x (A + B)
	Shipping	\$	392,735.78 ^b	D = 5% x (A + B)
	Instrumentation	\$	78,547.16 ^b	E = 1% x (A + B)
Total Direct Cost		\$	8,836,555	TDC = A + B + C + D + E
Indirect Cost				
	Engineering	\$	160,000 ^c	F
	Construction and Field Expenses	\$	96,000 ^c	G
	Contractor Fees	\$	600,886 ^c	H = 6.8% x (A + B + C + D + E)
	Startup	\$	96,000.00 ^c	Ι
	Performance Test	\$	88,365.55 ^c	J = 1% x (A + B + C + D + E)
	Contingencies	\$	265,096.65 ^c	K = 3% x (A + B + C + D + E)
Total Indirect Cost		\$	1,306,348	TIC = F + G + H + I + J + K
Total Capital Investment		\$	10,142,903	TCI = TDC + TIC

BACT Cost Analysis for CO, PM, NO_x and VOC - Tier 4 Integrated Control Package - Main and Support Gensets

Table D-8a. Capital Costs

Table D-8b. Operating Costs

Operating Cost				Reference
Indirect Annual Costs				
	Administrative Charges	:	\$ 202,858 ^b	$L = 2\% \times TCI$
	Property Tax	:	\$ 101,429 ^b	$M = 1\% \times TCI$
	Insurance	:	\$ 101,429 ^b	$N = 1\% \times TCI$
	Capital Recovery	:	\$ 701,738.01 ^d	$CRC_S = TCI \times CRF$
Total Indirect Annual Costs			\$ 1,107,454	IDAC = L + M + N + CRC
Total Annual Cost ^e		1	\$ 1,107,454 ^e	TAC = IDAC

^a Cost for tier 4 integrated control package is the average unit price from Vantage (for the 3 MWe unit) and CyrusOne (for the 2250 kWe unit) data centers.

^b Shipping costs and instrumentation costs are calculated in accordance to Table 2.4, Section 2.6.4, Chapter 2, Section 1 of EPA Air Pollution Control Cost Manual (APCCM), 7th Edition. Sales tax is calculated using the Washington state sales tax rate. Indirect annual costs are calculated per EPA APCCM Section 1, Chapter 2, 2.6.5.8

^c Each of the indirect capital costs are calculated following the most conservative approach between the Vantage and CyrusOne applications.

^d Capital recovery is calculated using a 4.75% annual interest rate, which is the bank prime rate as of December 2019, and a 25-yr life span for the DOC, following the precedence of the Vantage and CyrusOne permit applications.

e For annual operating cost, it is conservatively assumed that operating labor, supervisory labor, and electricity are negligible since the emission units will not be operated continuously. The cost for maintenance is also conservatively assumed negligible.

^f Costs for support genset control technology are scaled from main genset costs according to the 0.6 power rule.

Table D-8c. Criteria Pollutant Control Cost Effectiveness

Annual Control Cost for Diesel Oxidation Catalyst		\$ 1,107,454		
		Total Removal		
	Ecology Acceptable Unit Cost (\$/ton)	(tpy)		Reasonable Annual Cost (\$/yr)
Removal efficiency of 88% for PM	\$12,000	1.50 ^{a,}	° \$	18,056.76
Removal efficiency of 80% for CO	\$5,000	11.17 ^{a,}	\$	55,840.00
Removal efficiency of 70% for VOC	\$12,000	0.73 ^{a,}	° \$	8,707.44
Removal efficiency of 90% for NOx	\$12,000	49.82 ^{a,}	\$	597,888.00
	^b \$	680,492.20		
	Is the control d	evice cost reasonable?		No

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

^c "Ecology Acceptable Unit Costs" are consistent with the cost thresholds used in CyrusOne and Vantage applications.

Table D-8d. Toxic Air Pollutant Control Cost Effectiveness

					F	Reasonable
		ASIL Based Cost		Total Removal	A	nnual Cost
Pollutant ^a	ASIL (µg/m ³)	Factor ^b	Ecology Acceptable Unit Cost (\$/ton) ^c	(tpy)		$(\$/yr)^d$
Removal efficiency of 70% for Acrolein	3.50E-01	4.89	\$ 51,317	1.19E-04	\$	6.13
Removal efficiency of 70% for Benzene	1.30E-01	5.32	\$ 55,833	1.08E-02	\$	601.07
Removal efficiency of 70% for Benzo(a)pyrene	1.00E-03	7.43	\$ 78,029	3.55E-06	\$	0.28
Removal efficiency of 70% for Dibenz(a,h)anthracene	5.00E-04	7.73	\$ 81,190	4.82E-06	\$	0.39
Removal efficiency of 70% for Formaldehyde	1.70E-01	5.20	\$ 54,610	1.23E-03	\$	66.99
Removal efficiency of 70% for Naphthalene	2.90E-02	5.97	\$ 62,674	1.79E-03	\$	112.49
Removal efficiency of 70% for Xylenes	2.20E+02	2.09	\$ 21,934	2.68E-03	\$	58.87
Removal efficiency of 88% for Diesel engine exhaust, particulate	3.30E-03	6.91	\$ 72,585	1.51E+00	\$	109,284.44
Removal efficiency of 0% for Sulfur Dioxide (SO2)	6.60E+02	1.61	\$ 16,924	0.00E+00	\$	-
Removal efficiency of 80% for Carbon Monoxide (CO)	2.30E+04	0.07	\$ 731	1.12E+01	\$	8,162.00
Removal efficiency of 90% for Nitrogen Dioxide (NO2)	4.70E+02	1.76	\$ 18,472	4.98E+00	\$	92,022.57
			Total Reasonable Annual Cost for Com	bined Pollutants	\$	210,315.23
			Is the control device	cost reasonable?		No

^a Removal efficiencies are consistent with recent CyrusOne and Vantage cost calculations.

^b ASIL Based Cost Factor derived from the Hanford Methodology. https://www.osti.gov/servlets/purl/991923 . Cost Factor = Log₀(27,000 / ASIL)

c Assumes a maximum ceiling value of \$10,500/ton, as described in the Hanford Evaluation of Best Available Control Technology for Toxics (tBACT) Double Shell Tank Farms Primary Ventilation Systems Supporting Waste Transfer Operations and consistent with other recent data center NOC applications.

^d The total reasonable annual cost compared to the actual annual control cost demonstrates that the control is cost prohibitive. This is consistent with CyrusOne and Vantage applications.

Table E-1a. For Each Main Genset - Criteria Pollutant Model Parameters

	Averaging	Modeled	Modeled Load	Stack Height	Temp	Exit Velocity	Diameter	Emission Rate ²
Pollutant	Period	Configuration	Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/engine)
NO _X	1-hr	D12	100%	18.29	724.15	47.56	0.46	8.401E+00
NO _X	Annual	D18	100%	18.29	724.15	47.56	0.46	5.271E-02
PM ₁₀ /PM _{2.5}	24-hr	D12	100%	18.29	724.15	47.56	0.46	3.412E-01
PM _{2.5}	Annual	D12	10%	18.29	587.04	11.50	0.46	1.033E-03
CO	1-hr	D12	25%	18.29	659.26	18.63	0.46	1.593E+00
CO	8-hr	D12	25%	18.29	659.26	18.63	0.46	1.593E+00
SO ₂	1-hr	D12	100%	18.29	724.15	47.56	0.46	5.566E-03
SO ₂	3-hr	D12	100%	18.29	724.15	47.56	0.46	5.566E-03

¹ Stack temperature and exit velocity are specific to the percent engine load. The load that would result in maximum offsite concentration specific to the pollutant is listed here based on the load analysis results. The minimum stack temperature and exit velocity across all possible manufacturers is used for conservatism.

The emission rates for short-term (1-hr, 3-hr, 8-hr and 24-hr) models are calculated assuming each engine operates continuously for the modeled period (except for 1-hr NQ and 24-hr PM25 NAAQS modeling where not all engines are modeled with simultaneous operations). Maximum hourly emission rates across all vendors corresponding to the modeled load scenario are listed here. For annual models, the maximum hourly emission rates corresponding to the modeled load are scaled based on the proposed hours of operations per year below to obtain the annual modeled emission rate: 55

Maximum Hours of Operation per Year:

Table E-1b. For Each Support Genset - Criteria Pollutant Model Parameters

				Stack				
	Averaging	Modeled	Modeled Load	Height	Temp	Exit Velocity	Diameter	Emission Rate ²
Pollutant	Period	Configuration	Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/engine)
NO _X	1-hr	N/A	100%	3.66	770.48	58.97	0.15	8.632E-01
NO _X	Annual	N/A	100%	3.66	770.48	58.97	0.15	5.417E-03
PM ₁₀ /PM _{2.5}	24-hr	N/A	10%	3.66	540.93	15.91	0.15	4.891E-02
PM _{2.5}	Annual	N/A	10%	3.66	540.93	15.91	0.15	2.993E-04
CO	1-hr	N/A	50%	3.66	691.21	44.37	0.15	4.541E-01
CO	8-hr	N/A	50%	3.66	691.21	44.37	0.15	4.541E-01
SO ₂	1-hr	N/A	100%	3.66	770.48	58.97	0.15	1.240E-01
SO ₂	3-hr	N/A	100%	3.66	770.48	58.97	0.15	1.240E-01

¹ Stack temperature and exit velocity are specific to the percent engine load. The load that would result in maximum offsite concentration specific to the pollutant is listed here based on the load analysis results. The minimum stack temperature and exit velocity across all possible manufacturers is used for conservatism.

The emission rates for short-term (1-hr, 3-hr, 8-hr and 24-hr) models are calculated assuming each engine operates continuously for the modeled period (except for 1-hr NQ and 24-hr PM25 NAAQS modeling where not all engines are modeled with simultaneous operations). Maximum hourly emission rates across all vendors corresponding to the modeled load scenario are listed here. For annual models, the maximum hourly emission rates corresponding to the modeled load are scaled based on the proposed hours of operations per year below to obtain the annual modeled emission rate:

Maximum Hours of Operation per Year: 55

Table E-2a. For Each Main Genset - TAP Model Parameters

				Stack				
	Averaging	Modeled	Modeled Load	Height	Temp	Exit Velocity	Diameter	Emission Rate ^{2,3}
Pollutant	Period	Configuration	Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/engine)
Acrolein	24-hr	D12	100%	18.29	724.15	47.56	0.46	2.360E-05
Naphthalene	year	D18	100%	18.29	724.15	47.56	0.46	2.444E-06
Benzene	year	D18	100%	18.29	724.15	47.56	0.46	1.459E-05
Diesel Engine Exhaust, Particulate	year	D18	100% - Cummins DQKAN ¹	18.29	823.15	52.52	0.46	1.631E-03
со	1-hr	D12	25%	18.29	659.26	18.63	0.46	1.593E+00
SO ₂	1-hr	D12	100%	18.29	724.15	47.56	0.46	5.566E-03
NO ₂	1-hr	D12	100%	18.29	724.15	47.56	0.46	8.401E+00

¹ Stack temperature and exit velocity are specific to the percent engine load. The load that would result in maximum offsite concentration specific to the pollutant is listed here based on the load analysis results. The minimum stack temperature and exit velocity across all possible manufacturers is used for conservatism, except for the diesel engine exhaust particulate model. A separate analysis was conducted to determine the worst-case manufacturer specifications, which paired the manufacturer emission rate and stack temperature and velocity. Cummins was determined to have the specifications that would result in the highest offsite concentration based on the load analysis for diesel engine exhaust particulate.

² The emission rates for annual averaging period models are calculated assuming the following total number of hours of operation per year for each engine:

Maximum Hours of Operation per Year: 55

The emission rates for 24-hr and 1-hr models are calculated assuming each engine operates continuously for an entire day or hour, respectively. The CO emission rate is calculated using the Tier 2 standard under 40 CFR 89.112(a) and the maximum horsepower of all of the possible engine options. The NO_x emission rate is calculated using the maximum NO_x emission rate of all of the possible engine options.

Table E-2b. For Each Support Genset - TAP Model Parameters

	Averaging	Modeled	Modeled Load	Height	Temp	Exit Velocity	Diameter	Emission Rate ^{2,3}
Pollutant	Period	Configuration	Scenario ¹	(m)	(K)	(m/s)	(m)	(g/s/engine)
Acrolein	24-hr	N/A	100%	3.66	770.48	58.97	0.15	3.684E-05
Naphthalene	year	N/A	100%	3.66	770.48	58.97	0.15	2.120E-07
Benzene	year	N/A	100%	3.66	770.48	58.97	0.15	1.555E-07
Diesel Engine Exhaust, Particulate	year	N/A	50% - Cummins	3.66	691.48	44.37	0.15	1.427E-04
CO	1-hr	N/A	50%	3.66	691.21	44.37	0.15	4.541E-01
SO ₂	1-hr	N/A	100%	3.66	770.48	58.97	0.15	1.240E-01
NO ₂	1-hr	N/A	100%	3.66	770.48	58.97	0.15	8.632E-01

¹ Stack temperature and exit velocity are specific to the percent engine load. The load that would result in maximum offsite concentration specific to the pollutant is listed here based on the load analysis results. The minimum stack temperature and exit velocity across all possible manufacturers is used for conservatism, except for the diesel engine exhaust particulate model. A separate analysis was conducted to determine the worst-case manufacturer specifications, which paired the manufacturer emission rate and stack temperature and velocity. Cummins was determined to have the specifications that would result in the highest offsite concentration based on the load analysis for diesel engine exhaust particulate.

² The emission rates for annual averaging period models are calculated assuming the following total number of hours of operation per year for each engine:

Maximum Hours of Operation per Year: 55

³ The emission rates for 24-hr and 1-hr models are calculated assuming each engine operates continuously for an entire day or hour, respectively. The CO emission rate is calculated using the Tier 2 standard under 40 CFR 89.112(a) and the maximum horsepower of all of the possible engine options. The NO_x emission rate is calculated using the maximum NO_x emission rate of all of the possible engine options.

Engine		UTM X	UTM Y	Elevation
Model ID	Description	(m)	(m)	(m)
D1	D1 - Building D	286,886.10	5,236,186.20	396.24
D2	D2 - Building D	286,885.80	5,236,175.60	396.15
D3	D3 - Building D	286,885.20	5,236,167.80	396.09
D4	D4 - Building D	286,883.90	5,236,141.40	395.90
D5	D5 - Building D	286,883.60	5,236,133.90	395.85
D6	D6 - Building D	286,883.00	5,236,123.00	395.76
D7	D7 - Building D	287,099.40	5,236,176.80	395.35
D8	D8 - Building D	287,098.70	5,236,166.20	395.25
D9	D9 - Building D	287,098.10	5,236,157.40	395.16
D10	D10 - Building D	287,096.90	5,236,130.80	394.87
D11	D11 - Building D	287,097.20	5,236,124.90	394.80
D12	D12 - Building D	287,095.90	5,236,113.90	394.70
D13	D13 - Building D	286,919.30	5,236,101.70	395.37
D14	D14 - Building D	286,934.90	5,236,101.40	395.28
D15	D15 - Building D	286,950.60	5,236,101.00	395.22
D16	D16 - Building D	287,016.40	5,236,097.60	394.89
D17	D17 - Building D	287,032.00	5,236,096.40	394.83
D18	D18 - Building D	287,047.70	5,236,095.40	394.74
E1	E1 - Building E	286,589.80	5,236,110.00	395.87
E2	E2 - Building E	286,589.00	5,236,099.80	395.78
E3	E3 - Building E	286,589.00	5,236,092.00	395.65
E4	E4 - Building E	286,587.80	5,236,065.30	395.33
E5	E5 - Building E	286,587.40	5,236,057.80	395.25
E6	E6 - Building E	286,587.00	5,236,046.90	395.14
E7	E7 - Building E	286,803.50	5,236,101.40	395.83
E8	E8 - Building E	286,803.10	5,236,090.80	395.73
E9	E9 - Building E	286,803.10	5,236,082.20	395.62
E10	E10 - Building E	286,801.50	5,236,055.50	395.32
E11	E11 - Building E	286,801.10	5,236,049.60	395.25
E12	E12 - Building E	286,800.70	5,236,038.20	395.08
E13	E13 - Building E	286,622.90	5,236,025.80	394.83
E14	E14 - Building E	286,638.70	5,236,024.90	394.82
E15	E15 - Building E	286,654.10	5,236,024.50	394.81
E16	E16 - Building E	286,720.10	5,236,021.50	394.88
E17	E17 - Building E	286,735.90	5,236,020.70	394.88
E18	E18 - Building E	286,751.30	5,236,019.80	394.87
S1	Support Genset	286,991.00	5,236,103.40	395.07
S2	Support Genset	286,693.30	5,236,028.00	394.94

Table E-3. Engine Locations

Table E-4a. For Each Main Genset - Load Analysis Parameters

																									Modeled
						Stack		Exit		Maximum Ho	urly Emission Rate, V	Warm Engine ²	Maximum	Iourly Emission Rat	e, Cold Start				Maximum H	ourly Modeled Er	nission Rate				Emission Rate
	Operation	Flow Rate ¹	Diameter	Temp ¹	Stack Height	Height	Temp	Velocity	Diameter		(lb/hr/engine)			(lb/hr/engine)		Annual	Emission Rate (tpy/	(engine)		(g/s/engine)		Annual Mode	led Emission Rat	e (g/s/engine)	for TAPs ³
	Load	(acfm)	(ft)	(°F)	(ft)	(m)	(K)	(m/s)	(m)	NOx	PM ₁₀ /PM _{2.5}	CO	NOx	PM ₁₀ /PM _{2.5}	CO	NOx	PM ₁₀ /PM _{2.5}	CO	NOx	PM ₁₀ /PM _{2.5}	CO	NOx	PM ₁₀ /PM _{2.5}	CO	(g/s/engine)
	10%	4,002	1.50	597.0	60.0	18.29	587.04	11.50	0.46	7.02	1.27	6.01	7.01	1.34	6.81	0.19	0.04	0.18	8.845E-01	1.687E-01	8.577E-01	5.550E-03	1.033E-03	5.074E-03	31.30
	25%	6,482	1.50	727.0	60.0	18.29	659.26	18.63	0.46	9.81	1.38	11.16	9.80	1.46	12.65	0.27	0.04	0.33	1.236E+00	1.839E-01	1.593E+00	7.757E-03	1.125E-03	9.427E-03	58.70
	50%	10,902	1.50	821.0	60.0	18.29	711.48	31.34	0.46	20.34	1.49	6.06	20.32	1.57	6.87	0.56	0.04	0.18	2.563E+00	1.980E-01	8.656E-01	1.608E-02	1.211E-03	5.121E-03	102.80
	75%	14,174	1.50	836.6	60.0	18.29	720.15	40.75	0.46	34.67	2.05	15.63	34.63	2.16	17.71	0.95	0.06	0.46	4.368E+00	2.719E-01	2.231E+00	2.741E-02	1.664E-03	1.320E-02	151.00
	100%	16,546	1.50	843.8	60.0	18.29	724.15	47.56	0.46	66.67	2.57	12.04	66.60	2.71	13.64	1.83	0.07	0.35	8.401E+00	3.412E-01	1.719E+00	5.271E-02	2.088E-03	1.017E-02	173.50
¹ Fl	low rate and te	nperature are the lowes	st (i.e., most conservati	ive) parameters acr	oss all vendors (see L	oad Emissions t	ables) for each lo	ad.																	
² M	laximum hourly	emission rate across all	ll vendors (see Load Er	nissions tables) for	each load. The maxin	um emission ra	tes are for Tier 2	engines.																	
² E	missions for TA	Ps are on linear scale wi	ith the fuel consumpti	on rate. Therefore.	the load analysis for T	APs used the m	aximum hourly c	onsumption rate	across all vendo	ors (see Load Emiss	ions tables) in lieu of the	emission rate in g	/s for each load to	evaluate which load may	contribute the max	imum offsite									
c	oncentration.																								

Table E-4b. For Each Support Genset - Load Analysis Parameters

	Operation	Flow Rate ¹	Diameter	Temp ¹	Stack Height	Stack Height	Temp	Exit Velocity	Diameter	Maximum Ho	urly Emission Rate, (lb/hr/engine)	Warm Engine ²	Maximum	Hourly Emission Rat (lb/hr/engine)	te, Cold Start	Annual	Emission Rate (tpy,	/engine)	Maximum H	ourly Modeled Ei (g/s/engine)	mission Rate	Annual Mode	led Emission Rat	e (g/s/engine)	Modeled Emission Rate for TAPs ³
	Load	(acfm)	(ft)	(°F)	(ft)	(m)	(K)	(m/s)	(m)	NOx	PM ₁₀ /PM _{2.5}	co	NOx	PM ₁₀ /PM _{2.5}	CO	NOx	PM ₁₀ /PM _{2.5}	со	NOx	PM10/PM25	CO	NOx	PM ₁₀ /PM _{2.5}	со	(g/s/engine)
Γ	10%	615	0.50	514	12.0	3.66	540.93	15.91	0.15	0.48	0.37	0.63	0.48	0.39	0.71	0.01	0.01	0.02	0.0604790	0.0489101	0.0896687	3.795E-04	2.993E-04	5.305E-04	5.20
	25%	1,100	0.50	678	12.0	3.66	632.04	28.45	0.15	0.64	0.27	1.60	0.64	0.28	1.82	0.02	0.01	0.05	0.0806386	0.0358716	0.2291852	5.060E-04	2.195E-04	1.356E-03	8.70
	50%	1,715	0.50	785	12.0	3.66	691.21	44.37	0.15	1.19	0.33	3.18	1.19	0.35	3.60	0.03	0.01	0.09	0.1499375	0.0438431	0.4540731	9.409E-04	2.683E-04	2.686E-03	13.60
	75%	2,109	0.50	826	12.0	3.66	714.43	54.57	0.15	2.60	0.19	1.10	2.59	0.20	1.24	0.07	0.01	0.03	0.3270313	0.0252430	0.1568486	2.052E-03	1.545E-04	9.279E-04	17.65
L	100%	2,279	0.50	927	12.0	3.66	770.48	58.97	0.15	6.85	0.18	0.60	6.84	0.19	0.68	0.19	0.01	0.02	0.8632361	0.0239144	0.0859444	5.417E-03	1.463E-04	5.084E-04	23.07

 Description
 <thDescription</th>
 <thDescription</th>

Table E-5. For Each Engine - DPM Load Analysis

	•													Maximum
														Annualized
	1		1		Stack		Exit		DPM Maxim	um Hourly	DPM Maxim	um Hourly	DPM Annual	Modeled
Operation	Flow Rate	Diameter	Temp	Stack Height	Height	Temp	Velocity	Diameter	Emissio	n Rate ¹	Emission Rat	e, Cold Start	Emissions	Emission Rate
LUAU	(aciii)	(it)	(r)	(II)	(III)	(K)	(III/S) CAT (9 - 300	LIII)	(ib/iii/eligiiie)	(g/s/engine)	(ib/iii/engine)	(g/s/engine)	(ib/yi/engine)	(g/s/engine)
10%	851	0.50	650.3	12.0	3.66	616.65	22.02	0.15	0.06	7 560F-03	0.06	7971F-03	3 3 9	4 878F-05
25%	1300	0.50	745.0	12.0	3.66	669.26	33.63	0.15	0.00	1 260F-02	0.00	1 329F-02	5.65	8 130F-05
50%	1811	0.50	7845	12.0	3.66	691.20	46.84	0.15	0.15	1.890E-02	0.16	1.993E-02	848	1 220E-04
75%	2109	0.50	826.3	12.0	3.66	714.43	54.57	0.15	0.07	8.820E-03	0.07	9.300E-03	3.96	5.691E-05
100%	2461	0.50	927.2	12.0	3.66	770.48	63.67	0.15	0.07	8.820E-03	0.07	9.300E-03	3.96	5.691E-05
						Cumi	nins DODAC ·	300 kW						
10%	615	0.50	514.0	12.0	3.66	540.93	15.91	0.15	0.08	9.479E-03	0.08	9.995E-03	4.25	6.116E-05
25%	1.100	0.50	678.0	12.0	3.66	632.04	28.45	0.15	0.13	1.580E-02	0.13	1.666E-02	7.09	1.019E-04
50%	1.715	0.50	785.0	12.0	3.66	691.48	44.37	0.15	0.18	2.212E-02	0.19	2.332E-02	9.92	1.427E-04
75%	2,119	0.50	915.0	12.0	3.66	763 71	54.81	0.15	0.08	9 479E-03	0.08	9 995E-03	425	6116E-05
100%	2,279	0.50	990.0	12.0	3.66	805 37	58.97	0.15	0.08	1 011E-02	0.08	1.066E-02	4 5 4	6 524E-05
10070	2,2 , , ,	0.00	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	1210	0.00	CAT 3	516C - Tier 2.	2500 kW	0100	101112 02	0.00	1.0001 01	101	0.0212.00
10%	4,800	1.50	647.3	60.0	18.29	614.98	13.80	0.46	0.31	3.906E-02	0.33	4.119E-02	17.52	2.520E-04
25%	7,845	1.50	831.1	60.0	18.29	717.09	22.55	0.46	0.31	3.906E-02	0.33	4.119E-02	17.52	2.520E-04
50%	12,413	1.50	850.7	60.0	18.29	727.98	35.68	0.46	0.29	3.654E-02	0.31	3.853E-02	16.39	2.358E-04
75%	15,893	1.50	858.5	60.0	18.29	732.32	45.69	0.46	0.27	3.402E-02	0.28	3.587E-02	15.26	2.195E-04
100%	19,579	1.50	915.2	60.0	18.29	763.82	56.28	0.46	0.41	5.166E-02	0.43	5.447E-02	23.18	3.333E-04
						Cummins	DQKAF - Tie	r 2, 2250 kW			•			
10%	4,150	1.50	597.0	60.0	18.29	587.04	11.93	0.46	0.60	7.562E-02	0.63	7.974E-02	33.93	4.880E-04
25%	6,594	1.50	727.0	60.0	18.29	659.26	18.96	0.46	0.72	9.111E-02	0.76	9.607E-02	40.87	5.879E-04
50%	11,190	1.50	821.0	60.0	18.29	711.48	32.17	0.46	0.65	8.200E-02	0.69	8.646E-02	36.79	5.291E-04
75%	14,174	1.50	855.0	60.0	18.29	730.37	40.75	0.46	0.43	5.467E-02	0.46	5.764E-02	24.52	3.527E-04
100%	16,546	1.50	895.0	60.0	18.29	752.59	47.56	0.46	0.72	9.111E-02	0.76	9.607E-02	40.87	5.879E-04
						Cummins	DQKAN - Tie	r 2, 2500 kW			•		•	
10%	4,002	1.50	713.0	60.0	18.29	651.48	11.50	0.46	0.56	7.078E-02	0.59	7.463E-02	31.75	4.567E-04
25%	6,482	1.50	849.0	60.0	18.29	727.04	18.63	0.46	0.86	1.087E-01	0.91	1.146E-01	48.76	7.014E-04
50%	10,902	1.50	939.0	60.0	18.29	777.04	31.34	0.46	0.92	1.163E-01	0.97	1.226E-01	52.16	7.503E-04
75%	15,122	1.50	981.0	60.0	18.29	800.37	43.47	0.46	1.50	1.896E-01	1.59	1.999E-01	85.05	1.223E-03
100%	18,269	1.50	1022.0	60.0	18.29	823.15	52.52	0.46	2.01	2.528E-01	2.12	2.665E-01	113.40	1.631E-03
						Kohler K	D2250 - Tier	2, 2250 kW						
10%	4,469	1.50	734.0	60.0	18.29	663.15	12.85	0.46	0.15	1.944E-02	0.16	2.050E-02	8.72	1.254E-04
25%	7,148	1.50	847.4	60.0	18.29	726.15	20.55	0.46	0.65	8.158E-02	0.68	8.603E-02	36.60	5.264E-04
50%	12.031	1.50	842.0	60.0	18.29	723.15	34.59	0.46	0.36	4.513E-02	0.38	4.759E-02	20.25	2.912E-04
75%	17.296	1.50	836.6	60.0	18.29	720.15	49.72	0.46	0.74	9.373E-02	0.78	9.884E-02	42.05	6.048E-04
100%	18.132	1.50	843.8	60.0	18.29	724.15	52.12	0.46	0.39	4.860E-02	0.41	5.125E-02	21.80	3.136E-04
	-, -					Kohler k	D2500 - Tier	2, 2500 kW						
10%	4,674	1.50	759.2	60.0	18.29	677.15	13.44	0.46	0.27	3.375E-02	0.28	3.559E-02	15.14	2.178E-04
25%	7,599	1.50	867.2	60.0	18.29	737.15	21.85	0.46	0.60	7.500E-02	0.63	7.909E-02	33.65	4.840E-04
50%	12,865	1.50	836.6	60.0	18.29	720.15	36.98	0.46	0.45	5.625E-02	0.47	5.932E-02	25.24	3.630E-04
75%	18,916	1.50	867.2	60.0	18.29	737.15	54.38	0.46	0.89	1.125E-01	0.94	1.186E-01	50.47	7.260E-04
100%	18,340	1.50	852.8	60.0	18.29	729.15	52.72	0.46	0.60	7.500E-02	0.63	7.909E-02	33.65	4.840E-04
10% 25% 50% 75% 100%	4,674 7,599 12,865 18,916 18,340	1.50 1.50 1.50 1.50 1.50 1.50	759.2 867.2 836.6 867.2 852.8	60.0 60.0 60.0 60.0 60.0	18.29 18.29 18.29 18.29 18.29 18.29	677.15 737.15 720.15 737.15 729.15	13.44 21.85 36.98 54.38 52.72	0.46 0.46 0.46 0.46 0.46	0.27 0.60 0.45 0.89 0.60	3.375E-02 7.500E-02 5.625E-02 1.125E-01 7.500E-02	0.28 0.63 0.47 0.94 0.63	3.559E-02 7.909E-02 5.932E-02 1.186E-01 7.909E-02	15.14 33.65 25.24 50.47 33.65	2.178E-04 4.840E-04 3.630E-04 7.260E-04 4.840E-04

¹ Flow rate, temperature and corresponding hourly emission rate are summarized for each vendor and load where data is available.

Table E-6a. Modeled Rectangular Buildings

		UTM X	UTM Y	Elevation	Height	X Length	Y Length	Angle
Model ID	Description	(m)	(m)	(m)	(m)	(m)	(m)	(Degrees)
BUILD_D	New Building D	286910.1	5236112.2	395.5	8.08	158.2	80.60	2.9
BUILD_E	New Building E	286617.9	5236116.7	395.9	8.08	79.6	158.90	92.7

Table E-6b. Polygon Buildings

		UTM X	UTM Y	Elevation	Height
Model ID	Description	(m)	(m)	(m)	(m)
BLD_2	Existing Building	286582.87	5237178.33	407.7	9.14
BLD_5	Existing Building	285839.12	5236347.36	399.8	6.10
BLD_6	Existing Building	285885.78	5236347.4	399.6	6.10
BLD_8	Existing Building	285960.91	5236347.1	399.5	6.10
BLD_108	Existing Building	286007.3	5236347.36	399.5	6.10
BLD_109	Existing Building	285839.13	5236511.03	401.5	6.10
BLD_111	Existing Building	286884	5236274	397.0	8.53
BLD_116	Existing Building	287223	5236464.95	397.3	8.53
BLD_117	Existing Building	287218.45	5236317.87	396.1	8.53
BLD_1	Existing Building	287053.86	5236717.27	400.4	9.45
BLD_10	Existing Building	286957.5	5236983.37	403.8	9.45
BLD_21	Existing Building	287249.32	5237234.12	407.0	9.45
BLD_25	Existing Building	287036.46	5237231.36	407.3	9.45
BLD_22	Existing Building	287234.01	5237005.54	403.4	9.45
DWALLE	Genset Enclosure - Building D, East Side	287072.7	5236189.7	395.6	3.66
	Genset Enclosure - Building D, West				2.66
DWALLW	Side Genset Enclosure - Building E, East	286877.6	5236202.8	396.4	3.66
EWALLE	Side Genset Enclosure - Building F. West	286776.4	5236114.3	396.0	3.66
EWALLW	Side Genset Enclosure -	286618.4	5236121.8	396.0	3.66
DWALLSW	Building D, Southwest Side	286911	5236112.6	395.5	3.66
DWALLSE	Genset Enclosure - Building D, Southeast Side	287001.7	5236106.9	395.0	3.66
EWALLSW	Genset Enclosure - Building E, Southwest Side	286614.1	5236036.9	395.0	3.66
EWALLSE	Genset Enclosure - Building E, Southeast Side	286705.3	5236032.6	395.0	3.66

	Averaging	Background		Background
Pollutant	Doriod	Concentration/	Units	Concentration
	renou	Use ^a		$(\mu g/m^3)$
NO ₂	1-hr	68	$\mu g/m^3$	68
	Annual	3.5	ppb	6.6
PM ₁₀	24-hr	77.6	$\mu g/m^3$	77.6
PM _{2.5}	24-hr	18.9	$\mu g/m^3$	18.9
	Annual	5.8	$\mu g/m^3$	5.8
CO	1-hr	1.15	ppm	1316.5
	8-hr	0.81	ppm	927.3
03	PVMRM	52	ppb	102.0
	8-hr	57	ppb	111.8
S02	1-hr	2.9	ppb	7.6
	3-hr	5.4	ppb	14.1
	24-hr	0.9	ppb	2.4
	Annual	0.2	ppb	0.5
DPM	Annual	0.19	$\mu g/m^3$	0.19

Table E-7. Model Background Concentrations

^a Background concentrations for models provided by Ecology in email from Ranil Dhammapala, dated 1/3/20.

Table F-1. Maximum Modeled Concentrations - Main Generator Sets

Dollutant	Averagin				Maximur	n Modeled Co	ncentration	(μg/m ³)			
Fonutant	g Period	D12_10	D12_25	D12_50	D12_75	D12_100	D18_10	D18_25	D18_50	D18_75	D18_100
CO	8-HR	661.05	995.68	417.36	965.29	689.48	435.18	671.48	286.27	681.79	498.47
CO	1-HR	1031.75	1277.35	518.82	1168.32	840.83	780.99	957.90	403.83	922.48	637.97
NO _X	ANNUAL	70.01	66.80	89.93	122.29	204.18	59.92	66.80	101.91	147.12	254.25
NO _X	1-HR	1063.99	991.09	1536.19	2287.42	4109.24	805.39	743.23	1195.72	1806.08	3117.85
PM ₁₀	24-HR	109.58	111.79	117.06	132.22	148.79	80.41	80.65	82.49	91.78	102.16
PM _{2.5}	ANNUAL	16.41	12.66	9.90	9.69	10.03	14.04	12.66	11.21	11.65	12.49
PM _{2.5}	24-HR	109.58	111.79	117.06	132.22	148.79	80.41	80.65	82.49	91.78	102.16
SO ₂	3-HR	96.09	182.91	279.58	346.40	432.91	71.78	123.56	197.17	264.50	330.50
SO ₂	1-HR	120.29	200.46	299.69	392.76	489.14	91.06	150.33	233.27	310.11	371.13
TAPs	ANNUAL	2477.30	3172.53	3607.16	4227.60	4216.82	2120.38	3172.51	4087.40	5085.98	5250.91
TAPs	24-HR	16544.69	28019.14	42671.53	57701.62	62552.17	12140.56	20215.02	30071.32	40054.85	42946.71
TAPs	1-HR	37651.73	47068.59	61615.60	79075.07	84865.29	28500.68	35297.32	47959.56	62435.58	64390.80

Table F-2a. Maximum Modeled Concentrations - Support Engine S1

Dollutant	Averagin	Max	ximum Moo	leled Conce	entration (µ	ıg/m³)
ronutant	g Period	S1_10	S1_25	S1_50	S1_75	S1_100
CO	8-HR	34.39	75.57	130.87	42.35	22.31
CO	1-HR	90.91	182.54	298.73	95.31	50.11
NO _X	ANNUAL	2.98	3.14	4.72	9.19	22.77
NO _X	1-HR	61.31	64.22	98.61	198.76	503.30
PM ₁₀	24-HR	10.66	7.04	7.20	3.63	3.37
PM _{2.5}	ANNUAL	2.41	1.53	1.49	0.73	0.67
PM _{2.5}	24-HR	10.66	7.04	7.20	3.63	3.37
SO ₂	3-HR	68.41	143.63	246.82	345.19	442.56
SO ₂	1-HR	101.38	199.11	328.92	455.87	583.07
TAPs	ANNUAL	256.27	338.87	428.20	496.27	608.48
TAPs	24-HR	1133.82	1561.07	2073.96	2471.44	3075.58
TAPs	1-HR	5271.76	6928.88	8946.66	10728.03	13451.35

Table F-2b. Maximum Modeled Concentrations - Support Engine S2

Dollutant	Averagin	Max	ximum Moo	leled Conce	entration (µ	ıg/m³)
ronutant	g Period	S2_10	S2_25	S2_50	S2_75	S2_100
CO	8-HR	63.31	123.24	207.13	65.94	34.80
CO	1-HR	178.78	339.82	527.85	166.50	85.68
NO _X	ANNUAL	4.68	4.48	6.36	12.36	30.74
NO _X	1-HR	120.58	119.56	174.24	347.22	860.54
PM ₁₀	24-HR	25.71	15.51	14.87	7.54	6.98
PM _{2.5}	ANNUAL	3.79	2.18	2.00	0.98	0.90
PM _{2.5}	24-HR	25.71	15.51	14.87	7.54	6.98
SO ₂	3-HR	134.39	258.40	416.95	560.85	704.17
SO ₂	1-HR	199.37	370.66	581.20	796.39	996.92
TAPs	ANNUAL	402.52	483.06	576.72	667.18	821.49
TAPs	24-HR	2733.75	3438.48	4279.89	5130.04	6368.42
TAPs	1-HR	10367.47	12899.10	15808.73	18741.60	22998.94

	PM _{2.5} Modeled Maximum Concentration										NO _x Modeled Maximum Concentration									
			Annual					24-hr					Annual					1-hr		
Engine ID	10	25	50	75	100	10	25	50	75	100	10	25	50	75	100	10	25	50	75	100
D1	0.52694	0.37307	0.25318	0.24881	0.25933	7.1951	6.22609	4.28764	4.04238	4.48338	2.24832	1.9689	2.3011	3.14108	5.27895	62.31442	56.61259	86.31647	129.4088	229.4031
D2	0.58758	0.43452	0.30946	0.30584	0.31747	8.42763	7.67488	7.42579	7.5769	8.41736	2.50706	2.29319	2.81259	3.86104	6.46252	122.0735	98.85003	147.8565	218.3037	383.4654
D3	0.54261	0.42618	0.34256	0.34162	0.35374	7.91374	7.94647	7.77161	7.97376	8.68837	2.31519	2.24921	3.11339	4.31268	7.2009	121.256	101.3218	152.2051	226.1652	395.9836
D4	0.50494	0.43174	0.33919	0.3363	0.34756	8.1565	8.22193	8.39278	8.97588	9.66586	2.15448	2.27855	3.0828	4.24554	7.07504	99.26105	97.26093	146.3092	217.3586	384.5288
D5	0.45951	0.36185	0.30976	0.30451	0.31209	8.01081	8.08377	8.33279	9.03719	9.76467	1.96063	1.90968	2.81533	3.84428	6.35297	90.06616	92.29634	138.1908	205.7201	364.4504
D6	0.53779	0.30263	0.25826	0.25461	0.26265	5.2437	3.78168	2.89591	3.20791	3.58536	2.29463	1.59714	2.34728	3.21422	5.34663	75.03457	70.52239	107.8063	159.5077	284.0907
D7	0.48688	0.3756	0.28957	0.28189	0.29286	4.58435	4.22011	4.6151	5.29773	5.94803	2.0774	1.98224	2.63182	3.55868	5.96146	66.06387	63.37239	98.68692	147.5158	260.4482
D8	0.53506	0.41595	0.31925	0.30678	0.31743	5.40825	4.70111	5.10841	5.89449	6.72357	2.28296	2.1952	2.90153	3.87285	6.46165	71.01636	73.23169	115.2736	171.3091	303.3443
D9	0.59356	0.46814	0.36194	0.34651	0.35745	6.04775	5.18224	5.64871	6.53765	7.5139	2.53257	2.47062	3.28957	4.37438	7.27633	80.90656	83.6614	129.9141	193.1151	341.7785
D10	0.63171	0.49786	0.37521	0.37429	0.39234	5.74282	6.06828	6.51012	7.41416	8.44506	2.69535	2.62748	3.41015	4.72514	7.98652	81.19071	83.8572	121.3855	181.5275	321.6698
D11	0.65117	0.52039	0.40328	0.4056	0.42776	5.83691	6.17415	6.62663	7.5485	8.6102	2.7784	2.74639	3.66531	5.12046	8.70761	80.07499	82.03807	121.0216	178.7273	323.4268
D12	0.57642	0.2921	0.24206	0.24911	0.26654	8.23067	4.99896	3.53819	3.052	3.46778	2.45946	1.54157	2.20004	3.14488	5.42577	65.86217	63.54443	82.24613	118.2268	208.6203
D13	1.27068	1.01715	0.88548	0.9178	0.98201	10.9556	10.26041	10.02404	10.94575	12.14101	5.42167	5.36805	8.04778	11.58658	19.98992	98.97245	109.0085	162.2428	237.7506	420.1863
D14	1.24861	1.01061	0.8498	0.87663	0.93807	11.2452	10.3595	10.10677	11.64432	13.33579	5.32752	5.33356	7.72352	11.06676	19.09557	135.3281	136.8625	209.505	304.5843	543.3727
D15	1.23089	1.14976	1.05773	1.11095	1.20217	11.38439	10.48745	11.31246	13.0085	14.8873	5.25193	6.06793	9.61332	14.0249	24.47154	156.0583	156.7788	243.1862	357.8239	634.5597
D16	1.90432	1.82482	1.83068	2.01735	2.23384	10.63498	10.49971	11.15728	12.7596	14.55631	8.1253	9.63054	16.63846	25.4676	45.4725	144.8737	157.6384	240.7055	353.8154	627.6327
D17	1.90355	1.82046	1.81537	1.99587	2.20767	9.88443	9.97241	10.6156	12.11662	13.79601	8.122	9.60757	16.4993	25.19641	44.9397	129.059	140.5698	213.317	316.2005	560.982
D18	1.93329	1.84402	1.8144	1.9792	2.18289	11.75399	11.8627	12.28297	13.83602	15.6211	8.24889	9.7319	16.49041	24.98597	44.4353	149.5235	167.9295	263.5286	386.5572	676.6625
E1	0.78546	0.51593	0.30501	0.25527	0.23896	10.86856	8.97058	6.26204	5.94368	6.50503	3.35137	2.72286	2.77217	3.22265	4.86423	124.8004	112.1653	170.6784	252.7002	447.5384
E2	0.80969	0.56386	0.36649	0.30815	0.28941	10.89599	9.51389	6.77122	7.19239	8.19966	3.45476	2.9758	3.33091	3.89021	5.8913	142.2527	121.7337	184.3712	273.6115	483.6516
E3	0.82325	0.5785	0.3717	0.32419	0.31387	12.99581	12.88598	12.18153	12.22885	13.31387	3.51261	3.05308	3.37825	4.09264	6.38923	153.7884	129.8446	195.2961	290.8944	510.6281
E4	0.65661	0.49107	0.34396	0.31908	0.31364	10.52321	10.66148	11.0437	11.64994	12.37407	2.80161	2.59162	3.1261	4.02812	6.38456	109.8805	106.3506	159.5447	237.4719	419.1335
E5	0.55728	0.42331	0.29845	0.28029	0.28006	9.35501	9.41453	9.89095	10.6072	11.46114	2.37778	2.23403	2.7125	3.53851	5.70105	103.0513	98.8971	147.4145	219.6381	389.1109
E6	0.59902	0.25536	0.21411	0.21433	0.22432	6.61107	4.65041	3.44353	3.85203	4.32087	2.55586	1.34765	1.94599	2.70581	4.56624	85.67394	80.47026	123.3095	182.0868	321.5348
E7	0.77594	0.42101	0.25533	0.23422	0.23101	8.56948	9.06968	9.88629	11.32682	12.66	3.31076	2.22188	2.32063	2.95687	4.70245	139.9459	117.1887	178.4162	263.2952	467.4727
E8	0.79393	0.45885	0.28487	0.25959	0.2582	10.59591	10.96427	11.56188	13.08562	14.65891	3.38752	2.42163	2.58912	3.27718	5.25595	143.9231	116.4866	179.5071	262.4376	466.3402
E9	0.78014	0.48679	0.31316	0.28117	0.2787	10.75927	11.17881	11.85331	13.50692	15.24867	3.32867	2.56908	2.84616	3.54959	5.67332	134.2154	114.0698	176.0332	260.0762	457.3523
E10	0.46416	0.29181	0.21841	0.2214	0.23356	9.5841	10.016	10.76814	12.4179	14.23028	1.98044	1.54005	1.98505	2.79503	4.75432	103.413	104.7656	158.5629	234.5233	415.8326
E11	0.43771	0.2878	0.23172	0.23553	0.24889	8.82365	9.24606	9.99328	11.54402	13.19584	1.86761	1.51887	2.10598	2.97334	5.06645	97.11844	98.25182	156.8021	234.3337	404.4234
E12	0.58255	0.27837	0.17618	0.18132	0.1945	8.16045	5.15712	3.49265	2.63174	2.85465	2.48559	1.46913	1.60124	2.289	3.95925	77.87179	76.93586	119.97	177.2268	316.2415
E13	1.29819	1.03445	0.90549	0.93629	1.00264	13.26377	11.9965	11.07594	11.82784	12.99168	5.53907	5.45938	8.22969	11.82002	20.40991	112.6473	118.9623	176.9793	262.3916	467.1152
E14	1.47572	1.22734	1.04526	1.0945	1.18095	18.2524	15.89329	14.04304	14.7629	16.8874	6.29654	6.47736	9.49997	13.81725	24.03964	147.8541	151.3822	230.8656	341.9445	607.8807
E15	1.85039	1.51492	1.29829	1.34476	1.43671	24.7413	20.80459	17.56473	18.75075	21.39607	7.89516	7.99505	11.79974	16.97659	29.24593	178.933	185.2768	291.3752	436.8641	774.262
E16	2.04848	1.64261	1.33982	1.33195	1.39126	24.71502	23.40242	22.57058	24.9463	28.2056	8.74038	8.66892	12.17714	16.81487	28.3208	202.3917	221.8189	349.0549	516.9724	915.654
E17	1.75145	1.43238	1.18664	1.18713	1.24071	14.78948	15.01853	15.78623	17.81829	20.24489	7.47304	7.55945	10.785	14.98667	25.25613	172.7991	179.5544	270.3015	404.8348	720.129
E18	1.39776	1.16773	0.99349	1.00899	1.0592	11.60307	11.18633	12.33723	14.32135	16.45671	5.9639	6.16274	9.02945	12.73781	21.56118	138.5338	143.5136	216.7276	318.2801	568.7221

Table F-3. Individual Engine Load Analysis Results for $\mathrm{PM}_{2.5}$ and NO_{X}

Table F-4. Main Genset DPM Load Analysis Results

			D12					D18		
Make/Model	10%	25%	50%	75%	100%	10%	25%	50%	75%	100%
Cummins_DQKAN	0.03451	0.03631	0.02543	0.03107	0.03453	0.03018	0.03683	0.02914	0.03848	0.04464
Cummins_DQKAF	0.03782	0.03137	0.01818	0.00982	0.01408	0.03266	0.0315	0.02072	0.01184	0.01763
CAT_3516C	0.01745	0.01138	0.00737	0.00551	0.00677	0.01582	0.01202	0.00861	0.00681	0.00879
Kohler_KD2250	0.00878	0.02537	0.00936	0.01413	0.00699	0.00793	0.02628	0.01086	0.01775	0.00887
Kohler_KD2500	0.01467	0.02214	0.01105	0.01543	0.01064	0.01348	0.0233	0.01301	0.0198	0.01355

Table F-5. Support Genset DPM Load Analysis Results

			S1					S2		
Make/Model	10%	25%	50%	75%	100%	10%	25%	50%	75%	100%
Cummins_DQDAC	0.00301	0.00397	0.00449	0.00168	0.0017	0.00473	0.00566	0.00605	0.00226	0.0023
CAT_C9	0.0021	0.00292	0.00374	0.0016	0.00144	0.0031	0.00404	0.00503	0.00215	0.00195

Files are attached electronically. A directory of files is provided below.

Folder	File Name	Description				
\BPIP	Bpip input file Bpip output file	Files for BPIP inputs and outputs.				
	Bpip summary file					
\Load Analysis\CO	CLC1418.ami	AERMOD input and output files for the CO load				
	CLC1418.aml	analysis.				
\Load Analysis\DPM\Main Gensets	<i>Make_Model</i> .ami <i>Make_Model</i> .out	AERMOD input and output files for the DPM load analysis for each of the 5 main gensets being considered. File names are specified using the make and model of the given modeled engine.				
\Load Analysis\DPM\Supp ort Gensets	<i>Make_Model</i> .ami <i>Make_Model</i> .out	AERMOD input and output files for the DPM load analysis for both of the support gensets being considered. File names are specified using the make and model of the given modeled engine.				
\Load Analysis\NOx	NLC1418.ami NLC1418.aml	AERMOD input and output files for the NO ₂ load analysis.				
\Load Analysis\PM	PLC1418.ami PLC1418.aml	AERMOD input and output files for the $PM_{2.5}/PM_{10}$ load analysis.				
\Load Analysis\SO2	SLC1418.ami SLC1418.aml	AERMOD input and output files for the SO ₂ load analysis.				
\Load Analysis\TAP	TLC1418.ami TLC1418.aml	AERMOD input and output files for the TAP load analysis.				
\MET Data	MWHxx.PFL MWHxx.SFC	Meteorological files as inputs to AERMOD, including the surface file and upper air file. " <i>xx</i> " indicates the year among 2014-2018. The surface file and upper air file containing 2014-2018 data are also included in this folder.				
\Monte Carlo Script	MonteCarlo_script_parallel_ processing_Jan2019.R	A copy of the Monte Carlo script provided by Ecology, which is used to execute the Monte Carlo analysis for both NO_2 and $PM_{2.5}$				
\NAAQS Models\CO	CNCxx.ami CNCxx.aml	AERMOD input and output files for the CO NAAQS models. Model years are indicated by "xx" among 2014-2018.				
\NAAQS Models\NO2	NNC <i>xx</i> .ami NNC <i>xx</i> .aml	AERMOD input and output files for the NO ₂ NAAQS models. Model years are indicated by " <i>xx</i> " among 2014-2018. The model file that uses the concatenated 5-year meteorological data set is also included in this folder.				

Table G-1. Modeling Files Directory

Folder	File Name	Description					
	20200207_0055_MC_NO2_o utput.csv	Output file from the Monte Carlo Analysis					
	No2_e <i>yy</i> _month.mxd	Max daily output file from AERMOD for each of the 3 highest-contributing gensets, determined using the NO ₂ load analysis. These engines are used to represent the monthly testing of all gensets, per the model procedures outlined in Section 6 of this report. " <i>yy</i> " indicates the model ID of the particular genset.					
\NAAQS Models\NO2\R	No2_all_power.mxd	Max daily output file from AERMOD for the operating scenario where all gensets operate simultaneously for emergency operations, per the model procedures outlined in Section 6 of this report.					
	No2_e16.mxd	Max daily output file from AERMOD for the highest- contributing genset (model ID E16, 100% load). This file represents the operating scenario for maintenance and load testing for each genset, per the model procedures outlined in Section 6 of this report.					
	postfile_days_array.csv	File containing the index of Monte Carlo input files for use in the R script.					
	r_sabey_NO2.R	R script containing the command lines for executing the Monte Carlo script provided by Ecology.					
\NAAQS Models\PM2.5	PM2.5_24HR_NC1418.ami PM2.5_24HR_NC1418.out PM2.5_Annual_NC1418.ami PM2.5_Annual_NC1418.out	AERMOD input and output files for the PM2.5 NAAQS models.					
Folder	File Name	Description					
----------------------------	--	--					
\NAAQS Models\PM2.5\R	20200211_MC_PM25_outpu t.csv	Output file from the Monte Carlo Analysis					
	Pm25_e <i>yy_zz_</i> month.mxd	Max daily output file from AERMOD for each of the 3 highest-contributing gensets, determined using the $PM_{2.5}$ load analysis. These engines are used to represent the monthly testing of all gensets, per the model procedures outlined in Section 6 of this report. " <i>yy</i> " indicates the model ID and " <i>zz</i> " indicates the engine load of the particular genset.					
	Pm25_all_power.mxd	Max daily output file from AERMOD for the operating scenario where all gensets operate simultaneously for emergency operations, per the model procedures outlined in Section 6 of this report.					
	Pm25_e16_100.mxd	Max daily output file from AERMOD for the highest- contributing genset (model ID E16, 100% load). This file represents the operating scenario for maintenance and load testing for each genset, per the model procedures outlined in Section 6 of this report.					
	postfile_days_array.csv	File containing the index of Monte Carlo input files for use in the R script.					
	r_sabey_PM25.R	R script containing the command lines for executing the Monte Carlo script provided by Ecology.					
\NAAQS Models\PM10	PM10_24HR_NC1418.ami PM10_24HR_NC1418.out	AERMOD input and output files for the PM_{10} NAAQS model.					
\NAAQS Models\SO2	SO2_1HR_NC1418.ami SO2_1HR_NC1418.out SO2_3HR_NC1418.ami SO2_3HR_NC1418.out	AERMOD input and output files for the SO ₂ NAAQS models (with the file name indicating the averaging period of the given model).					
\TAP Models\Acrolein	ATC1418.ami ATC1418.out	AERMOD input and output files for the Acrolein TAP model.					
\TAP Models\Benzene	BTCxx.ami BTCxx.out	AERMOD input and output files for the Benzene TAP models. Model years are indicated by " <i>xx</i> " among 2014-2018.					
\TAP Models\CO	CTC1418.ami CTC1418.out	AERMOD input and output files for the CO TAP model.					
\TAP Models\DPM	DTCxx.ami DTCxx.out	AERMOD input and output files for the DPM TAP models. Model years are indicated by "xx" among 2014-2018.					
\TAP Models\Naphthalene	NaTC <i>xx</i> .ami NaTC <i>xx</i> .out	AERMOD input and output files for the Naphthalene TAP models. Model years are indicated by " <i>xx</i> " among 2014-2018.					
\TAP Models\NO2	NTC <i>xx</i> .ami NTC <i>xx</i> .out	AERMOD input and output files for the NO2 TAP models. Model years are indicated by " <i>xx</i> " among 2014-2018.					

Folder	File Name	Description
\TAP Models\SO2	STCxx.ami STCxx.out	AERMOD input and output files for the SO ₂ TAP models. Model years are indicated by " <i>xx</i> " among 2014-2018.